

WATER MINIMIZATION ASSESSMENT - HEALTH SCIENCES CENTRE, WINNIPEG, MANITOBA

58

By

Bruce Baird

A Practicum Submitted to the Faculty of Graduate Studies
In Partial Fulfillment of the Requirements
for the Degree of

MASTER OF NATURAL RESOURCES MANAGEMENT

Natural Resources Institute
The University of Manitoba
Winnipeg, Manitoba
R3T 2N2

June 23, 1996



National Library
of Canada

Acquisitions and
Bibliographic Services Branch

395 Wellington Street
Ottawa, Ontario
K1A 0N4

Bibliothèque nationale
du Canada

Direction des acquisitions et
des services bibliographiques

395, rue Wellington
Ottawa (Ontario)
K1A 0N4

Your file Votre référence

Our file Notre référence

The author has granted an irrevocable non-exclusive licence allowing the National Library of Canada to reproduce, loan, distribute or sell copies of his/her thesis by any means and in any form or format, making this thesis available to interested persons.

L'auteur a accordé une licence irrévocable et non exclusive permettant à la Bibliothèque nationale du Canada de reproduire, prêter, distribuer ou vendre des copies de sa thèse de quelque manière et sous quelque forme que ce soit pour mettre des exemplaires de cette thèse à la disposition des personnes intéressées.

The author retains ownership of the copyright in his/her thesis. Neither the thesis nor substantial extracts from it may be printed or otherwise reproduced without his/her permission.

L'auteur conserve la propriété du droit d'auteur qui protège sa thèse. Ni la thèse ni des extraits substantiels de celle-ci ne doivent être imprimés ou autrement reproduits sans son autorisation.

ISBN 0-612-12969-1

Canada

Name Bruce BARRI

Dissertation Abstracts International and Masters Abstracts International are arranged by broad, general subject categories. Please select the one subject which most nearly describes the content of your dissertation or thesis. Enter the corresponding four-digit code in the spaces provided.

Environmental Sciences

SUBJECT TERM

0768

UMI

SUBJECT CODE

Subject Categories

THE HUMANITIES AND SOCIAL SCIENCES

COMMUNICATIONS AND THE ARTS

Architecture 0729
Art History 0377
Cinema 0900
Dance 0378
Fine Arts 0357
Information Science 0723
Journalism 0391
Library Science 0399
Mass Communications 0708
Music 0413
Speech Communication 0459
Theater 0465

EDUCATION

General 0515
Administration 0514
Adult and Continuing 0516
Agricultural 0517
Art 0273
Bilingual and Multicultural 0282
Business 0688
Community College 0275
Curriculum and Instruction 0727
Early Childhood 0518
Elementary 0524
Finance 0277
Guidance and Counseling 0519
Health 0680
Higher 0745
History of 0520
Home Economics 0278
Industrial 0521
Language and Literature 0279
Mathematics 0280
Music 0522
Philosophy of 0998
Physical 0523

Psychology 0525
Reading 0535
Religious 0527
Sciences 0714
Secondary 0533
Social Sciences 0534
Sociology of 0340
Special 0529
Teacher Training 0530
Technology 0710
Tests and Measurements 0288
Vocational 0747

LANGUAGE, LITERATURE AND LINGUISTICS

Language
General 0679
Ancient 0289
Linguistics 0290
Modern 0291
Literature
General 0401
Classical 0294
Comparative 0295
Medieval 0297
Modern 0298
African 0316
American 0591
Asian 0305
Canadian (English) 0352
Canadian (French) 0355
English 0593
Germanic 0311
Latin American 0312
Middle Eastern 0315
Romance 0313
Slavic and East European 0314

PHILOSOPHY, RELIGION AND THEOLOGY

Philosophy 0422
Religion
General 0318
Biblical Studies 0321
Clergy 0319
History of 0320
Philosophy of 0322
Theology 0469

SOCIAL SCIENCES

American Studies 0323
Anthropology
Archaeology 0324
Cultural 0326
Physical 0327
Business Administration
General 0310
Accounting 0272
Banking 0770
Management 0454
Marketing 0338
Canadian Studies 0385
Economics
General 0501
Agricultural 0503
Commerce-Business 0505
Finance 0508
History 0509
Labor 0510
Theory 0511
Folklore 0358
Geography 0366
Gerontology 0351
History
General 0578

Ancient 0579
Medieval 0581
Modern 0582
Black 0328
African 0331
Asia, Australia and Oceania 0332
Canadian 0334
European 0335
Latin American 0336
Middle Eastern 0333
United States 0337
History of Science 0585
Law 0398
Political Science
General 0615
International Law and Relations 0616
Public Administration 0617
Recreation 0814
Social Work 0452
Sociology
General 0626
Criminology and Penology 0627
Demography 0938
Ethnic and Racial Studies 0631
Individual and Family Studies 0628
Industrial and Labor Relations 0629
Public and Social Welfare 0630
Social Structure and Development 0700
Theory and Methods 0344
Transportation 0709
Urban and Regional Planning 0999
Women's Studies 0453

THE SCIENCES AND ENGINEERING

BIOLOGICAL SCIENCES

Agriculture
General 0473
Agronomy 0285
Animal Culture and Nutrition 0475
Animal Pathology 0476
Food Science and Technology 0359
Forestry and Wildlife 0478
Plant Culture 0479
Plant Pathology 0480
Plant Physiology 0817
Range Management 0777
Wood Technology 0746
Biology
General 0306
Anatomy 0287
Biostatistics 0308
Botany 0309
Cell 0379
Ecology 0329
Entomology 0353
Genetics 0369
Limnology 0793
Microbiology 0410
Molecular 0307
Neuroscience 0317
Oceanography 0416
Physiology 0433
Radiation 0821
Veterinary Science 0778
Zoology 0472
Biophysics
General 0786
Medical 0760

EARTH SCIENCES

Biogeochemistry 0425
Geochemistry 0996

Geodesy 0370
Geology 0372
Geophysics 0373
Hydrology 0388
Mineralogy 0411
Paleobotany 0345
Paleoecology 0426
Paleontology 0418
Paleozoology 0985
Palynology 0427
Physical Geography 0368
Physical Oceanography 0415

HEALTH AND ENVIRONMENTAL SCIENCES

Environmental Sciences 0768
Health Sciences
General 0566
Audiology 0300
Chemotherapy 0992
Dentistry 0567
Education 0350
Hospital Management 0769
Human Development 0758
Immunology 0982
Medicine and Surgery 0564
Mental Health 0347
Nursing 0569
Nutrition 0570
Obstetrics and Gynecology 0380
Occupational Health and Therapy 0354
Ophthalmology 0381
Pathology 0571
Pharmacology 0419
Pharmacy 0572
Physical Therapy 0382
Public Health 0573
Radiology 0574
Recreation 0575

Speech Pathology 0460
Toxicology 0383
Home Economics 0386

PHYSICAL SCIENCES

Pure Sciences
Chemistry
General 0485
Agricultural 0749
Analytical 0486
Biochemistry 0487
Inorganic 0488
Nuclear 0738
Organic 0490
Pharmaceutical 0491
Physical 0494
Polymer 0495
Radiation 0754
Mathematics 0405
Physics
General 0605
Acoustics 0986
Astronomy and Astrophysics 0606
Atmospheric Science 0608
Atomic 0748
Electronics and Electricity 0607
Elementary Particles and High Energy 0798
Fluid and Plasma 0759
Molecular 0609
Nuclear 0610
Optics 0752
Radiation 0756
Solid State 0611
Statistics 0463
Applied Sciences
Applied Mechanics 0346
Computer Science 0984

Engineering
General 0537
Aerospace 0538
Agricultural 0539
Automotive 0540
Biomedical 0541
Chemical 0542
Civil 0543
Electronics and Electrical 0544
Heat and Thermodynamics 0348
Hydraulic 0545
Industrial 0546
Marine 0547
Materials Science 0794
Mechanical 0548
Metallurgy 0743
Mining 0551
Nuclear 0552
Packaging 0549
Petroleum 0765
Sanitary and Municipal 0554
System Science 0790
Geotechnology 0428
Operations Research 0796
Plastics Technology 0795
Textile Technology 0994

PSYCHOLOGY

General 0621
Behavioral 0384
Clinical 0622
Developmental 0620
Experimental 0623
Industrial 0624
Personality 0625
Physiological 0989
Psychobiology 0349
Psychometrics 0632
Social 0451

**WATER MINIMIZATION ASSESSMENT - HEALTH
SCIENCES CENTRE, WINNIPEG, MANITOBA**

By

Mr. Bruce Baird

A practicum submitted to the Faculty of Graduate Studies of the University of Manitoba in partial fulfilment of the requirements of the degree of Master of Natural Resources Management.

©1996

Permission has been granted to the LIBRARY OF THE UNIVERSITY OF MANITOBA to lend or sell copies of this practicum, to the NATIONAL LIBRARY OF CANADA to microfilm this practicum and to lend or sell copies of the film, and UNIVERSITY MICROFILMS to publish an abstract of this practicum.


The author reserves other publication rights, and neither the practicum nor extensive extracts from it may be printed or otherwise reproduced without the author's permission.

Executive Summary

The Health Sciences Centre (HSC) is the second largest water user in the City of Winnipeg consuming more than 260,000 hundred cubic feet (CCF) of water per year (742 million liters/yr). Over the past ten years consumption has remained relatively constant (slight decreasing trend since 1990), yet the cost of consumption has nearly doubled. This trend should continue as the City of Winnipeg's water and sewer rates are projected to increase by approximately 10-12% per year. The purpose of this research therefore, was to conduct a Water Minimization Assessment to identify and evaluate a variety of water conservation measures as a first step toward reducing water-related expenditures. Specific objectives included: i) identifying and documenting water consumption associated with HSCs major water use categories; ii) identifying and evaluating water conservation options available; and, iii) prioritizing the implementation of feasible options.

To evaluate potential options, consumption estimates were required. A literature review and personal communications identified 11 major water use categories. Per category consumption estimates (see exhibit) were derived using information pertaining to flow duration and flow rate, by methods such as: metering, published values, non-structured interviews, accelerated current logging, timed volume measurements, and technical specifications. Once consumption estimates were derived, a review of trade journals and personal communications identified a number of water conservation options available to HSC. The economic feasibility of each option was evaluated based on capital and operating costs, annual cost savings, and payback periods. Using a 5 year payback period cut-off, replacing dishwashers based on energy and water savings alone was not feasible. The remaining options; year round supply of chilled water as a heat sink for water-cooled condensers, 90% recirculating retrofit kits for two medical vacuum pumps, and converting three water-cooled condensers to air-cooled; were feasible and subjected to a negative bias sensitivity analysis. Factors that could affect an options feasibility or implementation prioritization, such as cost increases (+25% and +50%), consumption overestimation (-10%, -25%, and -50%), and water rate increases

lower than expected (0%/yr and 5.3%/yr) were included to identify high and low sensitivity estimates for each option's payback period and five and twenty year net present values (NPV). Each option was then prioritized according to its five year NPV. As a result of the analysis, HSC should implement recommendations one to three in the order in which they appear.



1. HSC should proceed with the installation of the winter chilled water supply as described by Scouten Mitchell Sigurdson (SMS) (1996) so as to provide year round chilled water.

With year round chilled water available, almost all of the water-cooled condensing units can be converted to use the existing chilled water loop. This project will cost approximately \$800,000 with a payback period between 3.4 to 4.6 years. It is the most significant water minimization option, as it represents 25.5% (66,711 CCF) of overall consumption.

2. HSC should proceed with the technical assessment required to operate the medical vacuum pumps in CS-008 and GG-048 at 90% recirculation.

Retrofitting these units will reduce overall consumption by 5819 CCF/yr or 2.2%. These retrofits have payback periods between 1.6 to 3.5 years for CS-008 and 1.2 to 2.6 years for GG-048.

3. HSC should convert three water-cooled condenser units not feasible in the SMS (1996) proposal (BA-001, GF-632, and GC-420) to air-cooled units.

Converting these units will reduce overall consumption by 4938 CCF/yr or 1.9%. The payback periods associated with these conversions are: 3.4 to 4.6 (BA-001), 1.8 to 3.5 (GF-632), and 3.3 to 6.7 (GC-420).

Implementing these water conservation options (recommendations 1-3) will reduce overall consumption by 82,204 CCF/yr or 31.4%. Additional savings are, or soon will be realized, as a result of on-going projects (replacing packing seals with mechanical seals in HSCs chilled water pumps and Dietetics Department restructuring eliminating the Oasis Cafeteria's dishwasher) and recently completed projects (sterilizer retrofits/replacements and a recirculating loop for the Central Energy Plant's air compressors). These should reduce overall consumption by 17,049 CCF/yr or 6.5%. Overall consumption can be reduced by 37.9% or 99,250 CCF/yr yielding annual cost savings of approximately \$370,000.

Potential exists for additional savings as no water minimization recommendations were made with respect to HSCs largest water use, Domestic Consumption. It is recommended that HSC conduct a separate study pertaining to Domestic water minimization for hospitals that includes input from a variety of stakeholders to ensure implementation.

Acknowledgments

I would like to thank Mr. David Koslowsky for believing in the idea and securing funding for the project, as well as his on-going advice and input. Thanks also goes to Dr. John Sinclair for his guidance and advice as my faculty adviser over the past year. I am grateful to my Practicum Committee for their invaluable input and constructive criticism. Thank you, Dr. John Sinclair (Natural Resources Institute), Mr. David Koslowsky (Health Sciences Centre), Dr. David Morgan (TetrES Consultants Inc.), and Dr. Daryl McCartney (University of Manitoba, Engineering).

I would also like to thank the staff at HSC for being extremely helpful by answering all my questions. In particular, Sally Plante and Ed Lehmann and the gents in the Central Energy Plant; Gord Berg and the guys in the Plumbing Shop; Larry Drebniski for downloading the ACR data, Manny Bettencourt; and Jane Maslowski for their time, advice, and information regarding HSC water use.

Loads of thanks to Jude at the NRI for keeping things organized.

TABLE OF CONTENTS

Executive Summary	ii
Acknowledgments	v
List Of Tables	viii
List Of Figures	viii
List Of Appendices	viii
 Chapter 1 Introduction.....	 1
1.1 Background.....	1
1.1.1 Water & Sewer Rates in Winnipeg.....	1
1.1.2 Water Use at the Health Sciences Centre	2
1.2 Issue Statement.....	2
1.3 Objectives	3
1.4 Methods	3
1.5 Limitations.....	6
1.6 Assumptions	7
1.7 Organizational Preview	7
 Chapter 2 Water Management and Conservation Practices	 8
2.1 Introduction	8
2.2 Municipal Water Management	8
2.3 Technical Water Conservation Options Available To HSC	9
2.3.1 Toilet Replacements	9
2.3.2 Flush Valves	9
2.3.3 Showerheads	9
2.3.4 Faucets	10
2.3.5 Chilled Water Loops And Cooling Towers	10
2.3.5.1 Evaporation.....	10
2.3.5.2 Bleed-Off.....	11
2.3.5.4 Leakage Within The Distribution System	11
2.3.6 Medical Air & Vacuum Pumps.....	11
2.3.7 X-Ray Processors	12
2.3.8 Sterilizers And Autoclaves	12
2.4 Conducting A Water Minimization Assessment.....	13
2.4.1 Planning And Organization	13
2.4.2 Assessment Phase	14
2.4.2.1 Water Use Inventory.....	14
2.4.3 Feasibility Analysis.....	16
2.5 Summary.....	16
 Chapter 3 Major Water Use Consumption Estimation	 18
3.1 Introduction	18

3.2 Use Category Methodology And Water Consumption Estimates	18
3.2.1 Sterilizers	18
3.2.2 Dialysis.....	20
3.2.3 Kitchen And Cafeteria	20
3.2.4 Water Softening (Steam Production)	21
3.2.5 Air Compressors	22
3.2.6 Cooling Tower And Chilled Water Makeup	22
3.2.7 X-Ray Processing	22
3.2.8 Medical Vacuum & Medical Air Pumps.....	23
3.2.9 Domestic.....	25
3.2.10 Hot Water.....	26
3.2.11 Water-Cooled Condensers	28
3.3 Summary.....	30
Chapter 4 Feasibility Analysis	32
4.1 Introduction	32
4.2 Sterilizers	32
4.3 Dialysis.....	32
4.4 Kitchen And Cafeteria.....	32
4.5 Water Softening (Steam Production)	33
4.6 Air Compressors	33
4.7 Cooling Tower And Chilled Water Makeup	33
4.8 X-Ray Processing	34
4.9 Medical Vacuum & Medical Air Pumps.....	34
4.10 Domestic.....	35
4.11 Hot Water	36
4.12 Water-Cooled Condensers	36
4.13 Economic Evaluation and Prioritization of Water Saving Measures.....	37
4.14 Summary.....	39
Chapter 5 Conclusion and Recommendations	40
5.1 Conclusion	40
5.2 Recommendations	40
Bibliography	47
Personal Communications	50
Written Communications	52

LIST OF TABLES

Table 1.1 Method Used to Determine Water Consumption for HSCs Major Water Uses.....	5
Table 3.1 Water Consumption Associated with Sterilizer Use.....	19
Table 3.2 Water Consumption Associated with Dialysis.....	20
Table 3.3 Water Consumption Associated with Kitchen and Cafeteria Use.....	21
Table 3.4 Water Consumption Associated with X-Ray Processing.....	23
Table 3.5 Water Consumption Associated with Medical Vacuum and Medical Air Pumps.....	24
Table 3.6 Estimated Consumption per Person per Day.....	25
Table 3.7 Water Consumption Associated with Domestic Water Production.....	26
Table 3.8 Hot Water Consumption per Square Foot.....	27
Table 3.9 Water Consumption Associated with Hot Water Production.....	28
Table 3.10 Health Sciences Centre Major Water Use Consumption Estimates.....	31
Table 4.1 Economic Evaluation of Water Conservation Options.....	38
Table 4.2 Sensitivity Analysis and Prioritization of Water Conservation Options.....	38
Table 5.1 Summary of Water Conservation Options Available to HSC.....	42

LIST OF FIGURES

Figure 1.1 HSC Water Consumption and Cost.....	2
Figure 1.2 Water Minimization Assessment Procedure.....	4
Figure 5.1 HSCs Major Water Use Consumption Estimates.....	41

LIST OF APPENDICES

Appendix A List of Abbreviations.....	53
Appendix B HSC Water Meter Information.....	57
Appendix C Theoretical vs. Actual Flow Rates for HSC Condensers.....	59
Appendix D HSC Condenser Loads.....	61
Appendix E Water-Cooled Condensers Summer and Winter Consumption.....	63
Appendix F Water Balance Accuracy Assessment.....	68
Appendix G Financial Services Condenser's Consumption Methodology.....	71

Chapter 1 Introduction

1.1 Background

1.1.1 Water & Sewer Rates in Winnipeg

During the 1996 fiscal year, the cost of consuming water for large industrial or institutional users was \$3.74/ hundred cubic feet (water rate = \$1.18/CCF (hundred cubic feet) and the sewer rate = \$2.56/CCF). These rates have been, and will continue to, increase as a result of the provincial government's Sustainable Development strategy for the Capital Region, which includes Winnipeg. Policy 2.6f (Water Service) of the strategy states that Provincial and Municipal governments should "adopt water pricing systems and amend by-laws to encourage water conservation and to pay for infrastructure renewal" (Manitoba Round Table on Environment and Economy, 1995, p.29).

Winnipeg City Council has adopted this strategy by incorporating price rate increases in their water supply plan (Wardrop Engineering Inc., 1992). Although recently, City Council has proposed, but not approved, a 35% reduction in the sewer rate (Free Press, June 6, 1996) for large water users in hope of promoting economic development. The benefits from a lower sewer rate should be short-lived¹, as the sewer rate increases were designed to help offset the City's increased borrowing costs for a \$150 million upgrade to the water treatment facilities (Free Press, June 6, 1996). The water rate, on the other hand, has and should continue to increase by approximately 10% per year over the next few years (Chartier, 1995) in order to generate revenue for aqueduct rehabilitation and future expansion of Winnipeg's water supply (Wardrop Engineering Inc., 1992). As water is being allocated on a full cost basis, the result is a mid to long term trend toward higher water and sewer rates for all users.

¹ HSC experienced a price rate drop in the 1988/89 fiscal year, but the price rate increased thereafter (see Figure 1.1).

1.1.2 Water Use at the Health Sciences Centre

Large institutional water users, like the Health Sciences Centre (HSC), can use water conservation as a means of controlling and reducing water-related expenditures.

Figure 1.1

illustrates that water consumption at HSC has remained relatively constant over the past 10 years, but the cost associated with this consumption (water and




Figure 1.1 HSC Water Consumption and Cost.

sewer) has nearly doubled (not adjusted for inflation). Conservation which reduces consumption and costs takes many forms, from reducing wasteful practices; to repairing leaking fixtures and pipes; to retrofitting or replacing older and less efficient fixtures and appliances with efficient ones (Environment Canada, 1990); as well as, reusing existing water within a closed loop system.

1.2 Issue Statement

The Health Sciences Centre (HSC) is a major tertiary care teaching hospital comprised of 26 buildings on a 32 acre site (Koslowsky, 1995) and is the second largest water user in the City of Winnipeg (Parbery, 1994; Wardrop Engineering Inc., 1992). In the 1994/95 fiscal year (Apr. 1/94 to Mar. 31/95) HSC used 261,869 CCF of water at a cost of \$769,350. Unless water conservation techniques are employed, water related costs will double in just under eight years. Thus, a water minimization assessment is a

necessary first step in order to reduce future water related expenditures and conserve water resources.

1.3 Objectives

The objectives of this study were:

1. to identify and document water consumption associated with the major water uses at HSC;
2. identify and evaluate water minimization options available for the major water uses identified in objective 1; and
3. prioritize water conservation options available for HSC.

1.4 Methods

The Water Minimization Assessment Procedure² (EPA, 1990), identified in figure 1.2, establishes a systematic framework from which to evaluate potential conservation measures. However, this research report deals only with the first three phases, as obtaining funding required for installation was beyond the report's scope.

Within this framework, the methodology used to derive consumption estimates was similar to that used by Black and Veatch (1991a & 1991b). Estimating consumption required information pertaining to flow duration and flow rate. Flow duration and flow rate estimates were obtained by:

- i. accelerated current logging to determine average run times, where the drawing of amperes was used as a proxy for run time;
- ii. timed volume measurements to determine flow rates;
- iii. in-hospital documentation (technical specifications, data files, etc.) to determine flow rates, or consumption per use estimates;

² The US Environmental Protection Agency developed a Waste Minimization Assessment Procedure for waste water. However to avoid confusion, it will be referred to as a Water Minimization Assessment Procedure.

- iv. non-structured informal surveys to establish frequency of use and hours of operation estimates;
- v. published values to determine flow rates and consumption estimates; and
- vi. water meters to determine consumption over a specified period of time.




Figure 1.2 Water Minimization Assessment Procedure

Source: EPA, 1990.

Table 1.1 illustrates the techniques used to derive consumption estimates for each of HSCs major water uses³.

Table 1.1 Method Used to Determine Water Consumption for HSCs Major Water Uses.

Major Water Use Category	Method Utilized					
	M	PV	NSI	AC	TV	ED
Sterilizer Use			✓			✓
Dialysis	✓					
Kitchen & Cafeteria Use			✓			✓
Water Softening (Steam Production)	✓					
Air Compressors	✓					
Cooling Tower Makeup	✓					
X-Ray Processing			✓			✓
Medical Vacuum & Medical Air				✓		✓
Domestic		✓	✓			
Hot Water	See Section 3.2.10					
Water-Cooled Condensers	✓			✓	✓	✓

Legend:

✓	Included	AC	Accelerated Current
M	Water Meter	TV	Timed Volume
PV	Published Value	ED	Existing Data within HSC
NSI	Non-Structured Interview		

Once per category estimates were derived, they were compared to the hospital's average annual consumption (based on consumption from the previous two years)⁴, via a water balance, in order to ensure estimated consumption equals actual consumption. Although not precise, this methodology does give a good indication of annual water usage, from which to evaluate a variety of water conservation measures.

³ Black and Veatch (1991a & 1991b) and Wilson (1994) identified major water uses for hospitals when they audited two hospitals in the Los Angeles area.

⁴ See Appendix B.

A review of trade publications and hospital journals, as well as personal communications identified water conservation techniques available for hospitals. From which, the feasibility of these options were evaluated based on capital and operating costs, annual cost savings, and payback periods.

1.5 Limitations

A number of limitations are present. First, the focus of the Water Minimization Assessment was to gather information concerning major water uses where significant cost savings may be realized. As a result, no information was gathered for the following:

- drinking fountains
- labs
- janitor and utility rooms
- operating rooms

Secondly, the water assessment primarily used time of use and flow rates to estimate consumption. It is realized that this is the least precise water auditing methodology; however due to the number of sensitive areas, pumps and fixtures, and plumbing complexities, it was deemed necessary.

Thirdly, ACR current logging measurements required the services of the Electrical Shop to install and remove the device. However, measurements were only taken when time permitted due to the lack of available resources resulting in a sample size of fifteen, not twenty-five.

Fourthly, samples associated with the water-cooled condensers were not truly random. Condensers that were difficult to access were excluded from the sampling list. The remaining condensers were randomly sampled.

Finally, only those buildings which are billed (water) directly to the Health Sciences Centre Energy Management Department were included in the study (Table 1.1).

1.6 Assumptions

Some assumptions were used throughout the Research Report and are noted at the time of use.

1.7 Organizational Preview

Chapter one has outlined the study's objectives, methodology employed to meet those objectives, and the reasoning behind them. The following chapter will explore the existing literature regarding water conservation, conservation practices and techniques available to HSC, and what is involved in a water minimization assessment (Chapter 2); Chapter 3, the assessment phase, will detail the methodology used to obtain each consumption estimate; Chapter 4, the feasibility analysis phase, will examine the economic feasibility of the various minimization options; and finally, Chapter 5 summarizes the findings from Chapter's 3 and 4, from which recommendations are based.

Chapter 2 Water Management and Conservation Practices

2.1 Introduction

As a first step, the literature was used to identify current water management approaches available to municipalities; resulting in a noticeable trend toward demand management principles creating an incentive for all water users to conserve, especially large water users. The result is a number of water conservation options are available to HSC. However, to effectively evaluate such options requires a methodological approach for estimating water consumption.

2.2 Municipal Water Management

Municipal water is managed according to two principles, demand-side management or conservation and supply management or supply augmentation. These principles work in conjunction with each other, yet in many regions there has been a noticeable shift toward demand management as a result of slowing population growth (consumptive growth) and limited capital budgets. As for Winnipeg, conservation measures (i.e. price rate changes) are being used to delay infrastructure improvements into the future while generating capital reserves for future construction costs (at present) and to reduce the City's debt load associated with upgrading existing facilities.

Municipal governments are limited by provincial regulators as to which conservation measures council can enact (REIC Ltd. and Associates, 1991). REIC Ltd. and Associates (1991) explained that municipalities cannot legislate water conservation measures beyond lawn watering bans nor adopt stricter standards than those imposed by the province (e.g. plumbing or building codes). The latter which, limits a municipality from mandating water-conserving fixtures (REIC Ltd., 1991). Thus, incentive programs and rate changes are the only conservation measures that a municipality can enact that would directly impact institutional water users, such as the Health Sciences Centre. At present, Winnipeg does not have an incentive program for replacing inefficient fixtures, although Council has adopted a strategy to increase water and sewer rates over the

next few years. Such increases will significantly impact large volume users unless they begin to adopt a variety of water conservation measures.

2.3 Technical Water Conservation Options Available To HSC

As water and sewer rates increase, water conserving technologies can be used by institutional users to offset the increasing cost of using large volumes of water. These technologies take many forms, such as; retrofitting or replacing water-inefficient fixtures, or utilizing a closed loop cooling system.

2.3.1 Toilet Replacements

Toilet replacements are relatively costly (Gates, 1994), but can result in significant reductions in water usage. Changing the conventional 20L toilet to a ultra-low volume (ULV) model (less than 6L per flush) can result in water use savings of approximately 70% (REIC Ltd., 1992). In the past, the main disadvantage with ULVs was only a limited number of CSA (Canadian Standards Association) approved models were available (Gates, 1994).

2.3.2 Flush Valves

Flush valves are used to control the flow rate in urinals and tankless toilets. Valve operated toilets use approximately 19-25L per flush, but can be retrofitted with a flow control valve to reduce water consumption to 15L per flush (Environment Canada, 1993). Urinals on the other hand use considerably less water than the standard toilet (7-9L per flush), with further savings achieved by installing a water-saving flush valve that only uses 3L per flush (Environment Canada, 1993).

2.3.3 Showerheads

Conventional showerheads in many commercial institutions use between 13-19L per minute (Brooks and Peters, 1988) or approximately 100L per use (Environment Canada, 1993). Properly engineered showerheads (reducing water consumption without sacrificing performance) have been developed reducing water consumption to between 6-10L per minute (REIC Ltd. and Associates, 1991).

2.3.4 Faucets

Conventional kitchen and bathroom faucets deliver between 11-13L per minute during normal use (Brooks and Peters, 1988), far more than is required for most cases (REIC Ltd. and Associates, 1991). Low-flow faucet aerators can reduce flow rates by approximately 50% (REIC Ltd. and Associates, 1991), while automatic shut-off features (e.g. infrared sensors) can achieve further economies in the order of 85% of the total flow (Brooks and Peters, 1988). The aerator chosen must match the intended use of the fixture (REIC Ltd. and Associates, 1991).

2.3.5 Chilled Water Loops And Cooling Towers

Air conditioning, refrigeration systems, as well as many industrial processes require chilled water to act as a heat sink (Marley, 1982). Chilled water loops and cooling towers work in conjunction with one another as water is continuously heated (e.g. heat sink for pump cooling) and then cooled (via the cooling tower). The main reasoning behind such systems is to reduce energy costs by using the temperature differential between the ambient air and water entering the tower. This differential results in heat being dissipated through evaporation from the tower water to the atmosphere.

In addition to energy savings, water and sewer related expenses are minimized as the water is utilized more than once. The number of times water circulates around a cooling loop (cycles) depends upon the treatment method used to maintain the specified quality. In fact, water is only lost from the system in one of four ways: evaporation, bleed-off (Black and Veatch, n.d.), and leakage. Makeup water is then required to account for such losses.

2.3.5.1 Evaporation

Cooling towers use evaporation to cool the water within the system. The evaporative rate is largely dependent on the amount of cooling achieved, approximately 1% of the rate of recirculating water for every 10°F temperature drop achieved by the tower or approximately 2.4 gpm per 100 tons of cooling (Black and Veatch, n.d.). Many large water and sewer authorities give credit for water that does not enter into the Municipal

sewage system, for cooling towers these savings can be quite considerable (Saunders, 1994).

2.3.5.2 Bleed-Off

Bleed-off is used to prevent damage caused by an increase in the concentration of dissolved solids as a result of evaporation. As only pure water evaporates from the cooling tower, dissolved solids become more concentrated (Black and Veatch, n.d.). Therefore, a portion of the remaining water (bleed-off) must be discharged and replaced with fresh water until the concentration ratio is within acceptable limits (Black and Veatch, n.d.). The frequency with which these bleed-offs occur depend on the quality of water used within the system and the method utilized (e.g. chemical treatment) to control and/or inhibit corrosion, scaling, and biofouling (Black and Veatch, n.d.). Since the rate of evaporative loss cannot be altered, water conservation for cooling towers focuses on reducing the frequency of bleeding.

2.3.5.4 Leakage Within The Distribution System

Leaks in the distribution system can result from leaking pipes, fittings, cooling coils, or pump seals. At HSC, all distributional piping is located inside the hospital complex (tunnels or buildings). As a result, losses associated with leaking pipes and fittings should be identified and repaired quickly. With water consumption monitored on a daily basis, the potential exists to identify cooling coil cracks inside air handling units.

At present, HSC has a combination of packing and mechanical seals in their chilled water pumps. Packing seals, unlike mechanical seals, are not water-tight and require periodic maintenance and/or replacement to minimize water consumption. Packing seals, due to their frictional nature, reduce a pump's horsepower while increasing heat production within the system.

2.3.6 Medical Air & Vacuum Pumps

Many medical air and vacuum pumps use a liquid ring (water) to seal the vacuum chamber as well as to cool the pump (Black and Veatch, 1991a). For vacuum pumps,

water is utilized in one of three ways: as a single-pass; partially recirculated; or, 90% recirculated service liquid. Partial recirculation, distributes approximately 50% of the water from the separator to the pump, whereas, 90% recirculation, distributes 90% of the service liquid through a shell and tube or air cooled heat exchanger (Miller, 1995a). As for medical air compressors, the CSA code stipulates that no recirculation is acceptable (Miller, 1995a).

Recently, CSA approval has been obtained for rotary vane vacuum and oil-less air systems that utilize no water. The new vacuum systems are air-cooled and utilize oil-lubricated rotary vanes on an eccentrically-mounted rotor to draw the necessary vacuum (Thomas Industries Inc., 1993). New medical air compressors use sealed bearings and self-lubricated pistons to deliver the 100% oil-free air required for medical operations (Thomas Industries Inc., 1993).

2.3.7 X-Ray Processors

X-ray film processors use a continuous stream of running water during the processing stage (Black and Veatch, 1991a). A three tank system is used: first, the film enters the developing tank, then the fixing tank, and finally the washing tank (Popoff, 1995a). For effective processing, a flow rate of 2 gpm or less is required (Wilson, 1994).

Modern processors use solenoid control valves to regulate the feed water, so that water is only used when a film is being processed (Wilson, 1994). The water is shut off after approximately 2 to 3 minutes have passed without a film being processed (Black and Veatch, 1991a). Retrofit valve kits are available for some older X-ray processors (Wilson, 1994).

2.3.8 Sterilizers And Autoclaves

There are two types of sterilizers, steam and ethylene oxide, of which both require water. The steam sterilizer uses steam to sterilize the load and water to recondense the steam for discharge and to draw a vacuum during the drying stage (Black and Veatch, 1991b; Wilson, 1994). The ethylene oxide sterilizer, on the other hand, uses

steam to humidify the load and vaporize the EtO gas and water to draw the necessary vacuum to remove the spent ethylene oxide (Wilson, 1994).

As a result of the Canadian government's commitment to ban CFCs (chloroflourocarbon's), 12/88 (12% ethylene oxide and 88% freon) CFCs in hospitals had to be discontinued by December 31, 1995 resulting in the elimination of 12/88 EtO sterilizers. Replacements for the 12/88 sterilizers include: 100% ethylene oxide, 12/88 EO/HCFC using the ozone friendly HCFC, and 10/90 EO/CO₂.

2.4 Conducting A Water Minimization Assessment

Given the concern over increasing water rates, many municipalities, industries and institutions are using water audits, water conservation studies, or water minimization assessments as a cost cutting strategy. The United States Environmental Protection Agency (1990) developed the Waste Minimization Assessment Procedure to provide a systematic framework from which conservation or minimization studies should be based. It was designed for waste water studies, however to avoid confusion, it will be referred to as a Water Minimization Assessment throughout the research report. The Environmental Protection Agency, identified four phases to a Waste Minimization Assessment, they are:

1. Planning and Organization
2. Assessment
3. Feasibility Analysis
4. Implementation

2.4.1 Planning And Organization

The essential elements of this phase are getting management support and setting minimization goals (EPA, 1990). The importance of getting management support cannot be overstated as it directly relates to implementation of feasible options (EPA, 1990).

2.4.2 Assessment Phase

The Assessment Phase consists of a number of steps (EPA, 1990):

- Prioritize and select assessment targets
- Collect and process facility data
- Review data and inspect site
- Generate options
- Select and screen options for feasibility analysis

Conducting a water audit or adopting its methodology (water inventory) during the Assessment Phase is a necessary step toward achieving resource optimization since it takes a comprehensive look at the facility in order to understand resource flows, as well as focusing one's attention to areas where significant reductions or cost savings can be realized (UNEP, 1991).

2.4.2.1 Water Use Inventory

In order to develop a comprehensive inventory of the facilities water uses, a variety of information sources are required, including (UNEP, 1991; Environment Canada, 1993):

- the use of existing data (e.g. space inventories, plumbing plans, etc.)
- meeting with area personnel
- surveying area personnel about water uses within the area
- transferring questionnaire information to spreadsheets and base maps
- verifying information using plumbing plans, visual inspections and building personnel.

All extraction points should be described and located as to the category of water use; volume, rate, and frequency of use; and whether the water is lost or consumed (Environment Canada, 1993).

Once extraction points have been identified, estimates as to their associated flows must be considered. These estimates can be obtained by either published values or actual measurements. Published values are available for most conventional water uses; from which location specific information such as, the number of users per day or duration of use, can be incorporated (Environment Canada, 1993). Should published values be unavailable or not appropriate, actual measurements should be obtained. These measurements should be taken over the same general time period to ensure periodic and seasonal flows do not affect the water balance equation, as well as, if outdoor use is suspected, measurements should be conducted during the summer months (Environment Canada, 1993). Environment Canada (1993) has classified field measurements into four groups, flow metering, bucket and stopwatch measurements, volume/frequency measurements, and indirect measurements.

Metering the main flow of water into the facility is an integral component of any water audit (Environment Canada, 1993). In addition to the main meter, sub-areas throughout the facility can also be monitored by installing a water meter on the water distribution system or water using equipment (Environment Canada, 1993). The choice of water meter depends on the data accuracy requirements. Permanent flow meters provide highly accurate data (daily, weekly, monthly, etc.), however they are expensive and must be permanently fixed into the plumbing run (Environment Canada, 1993). Less accurate data can be provided by using temporary flow meters (clamp-on or inserted).

Bucket and stopwatch measurements can be utilized to estimate flows provided the flow is constant and free flowing (Environment Canada, 1993). Flow is calculated by determining the time required to fill a bucket of a known volume. Should the flow not be continuous but fills a known volume, the frequency by which it is emptied or replaced can be used to estimate its flow (Environment Canada, 1993).

Measurements, such as logging the operation of the water pumps or displacement tests on water storage tanks, provide an indirect indication of flow (Environment Canada,

1993). However, Environment Canada (1993) indicates that this method is the least accurate of the four mentioned, but does provide the user an understanding of water use within the facility.

2.4.3 Feasibility Analysis

For each water use category or unit operation, an option must be both technically and economically feasible. A technical evaluation assesses whether a particular option will work within its proposed application (EPA, 1990).

A cost/benefit analysis (CBA) should be undertaken to determine the capital costs, cost savings and payback period associated with implementing a particular option (Environment Canada, 1993). In addition to the CBA, the option should also be assessed in relation to (Environment Canada, 1993):

- social/political impacts
- environmental/technical impacts
- reliability
- short and long term effectiveness.

The chosen alternative will be consistent with the goals laid out by senior management thereby facilitating its implementation.

2.5 Summary

Winnipeg has adopted water and sewer price rate increases in order to delay future expansion while generating capital reserves in addition to accounting for current borrowing costs for upgrading facilities. These increases create an incentive for large water users, like HSC, to reduce consumption by adopting newer more efficient technologies. However, a proper framework is required in order to evaluate the feasibility of adopting said technologies. As a result, the United States Environmental Protection Agency developed the Waste Minimization Assessment Procedure to outline the steps involved from planning to the successful implementation of waste

minimization projects. Thus, the following chapter details the methodology used to obtain the consumption estimates within this framework, expressed as a percentage of total consumption, for HSCs major water use categories.

Chapter 3 Major Water Use Consumption Estimation

3.1 Introduction

A variety of techniques were used to estimate flow rates and flow duration for each HSCs major water use categories, such as:

- Non-Structured Interviews,
- Metering (permanent and clamp-on),
- Timed Volume Measurements,
- Published Values,
- Current (AC) and Activity Logging,
- Technical Specifications from Existing Equipment.

The per use category estimates were derived by using one or a combination of the above techniques. These estimates, as percentages of overall consumption⁵, were then summed and compared, via a water balance, against the hospital's annual average based on the previous two years consumption (262,041 CCF).

3.2 Use Category Methodology And Water Consumption Estimates

3.2.1 Sterilizers

Sterilizer consumption was estimated using employee knowledge and technical information. Employee knowledge was provided by the Central Processing Department since it is responsible for the majority of the sterilizing at HSC. Susan Hatfield (1995) estimated the number of cycles per week and the duration of each cycle for the steam sterilizers in WT-069 and GG-049, the EtO sterilizer in GG-047, and the washer in GG-639. Consumption estimates for the steam sterilizers were provided by MGT (1994) and Hatfield (1995) provided estimates for the EtO sterilizers and washer.

⁵ Percentages were determined by dividing the estimated per use category consumption by the annual average based on the previous 2 years (262,041 CCF).

There are 22 smaller steam sterilizers located throughout the hospital (General O.R., 10 units; Children's O.R., 3 units; Women's O.R., 3 units; Thorlakson and Cancer buildings, 3 units each). The methodology used to estimate water consumption depended upon if sterilizer print outs (hard copies) were available. Where hard copies were available (General and Children's O.R.'s), print outs were collected for a two week period to determine the number and duration of sterilizing cycles. Due to technical difficulties, the Children's O.R.'s print outs were collected for only one week. For the remaining sterilizers, personal communications were used to estimate the frequency and duration of daily sterilizing cycles (Lorimer (1995) for the Women's O.R. and Maslowski (1995) for the Thorlakson building). No information was available for the Cancer building's sterilizers due to variable cycle frequency and duration. A generalized six US gallons per minute flow rate was used to estimate water consumption (MDT Technology for Life, n.d.) since it was not possible to differentiate cycle frequency and duration on a per sterilizer basis. Consumption estimates for all HSCs sterilizers is provided in table 3.1.

Table 3.1 Water Consumption Associated with Sterilizer Use.

Location	Sterilizer	Cycles/Week	Gallons/Cycle	CCF/Yr
General (GG-049)	Steam	64	598	3194
General (GG-047)	EtO ⁶	6	13600 ⁷	6812
General (GG-639)	Washer	46	11250	801
Women's (WT-069)	Steam	28	598	1398
		Minutes/Wk	US GPM	
General OR (10 units)	Steam	4243	6	1770
Children's OR (3 Units)	Steam	481	6	201
Women's OR (3 Units)	Steam	700	6	292
Cancer Bldg. (3 Units)	Steam	N/A	N/A	N/A
MS Bldg. (3 Units)	Steam	1855	6	774
Total CCF/Year				15,242
Percent of Total Consumption				5.8%

⁶ Two sterilizers operating on alternating cycles.

⁷ 17 hours per cycle*800 gallons per hour.

3.2.2 Dialysis

HSC has two Dialysis units, Central (CDU) and Self-Care (SCD), each using reverse osmosis to produce the high quality water required. However, reverse osmosis is a water intensive process. Currently, for every unit of acceptable water produced, 1.5 units are rejected.

Since water consumption associated with Dialysis is relatively stable, the water meter in the CDU was monitored for a period of two weeks in July to determine the average daily flow. SCD meter readings were taken on a monthly basis by the Central Energy Plant for billing purposes so the two-year annual average was used to estimate water consumption. The SCD meter, however, accounts for all water uses in the building; therefore, to reduce the effects of double counting, domestic consumption was estimated based on the square footage of the building and then subtracted from the averaged total (see Table 3.2).

Table 3.2 Water Consumption Associated with Dialysis.

Self-Care Dialysis Unit		
2 year average (93/94 and 94/95 fiscal years)		4655 CCF/yr.
Domestic Consumption (8876 sq.ft*.04 CCF/sq. ft)		(355) CCF/yr.
	SCD Total	4300 CCF/yr.
Central Dialysis Unit		
2 week average = 4 Imp. GPM		
CDU Total (4 gpm*60 min/hr*24 hr/day*365 days/yr./623 Imp.		3375 CCF/yr.
	Total CCF/yr.	7675
	Percent of Total Consumption	2.9%

3.2.3 Kitchen And Cafeteria

HSC has two kitchens, Rehab and Main, producing approximately 7000 meals per day (Richardson, 1995). Black and Veatch (1991a; 1991b) estimated miscellaneous water use associated with meal production at 0.5 gallons per meal.

Dishwashing results in significant water use in HSCs kitchens and cafeterias. There are 5 dishwashers throughout the complex, three in cafeteria's (Oasis, Cafe on 2, and Tunnel) and one in each of the two kitchens. Kathleen Richardson (1995) provided the time of use estimates, while consumption estimates were taken from the Dishwasher's technical specifications.

Table 3.3 details HSCs water consumption associated with kitchen and cafeteria activities.

Table 3.3 Water Consumption Associated with Kitchen and Cafeteria Use.

Water Use		Times per Day	Duration of Use	Imp. GPD	CCF/Year
Miscellaneous	7000 meals			3500	2051
Dishwashers	Main Kitchen	3	4.5	1734 ⁸	1016
	Cafe on 2	1	10.5	2963 ⁹	1736
	Rehab	2	1.5	733 ¹⁰	430
	Oasis	1	5	1989 ¹¹	1165
	Tunnel	1	5	1989 ¹²	1165
Total CCF/yr.					7563
Percent of Total Consumption					2.9%

3.2.4 Water Softening (Steam Production)

Water softening is required for steam production. HSC has three softeners in the Central Energy Plant and 1 small unit in GG-038. CEP monitors water softening on a daily basis using water meters. As a result, water consumption was estimated using a two-year annual average (4970 CCF/yr or 1.9% of total consumption). No information was collected for the small unit in GG-038.

⁸ Hobart FTM/FT-800 Series Dishwasher: 4.7 gpm plus 155 gallons to fill tank per use (Hobart, n.d.).

⁹ Flight-a-Round FA-EEE Series Dishwasher: 4.6 gpm 65 gallons to fill tank per use (Brodeur, 1995).

¹⁰ Hobart FTM/FT-800 Series Dishwasher: 4.7 gpm plus 155 gallons to fill tank per use (Hobart, n.d.).

¹¹ Hobart C-44 Dishwasher: 2.8 gpm per rack 203 racks/hr (King, 1995) using a 70% efficiency (Brodeur, 1995).

¹² Hobart SM-6 Dishwasher: No information available, therefore used information for Hobart C-44.

3.2.5 Air Compressors

HSC has four water-cooled air compressors that supply the majority of the hospital's compressed air requirements. The compressors are located in the Central Energy Plant and are monitored on a daily basis using water meters. Therefore, consumption was estimated using the two-year annual average (10,893 CCF/yr or 4.2% of total consumption).

3.2.6 Cooling Tower And Chilled Water Makeup

To operate HSCs chilled water loop from mid-April to mid-October, water is required to prime the system, as well as to account for losses associated with evaporation, bleed off, and leakage. The Central Energy Plant monitors water consumption on a daily basis using a number of meters. As a result, water consumption was estimated using the two-year annual average (9768 CCF/yr or 3.7% of total consumption).

3.2.7 X-Ray Processing

HSC has twenty X-Ray processors located throughout the complex. All but two of these processors (AACs M6AN & Rehab's M6AN) have stand-by switches. Since the stand-by switches shut the water off 2-3 minutes after a film has been processed, consumption estimates are complicated due to the fact that consumption depends not only on the number of films processed but also their frequency. As a result, Jacob Popoff (1995a) tried to account for these variables when estimating utilization in hours per day (see table 3.4).

Table 3.4 Water Consumption Associated with X-Ray Processing.

Processors	Department	Hrs./day	GPM	Days/yr.	CCF/yr.
Konica	AAC	2	1	365	70
M7B Mammo	AAC	2	1.5	180	72
Kodak 460 RA	AAC	4	1.5	365	211
M6AN	AAC	24	2.5	365	2109
M6B	AAC	3	1.5	365	158
M6AN Angio	AAC	2	1.5	250	72
M8 #2 Angio	AAC	2	1.5	250	72
M8 #1 Multi-loader	AAC	2	1.5	250	72
M8 #3 Angio	AAC	1	1.5	250	36
Cine Processor	AAC	1.5	2.5	261	94
M7B Operating Rm.	AAC	1	1.5	261	38
M7B Laser CT	AAC	6	1.5	365	316
M6AN	Rehab	8	2.5	250	482
Dental (Phillips)	Dental	1	.5	250	12
M6B	Nuclear Med.	1	1.5	250	36
M7B	Ultrasound	3	1.5	250	108
Konica	Children's	2	1.5	365	70
M7B Laser	Children's	1	1.5	250	36
M6AW (Satellite)	Children's	1	1.5	250	36
Cine (Gaevert R10)	Children's	1 hr/week	2.5	365	13
Total CCF/yr.					4113
Percent of Total Consumption					1.6%

Source: Popoff (1995b)

3.2.8 Medical Vacuum & Medical Air Pumps

HSC has 15 medical vacuum (11 medical and 4 laboratory) and 4 medical air pump units¹³ that use a liquid ring of domestic water to seal the pump's chamber, as well as to dissipate waste heat.

An RCC Silent Partner data logger with a one second sampling rate was used to determine the load associated with 15 units. Measurements were taken over a period of three days on each pump from August to November. The order in which the

¹³ 18 of the units are Duplex (2 pumps) and 1 is a Triplex (three pumps) unit.

measurements were made were completely randomized. Of the four units that were not included; three have run-time meters, whereas the only other one runs about 5 seconds every hour in order to maintain its pressure. For these units (run-time metered pumps), daily readings were recorded over a two week period in July.

Flow rates associated with each unit were supplied by Gord Berg (1995). With the exception of two units, the remaining medical vacuum or medical air compressors have flow restricters which prevent flows from exceeding a specified limit.

Table 3.5 illustrates the water consumption associated with the medical vacuum and medical air pumps.

Table 3.5 Water Consumption Associated with Medical Vacuum and Medical Air Pumps.

Building	Room #	GPM	% On	CCF/yr.
Medical Vacuum Pumps				
General Hospital	GG-048	6	66.7	3376
	GH-014	7	80.2	4736
Cancer	ON-S01	5	26.2	1105
Women's Hospital	WR-126A	15	5.2	658
	WT-656	6	0	0
Respiratory/Rehabilitation	RR-044B	2.5	12.2	257
Thorlakson Medical Support	MS-074	15	2.4	303
PsychHealth	PX-030	2	0	0
Sherbrook Parkade	SP-069	6	2.2	111
Children's Hospital	CS-008	9	44.7	3394
Laboratory Vacuum Pumps				
General Hospital	GG-048	1.5	.8	10
Thorlakson Medical Support	MS-074	15	2.7	341
Cancer	ON-030	2.5	31.2	658
Materials Handling	MH-005	1.5	4.8	60
Medical Air Pumps				
General Hospital	GG-811	5	16.9	713
Women's Hospital	WS-018	4	24.2	817
Children's Hospital	CS-008	9	24.2	1838
Total CCF/yr.				18,380
Percent of Total Consumption				7.0%

3.2.9 Domestic

Domestic consumption for HSC was estimated using a combination of published values and personal communications. The published values pertain to consumption estimates associated with the plumbing fixtures, the frequency and time of use with which people use the fixtures, and the number of visitors associated with inpatients. Table 3.6 incorporates these values to estimate the number of imperial gallons consumed per person per day. The methodology used is similar to that in Black and Veatch (1991a; 1991b). The personal communications related to the number of staff, patients (in and outpatients), students, volunteers, and day-care children. Table 3.7 incorporates these values with the per person consumption estimates from table 3.6 to estimate domestic consumption for HSC.

Table 3.6 Estimated Consumption per Person per Day.

	Daytime	Overnight	Visitors	Source
Toilets				
Imp. Gallons per Flush	4.5	4.5	4.5	Environment Canada, 1993
Flushes per Day	2	4	1	Black & Veatch 1991a&b
Volume/Person/Day	9	18	4.5	
Faucets				
Imp. GPM	2	2	2	Environment Canada, 1993
Minutes/Person/Day	7	8	2	Black & Veatch, 1991a&b
Volume/Person/Day	14	16	4	
Showers				
Gallons per Shower ¹⁴		22		Environment Canada, 1993
Total GPD/Person	23	56	8.5	

¹⁴ Based on a 5 minute shower.

Table 3.7 Water Consumption Associated with Domestic Water Production.

	Daily	Overnight	Visitors	Source
Staff	5000			Koslowsky, 1995
Students	238			Kirk, 1995; Loveridge, 1995; Nicol, 1995; Yachemitz, 1995
Volunteers	165			Anderson, 1995; Good, 1995; Hickerson, 1995
Day-care	32			Braun, 1995
Lennox Bell Lodge		54		Squires, 1995
Outpatients			360	Stack, 1995
Inpatients		855		Koslowsky, 1995
Visitors			1710 ¹⁵	Black and Veatch, 1991a&b
Total Persons/Day	5435	909	2070	
Total GPD/Person	23	56	8.5	
Days	251	365	251	
Sub total: CCF/yr.	50,363	29,823	7089	
Total CCF/yr.				87,275
Percent of Total Consumption				33.3%

3.2.10 Hot Water

Hot water is produced in many locations throughout HSC, however, none of these locations are exclusively metered. As a result, the only way to estimate hot water production was via the Maintenance building's water meter. This meter accounts for HSCs central hot water supplied to the following buildings: GA-GH, AD, MA, LB, WR/WS/WT, LA2&3. Central hot water was then estimated by subtracting the two-year annual average (Maintenance Building) from all the known water uses within the Maintenance Building (Domestic and Condenser¹⁶).

Domestic consumption was not estimated using the same methodology as described in section 3.2.9, since it was not possible to determine the number of people working in

¹⁵ 2 Visitors per Patient (Black and Veatch, 1991a; 1991b).

¹⁶ Methodology described in section 3.2.11.

the Maintenance building on a daily basis. Domestic consumption was estimated based on the square footage of the building. Consumption per square foot was estimated by dividing the annual domestic value from table 3.7 (87,275 CCF) into the total square footage associated with all the buildings (1,999,965) except for the Central Energy Plant. The CEP was not included in the total due to its large square footage and limited number of people. As a result, per square foot domestic consumption was estimated to be 0.043 CCF/sq. ft.. Using 0.043 CCF/sq. ft. to estimate domestic consumption for the Maintenance building, table 3.8 estimates the amount of hot water consumed per square foot based upon central hot water production in the Maintenance building. The Maintenance building was chosen since it produces a significant proportion of HSCs hot water and other water uses within the building are limited.

Table 3.8 Hot Water Consumption per Square Foot.

Domestic	Square Footage	CCF/Sq. ft.	Total (CCF/yr.)
	37,431	.043	(1610)
Condenser	CCF/period		
	Summer Consumption	Winter	
Plumbing Shop	340	197	
CCMS	0	236	
			(773)
Annual Average	CCF/period		
	Fiscal Year 93/94	Fiscal Year 94/95	
	14,025	14,295	
			14160
Total Hot Water (CCF/Yr.) Produced in MA Bldg			11,777
Square Footage Served by Hot Water			737,915
Hot Water (CCF)/Sq.Ft.			0.016

Using the 0.016 CCF/sq. ft. value, table 3.9 estimates consumption for the remaining buildings.

Table 3.9 Water Consumption Associated with Hot Water Production.

Building	Square Footage	CCF/Year
PsychHealth	179,073	2865
Thorlakson Medical Support	259,695	4155
Children's	235,231	3764
Cancer	99,941	1599
School of Nursing	89,324	1429
Respiratory/Rehabilitation Hospital	200,825	3213
Materials Handling	56,367	902
Community Services	59,150	946
Financial Services	15,186	243
Self-Care Dialysis	8876	142
Maintenance Service	737,915	11807
Total CCF/yr.		31,065
Percent of Total Consumption		11.9%

As domestic consumption is already accounted for, extreme caution should be exercised when interpreting hot water consumption as double-counting is likely.

3.2.11 Water-Cooled Condensers

HSC has approximately 95 water-cooled condensers located throughout the complex. They are used to provide local space or process cooling. All but 16 of these units use water in a single pass capacity, the remaining 16 can be converted to use the existing multi-pass chilled water loop (spooled¹⁷) during summer operations.

A preliminary list of condensers was identified by Navarro (1994), but it had a limited scope. Therefore, visual inspections of all mechanical rooms, as well as a literature search of project information by Rick Van Dulman (1995), identified the remaining condensers.

¹⁷ Spool refers to a removable section of chilled water supply and return piping that is removed from the domestic water supply in summer, so that the condenser can run on the existing chilled water loop.

Since existing HSC horsepower data was insufficient, SMS consultants (1996) calculated the theoretical horsepower associated with each condenser¹⁸ using formula 3.1.

$$\text{For 3ph motor HP} = 1.73 * V * I_a * 0.9(\text{motor factor}) * 0.8(\text{power factor}) * 0.00134(\text{conversion factor}) \quad (3.1)$$

In order to calculate the theoretical flows, the temperature differential between the inlet and outlet water temperature was required for all condensers. Inlet and outlet temperatures were recorded in July using a Thermocouple Type J digital thermometer, where measurements were obtainable. This method provided the summer differentials. For winter differentials, the same outlet temperature was used¹⁹, but an inlet temperature of 45°F was observed in December. Where temperature differentials could not be obtained a 20°F delta was used in the summer and a 45°F delta in winter.

Theoretical flow rates were calculated using formula 3.2.

$$\text{US GPM per horsepower}^{20} = 14,544 / (500 * (\Delta^{\circ}\text{F})) \quad (3.2)$$

When verifying the accuracy of these calculations, there was a discrepancy between the theoretical and actual flow rates. Bucket and stopwatch measurements in July, indicated that actual flow rates were in fact much smaller than the calculated flow rates. To provide additional data to this fact, an ultrasonic clamp-on flow meter was used in November. Due to time limitations, the flow meter only took measurements over a one

¹⁸ SMS (1996) calculated the theoretical horsepower for the following condensers: GC-107, GC-010C, GD-043 (F-37 & F-38), GG-347B, GG-346, GH-195A, GH-014, NA-029A, TW37B, TW37D, RR-044B, RR-029A, WT-563, WS-202A, WS-002, BA-001, ON-302, ON-245, ON-231, ON-040, CS-231, CS-111, CS-105, CS-006, MS BLDG, and FE-018. Horsepower's and flow rates for all the compressors are identified in Appendix C.

¹⁹ All condensers have thermo-regulating valves that control the outlet temperature.

²⁰ Perry (1976).

day interval. As a result of these measurements, actual flow rates were on average 50% smaller than theoretical flow rate (see Appendix C).

To determine the run times associated with the condensers, an ACR current logger using an eight second sampling rate was attached to the load side of the condenser motor for a period of three days. The ACR recorded the amperage drawn by the condenser's motor. Amperage was used as a proxy for run time, since amperes are only drawn when the condenser is running. Condensers were chosen using a two stage process since the installation of the device required the services of the Electrical shop. First, all inconveniently located condensers were removed from the sample list; from which, twenty-five condensers were randomly selected. Time limitations resulted in the sample size being reduced from twenty-five to fifteen. Monitoring occurred from late July to the end of November incorporating both summer and winter loads. These measurement identified an average run time for HSCs water-cooled condensers at 59% (see Appendix D).

Consumption per condenser was calculated using formula 3.3 for winter and formula 3.4 for summer consumption resulting in an overall consumption estimate of 77,064 CCF/yr or 29.4% of total consumption (see Appendix E).

$$\text{Winter Consumption} = \text{formula (3.2)} * \text{horsepower} * 60 \text{ minutes/hour} * 24 \text{ hrs/day} * 200 \text{ days} * .59 \text{ (average load)} * .50 \text{ (average theoretical adjustment)} \quad (3.3)$$

$$\text{Summer Consumption} = \text{formula (3.2)} * \text{horsepower} * 60 \text{ minutes/hour} * 24 \text{ hrs/day} * 165 \text{ days} * .59 \text{ (average load)} * .50 \text{ (average theoretical adjustment)} \quad (3.4)$$

3.3 Summary

Sections 3.2.1 to 3.2.11 detailed the methodology used to establish estimates of per category water use. Table 3.10 is a water balance comparing the per category consumption estimates against HSCs annual consumption.

Table 3.10 only compares estimated consumption versus actual consumption for the entire hospital. A number of water meters located throughout the complex. That afforded an opportunity to assess the accuracy or acceptability of the entire methodology for estimating consumption. In Appendix F, per category estimates were compared to the two-year annual averages associated with the various water meters or sub-meters at HSC (see Appendix F), indicating that the overall methodology is more likely to be accurate as the number of buildings a water meter services increases. As a result, a sensitivity analysis should be conducted when determining the economic feasibility of a particular minimization option in order to account for the increased variability.

Table 3.10 Health Sciences Centre Major Water Use Consumption Estimates.

Water Use Category	CCF/Yr.	Percent
Sterilizers	15,242	5.8
Dialysis	7675	2.9
Kitchen and Cafeteria	7563	2.9
Water Softening (Steam Production)	4970	1.9
Air Compressors	10,893	4.2
Cooling Tower and Chilled Water Makeup	9768	3.7
X-Ray Processing	4115	1.6
Medical Vacuum & Medical Air Pumps	18,380	7.0
Domestic	87,275	33.3
Hot Water ²¹	31,065	11.9
Water-Cooled Condensers	77,064	29.4
Total	274,010	104.6%

Given these figures, cost savings (benefits) are now identifiable permitting the use of a cost-benefit analysis framework to evaluate potential water conservation measures.

²¹ Figure undoubtedly includes double-counting.

Chapter 4 Feasibility Analysis

4.1 Introduction

For the majority of water uses identified in Chapter 3, options exist to reduce consumption, though not all are feasible at this time. Chapter 4 will identify and economically evaluate water saving measures for each water use category based on capital and operating costs, cost savings, and payback periods. Feasible options will be prioritized based on a sensitivity analysis of their net present value after five years.

4.2 Sterilizers

Changes in Manitoba's *Ozone Depleting Substances Act* resulted in HSC replacing the existing "12/88" (12% CFC-12 and 88% Ethylene Oxide gas) sterilizers with new disposable cartridge based systems using 100% Ethylene Oxide. Unlike the old system, no domestic water is required during sterilization. To meet demand, an additional steam sterilizer (135 gallon per cycle water saving model) was required.

In January 1995, water saving retrofit kits were installed on the existing steam sterilizers, in WT-069 and GG-049, converting them from 600 to 135 gallons per cycle units (Koslowsky, 1995). The result of these changes is an overall reduction in consumption of 8825 CCF/yr or 3.4%.

4.3 Dialysis

Reverse osmosis is a water intensive process and little opportunity exists to reduce consumption. Flow meters are monitored daily. However, they focus on quality (electrolyte analysis and conductivity measurements), not quantity, since the amount of water consumed by reverse osmosis is relatively fixed (Lepp, 1995).

4.4 Kitchen And Cafeteria

Dishwashing is the most significant water use in HSCs kitchens and cafeterias. Of the five dishwashers, two are relatively water-efficient (Rehab and Main kitchens), two have water efficient replacements identified (Cafe on 2 and Tunnel cafeterias), and one will

be eliminated (Children's cafeteria). Eliminating the Oasis cafeteria dishwasher will reduce over consumption by 1165 CCF/yr or 0.4% as this cafeteria is going to disposable products. Recently, capital funding to replace the Cafe on 2 and Tunnel Cafeteria's dishwashers was rejected (Walker, 1996) as replacing dishwashers is not justified based on energy and water savings alone (see Section 4.13).

4.5 Water Softening (Steam Production)

The CEP monitors water consumption associated with water softening on a daily basis using a series of water meters. Water savings can be realized by reducing the amount of makeup water required by reducing the amount of steam required, changing operating procedures that reduce the number of regeneration's required, and/or increasing the amount of condensate (condensed steam) returned to the CEP.

Recently, boiler makeup water has decreased due to an increase in the amount of condensate returned (Lehmann, 1995). Also, Lehmann (1995) states that a change in operating procedures has reduced the number of regeneration's required. However, the savings associated with these changes have yet to be determined.

4.6 Air Compressors

In the past, approximately 65% (Lehmann, 1995) of air compressor cooling water was reused, via the "swimming pool"²², for cooling tower and chilled water makeup during summer operations (6 months). Recently, a recirculating cooling loop was installed eliminating water consumption. Such a change will reduce total consumption by 6529 CCF/yr or 2.5% of total consumption.

4.7 Cooling Tower And Chilled Water Makeup

Makeup water is required to account for losses associated with evaporation, bleed-off, and leakage. The quantity of makeup water required depends on the rates at which losses occur. Of the three, savings can only be achieved from reducing the amount of bleed-off and leakage.

²² A storage tank with overflow drainage located in the sub-basement of the Central Energy Plant.

The Central Energy Plant uses conventional chemical treatment and sulfuric acid to reduce impurities within the chilled water loop. As a result, HSC is operating at a concentration ratio of 5 (Lehmann, 1995). Black & Veatch (n.d.) estimate that acid treatment in conjunction with conventional chemistry can achieve concentration ratios up to 6 cycles. In which case, savings associated with bleed-off are limited.

However, savings associated with system losses do exist. During the summer of 1995, average daily makeup required to operate HSCs chilled water loop was 2010 imperial gallons. These losses are a result of 31 chilled water pumps using packing seals. These seals are not water-tight and require periodic maintenance and/or replacement to minimize losses. Due to chemical treatment, these losses are significant as the cost per 1000 imperial gallons of makeup water is \$66.38. Currently, a program is in place to replace these seals with water-tight mechanical seals resulting in savings of approximately 0.2% or 530 CCF/yr²³.

4.8 X-Ray Processing

Eighteen out of twenty of HSCs x-ray processors have stand-by switches to shut the water off approximately 2-3 minutes after a film has been processed. The two units that do not have stand-by switches (M6AN in GG-187 and Rehab) consume water whenever the machine is on, whether or not a film is being processed. Current restructuring and renovation plans will see these units replaced with new water efficient processors (Popoff, 1995a). The amount of water saved will depend on the number of hard copies processed and the exact nature of the restructuring.

4.9 Medical Vacuum & Medical Air Pumps

All of HSCs medical vacuum and medical air pumps use a liquid ring to seal the pump chamber, as well as to dissipate waste heat. Ninety percent water-saving retrofit kits are available, for medical vacuum pumps. The CSA code prevents their use with medical air compressors (Miller, 1995a). Potentially three vacuum units; CS-008, GG-

²³ Based on 165 days of chilled water service (Lehmann, 1995).

048, and GH-014; can be retrofitted with 90% water saving retrofit kits. Retrofitting CS-008 and GG-048 would reduce consumption by 2.2% or 5819 CCF/yr. Currently, a study is underway to determine whether the vacuum unit in CS-008 can assume GH-014's load, as this unit is very old and inefficient. If the option of converting GH-014's load proves feasible, an additional 4736 CCF/yr or 1.8% (slightly less than this due to the increased load on CS-008) can be realized. If not, then a 90% retrofit kit is available and would only save 1.6% not 1.8% of total consumption.

4.10 Domestic

Domestic consumption represents the single largest water use at HSC (33.3%), however, the extent of the savings are limited by the existing plumbing infrastructure, plumbing code requirements, and health concerns.

Tankless toilets with flushometers flush valves are almost exclusively used throughout HSC. These flush valves can be adjusted to consume less water, however, present bowl geometry limits the amount of savings available (Berg, 1995). Also, there are health concerns, bacteria and infections, associated with inadequate flushing.

Another option is to change to new ultra-low volume (ULV) toilet bowls. This option is expensive because, in addition to the bowl costs, ULV bowls require different piping runs and fittings. The option to convert to ULVs is limited to new developments and renovation zones.

In order to prevent air borne bacteria from entering the water supply, the Plumbing Code does not permit aerated flow restricting devices in hospitals. As a result, laminar flow devices, using a series of screens, have been developed to reduce consumption. These devices are much more expensive than aerated models (approximately \$6 per compared to \$2) and have higher flow rates of 2.0 US gpm (33% savings) compared to 0.5 US gpm (83% savings) for aerated models.

4.11 Hot Water

Savings associated with hot water are linked to savings elsewhere. Savings may be realized by technical improvements (e.g. flow restricting devices), improving general operating procedures (e.g. full loads in dish and clotheswashers), and/or employee education (e.g. eliminating unnecessary flows -- only running water when required). Due to the linkages elsewhere, cost savings associated with these measures are difficult to quantify, and in the case of improving general operating procedures and employee education difficult to verify.

4.12 Water-Cooled Condensers

Water-cooled condensers represent the second largest water use (29.9%) at HSC. This use has increased over the years to meet localized space cooling or refrigeration needs. The problem with these units is that water is only used in a single-pass capacity to dissipate waste heat. One option is to convert these units from water to air-cooled. However, due to the large number of units (~92) and finite space (roof tops) to locate the air conditioning units, this option is only preferred for a limited number of condensers, which will be identified later. As a result, the Health Sciences Centre commissioned a preliminary engineering study (HSC Project No. 95-20-SP) to evaluate the possibility of operating the existing chilled water loop year round. The study was based on the premise that "winter chilled water would be provided by a process fluid cooler and a plate heat exchanger located in the Central Energy Plant" (SMS, 1996, p.1). SMS (1996) identified the cost of the fluid cooler and associated distributional hardware, piping requirements, and operating expenses; as well as identifying condensers that were not included in the study. By operating the chilled water loop year-round, HSC can reduce its present water consumption by approximately 25.5% or 66,711 CCF/yr. Additional savings of 1.9% or 4938 CCF/yr can be realized by converting three existing water-cooled condensers, excluded²⁴ from the year round study (BA-001, GF-632, and GC-420), to air-cooled units.

²⁴ Excluded condensers include: FE-018, BA-001, GC-420, GD-725, GE-708, GF-632 (SMS, 1996).

4.13 Economic Evaluation and Prioritization of Water Saving Measures

Sections 4.2 to 4.12 identified a number of water saving measures available to HSC. However, two questions still needed answering: i) Are these measures feasible? And if so, ii) What is its relative priority in relation to other measures? Table 4.1 answers the first question by evaluating each option based on their capital and operating costs, cost savings, and payback period²⁵. Using a payback period of 5 years or less to determine the feasibility of a conservation option, it was not feasible to replace dishwashers based on energy and water savings alone.

Table 4.2 answers the second question by conducting a negative bias sensitivity analysis. Measures that could effect feasibility and/or priority, such as capital cost increases, consumption overestimation, and differences in water rate increases, were selected to identify the range of probable outcomes (high and low sensitivity estimates).

Since the Health Sciences Centre is a public institution, the criteria for choosing among competing investment opportunities (Projects) should be the project that has the highest net present value as it contributes the most to the welfare of society (Treasury Board, 1976). Such an approach to decision-making complements the Provincial government's position on Sustainable Development: "employees and organizations at all levels must identify what they do that has an impact on the environment and economy and they must isolate and correct the causes of and activities which are unsustainable" (Manitoba Round Table on Environment & Economy, 1992, p.iii). The average five year net present value, in Table 4.2, was used to prioritize the various water saving measures. This value was used as it indicates the foregone benefits or opportunities of the various projects over a short-term planning horizon. Also, included in table 4.2 is the net present value over 20 years reflecting the foregone opportunity or benefits over the life of the equipment.

²⁵ Payback periods were calculated using the following formula: Capital Cost/(CCF Saved/yr*Cost/CCF - Operating Costs). The Cost/CCF used was \$3.74 (combined water and sewer rate for 1996). The proposed ten to twelve percent per year increase in the water and sewer rate were not included in the calculations. Thus, the payback periods did not change when the water and sewer rates changed in Table 4.2.

Table 4.1 Economic Evaluation of Water Conservation Options

Use Category	Type of Saving	Cost Data Source	Capital Cost ¹	Operating Cost	Cost Savings	Payback Period ²	CCF/YR Saved	Status
Sterilizers	Retrofit sterilizers (WT-069 & GG-049) ³	Koslowsky, 1994	\$ 22,504	\$ 1,000	\$ 8,950	2.5 years	3,555	Completed
	Replace EtO sterilizers	Statutory Requirement					6,812	Completed
	Install New Steam sterilizer	To Meet Demand due to Statutory Requirement					(1,542)	Completed
Kitchen/Cafeteria	Replace Tunnel Dishwasher	Walker, 1996	\$ 22,640	Undetermined	\$ 3,422	>6 years	-	Not Feasible
	Replace Cafe on 2 Dishwasher	Walker, 1996	\$ 65,000	Undetermined	\$ 2,500	>10 years	-	Not Feasible
	Eliminate Oasis Cafeteria Dishwasher						1,165	
Air Compressor	Install Recirculating Cooling Loop	Lehmann, 1996	\$ 31,155	\$ 12,000	\$ 24,418	2.5 years	6,529	Completed
Chilled Water	Replace Packing Seals with Mechanical Seals ⁴	Cruickshank, 1996	\$44,082	N/A	\$ 21,916	2.0 years	530	On-Going
X-Ray Processing	Department Restructuring	Unknown, Not Based on Energy or Water Savings					N/A	On-Going
Medical Vacuum	Retrofit Vacuum Pump in CS-008	Miller, 1995	\$ 17,100	\$ 800	\$ 11,284	1.6 years	3,017	See Table 4.2
	Retrofit Vacuum Pump in GG-048	Miller, 1995	\$ 11,400	\$ 800	\$ 10,479	1.2 years	2,802	See Table 4.2
	Put GH-014 Vacuum Pump's Load on CS-008	Currently Under Review					4,736	
Domestic	Install Faucet Moderators	Requires Further Study, See Section 5.2						
	Adjust Flush Valves	Requires Further Study, See Section 5.2						
Condensers	Install Year Round Cooling Loop	SMS, 1996	\$ 784,206	\$ 18,200	\$ 249,499	3.4 years	66,711	See Table 4.2
	Convert BA-001 Condenser to Air Cooled	Bettencourt, 1996	\$ 12,612	Unchanged	\$ 4,155	3.0 years	1,111	See Table 4.2
	Convert GF-632 Condenser to Air Cooled	Bettencourt, 1996	\$ 16,577	Unchanged	\$ 9,376	1.8 years	2,507	See Table 4.2
	Convert GC-420 Condenser to Air Cooled	Bettencourt, 1996	\$ 16,480	Unchanged	\$ 4,937	3.3 years	1,320	See Table 4.2

¹Including installation costs and appropriate taxes.

²Based on 1996 water rate at \$3.74/CCF. Payback Period = Capital Costs/(CCF/yr saved*\$3.74/CCF-Operating Costs).

³Based on 1994 costing data (\$2.80/CCF), not adjusted for inflation.

⁴Cost savings based on \$41.35/CCF.

Table 4.2 Sensitivity Analysis and Prioritization of Water Conservation Options

Table 4.2 Sensitivity Analysis and Prioritization of Water Conservation Options														
Use Category	Type of Saving	Discount Rate ¹ = 4.775%	Capital Costs		Consumption			Water & Sewer Rate			Summary Statistics			Priority ²
			+25%	+50%	-10%	-25%	-50%	0%/yr	+5.3%/yr	+10.6%/yr	Mean	Sensitivity		
										Present Condition				
												High	Low	
Medical Vacuum	Retrofit Vacuum Pump in CS-008	Net Present Value (5 years)	\$ 33,706	\$ 29,626	\$ 32,043	\$ 23,428	\$ 9,070	\$ 27,270	\$ 32,263	\$ 37,787	\$ 28,149	\$ 9,070	\$ 37,787	4
		Net Present Value (20 years)	\$ 330,578	\$ 326,498	\$ 97,157	\$ 244,489	\$ 154,319	\$ 110,787	\$ 189,637	\$ 334,658	\$ 223,515	\$ 97,157	\$ 334,658	
		Simple Payback Period ³	2.0	2.4	1.8	2.2	3.5	1.6	1.6	1.6	2.1	3.5	1.6	
	Retrofit Vacuum Pump in GG-048	Net Present Value (5 years)	\$ 36,414	\$ 33,694	\$ 33,785	\$ 33,785	\$ 12,464	\$ 29,367	\$ 34,004	\$ 39,134	\$ 31,581	\$ 12,464	\$ 39,134	3
Net Present Value (20 years)		\$ 311,675	\$ 308,955	\$ 280,802	\$ 280,802	\$ 146,908	\$ 106,478	\$ 179,709	\$ 314,385	\$ 241,216	\$ 106,478	\$ 314,385		
Simple Payback Period		1.5	1.8	1.3	1.6	2.6	1.2	1.2	1.2	1.5	2.6	1.2		
Condensers	Install Year Round Cooling Loop	Net Present Value (5 years)	\$ 258,699	\$ 71,582	\$ 318,819	\$ 128,326	-	\$ 213,274	\$ 323,684	\$ 445,815	\$ 251,457	\$ 71,582	\$ 445,815	1
		Net Present Value (20 years)	\$ 6,818,966	\$ 6,831,849	\$ 6,208,561	\$ 5,012,279	-	\$ 2,055,917	\$ 3,799,411	\$ 7,006,082	\$ 5,361,866	\$ 2,055,917	\$ 7,006,082	
		Simple Payback Period	3.7	4.5	3.8	4.6	-	3.4	3.4	3.4	3.8	4.6	3.4	
	Convert BA-001 Condenser to Air Cooled	Net Present Value (5 years)	\$ 6,103	\$ 3,094	\$ 6,998	\$ 3,825	\$ (1,462)	\$ 5,240	\$ 7,079	\$ 9,113	\$ 4,999	\$ (1,462)	\$ 9,113	5
Net Present Value (20 years)		\$ 133,879	\$ 133,879	\$ 120,491	\$ 100,409	\$ 66,939	\$ 51,439	\$ 80,475	\$ 133,879	\$ 102,674	\$ 51,439	\$ 133,879		
Simple Payback Period		3.8	4.6	3.4	4.0	6.1	3.0	3.0	3.0	3.9	6.1	3.0		
	Convert GF-632 Condenser to Air Cooled	Net Present Value (5 years)	\$ 67,502	\$ 71,457	\$ 27,131	\$ 19,972	\$ 8,041	\$ 23,165	\$ 27,314	\$ 31,903	\$ 34,561	\$ 8,041	\$ 71,457	2
Net Present Value (20 years)		\$ 319,486	\$ 323,441	\$ 253,916	\$ 208,960	\$ 134,033	\$ 97,860	\$ 163,380	\$ 263,887	\$ 223,120	\$ 97,860	\$ 323,441		
Simple Payback Period		2.2	2.7	2.0	2.4	3.5	1.8	1.8	1.8	2.3	3.5	1.8		
	Convert GC-420 Condenser to Air Cooled	Net Present Value (5 years)	\$ 5,467	\$ 1,535	\$ 6,887	\$ 3,117	\$ (3,165)	\$ 4,798	\$ 6,983	\$ 9,400	\$ 4,378	\$ (3,165)	\$ 9,400	6
Net Present Value (20 years)		\$ 138,143	\$ 134,211	\$ 126,295	\$ 102,624	\$ 63,173	\$ 44,127	\$ 78,625	\$ 142,075	\$ 103,659	\$ 44,127	\$ 142,075		
Simple Payback Period		4.2	5.0	3.7	4.5	6.7	3.3	3.3	3.3	4.3	6.7	3.3		

¹Discount rate = 6.875% (5 year GIC return as of 5/6/1996) - 2.1% (Inflation rate 1995).

²Based on Net Present Value over 5 years.

³Simple Payback Period does not account for increases in the water & sewer rate. Payback Period = Capital Costs/(CCF/yr. saved*\$3.74/CCF-Operating Costs).

With the exception of the GF-632 condenser, there is a clear hierarchy with respect to 'like' options. HSC should pursue year round cooling first, as it clearly has the largest net present value; followed by vacuum pump retrofits; and finally, converting individual water-cooled condensers to air-cooled. This hierarchy should be followed instead of the priority ratings in table 4.2 for two reasons: i) the average net present values for GF-632 and vacuum pumps are quite close, and ii) potential cost savings may be realized by grouping 'like' projects (e.g. travel and per diem expenses for vacuum pumps and crane rental for air-cooled condensers).

4.14 Summary

Chapter 4 identified a number of water saving initiatives available to HSC. Some have recently been completed or are currently on-going, whereas others have potential for future installation. At present, the only potential option that was not feasible, based on a payback period of five years or less, was installing new dishwashers based on their energy and water savings alone. The remaining options were feasible and were prioritized according to their net present value over five years, resulting in the following implementation hierarchy:

1. Provide Year Round Chilled Water
2. Retrofit CS-008 and GG-048 Vacuum Pumps with 90% Recirculation Retrofit Kits
3. Convert BA-001, GF-632, and GC-420 Water-Cooled Condensers to Air-Cooled.

These changes, in conjunction with recently completed and on-going projects or programs over the past year, will result in an overall reduction of 99,253 CCF/yr or 37.9% resulting in annual savings of approximately \$390,000 (based on 1996 costs).

Chapter 5 Conclusion and Recommendations

5.1 Conclusion

HSC has seen water-related expenditures increase by 10.6% per year over the past four years due to water and sewer rate increases. These increases have created an incentive to reduce consumption. As a result, research was undertaken to identify and evaluate potential water saving measures available to HSC, as well as other large scale tertiary care hospitals, in order to reduce present and future water-related expenditures.

This was accomplished by systematically identifying consumption estimates for HSCs major water uses (see figure 5.1). From which, potential water minimization options were identified and economically evaluated according to capital and operating costs, cost savings, simple payback period, and five year net present value. The five year net present value was then used to prioritize the potential minimization options which have not been completed or are currently on-going. The result is HSC can reduce present consumption by approximately 99,250 CCF/yr. or 37.9% and realize savings close to \$387,000/yr (see table 5.1).

5.2 Recommendations

Currently, a portion of these savings are being realized as some projects have been completed or are currently on-going (see table 5.1). However, they only account for 17,049 CCF/yr or 17.2% of identified savings while the remaining savings are contingent upon future installations, retrofits, or replacements. Thus, the following recommendations:

1. HSC should adopt the following water minimization implementation hierarchy:
 - i. Provide Year Round Chilled Water (NPV = \$251,457),
 - ii. Retrofit CS-008 (NPV = \$28,149) and GG-048 (NPV = \$31,581) Vacuum Pumps with 90% Recirculation Retrofit Kits, and

Figure 5.1 HSCs Major Water Use Consumption Estimates




Table 5.1 Summary of Water Conservation Options Available to HSC

Use Category	Type of Saving	Capital Cost ¹	Operating Cost	Cost Savings	CCF/YR Saved	Percent	Payback Period ²	Net Present Value (5 yr) ³	Implementation Status
Sterilizers	Retrofit sterilizers (WT-069 & GG-049) ⁴	\$ 22,504	\$ 1,000	\$ 8,950	3,555	1.4%			Completed
	Replace EtO sterilizers		Statutory Requirement	\$ 25,477	6,812	2.6%			Completed
	Install New Steam sterilizer		Required to meet Demand	\$ (5,767)	(1,542)	-0.6%			Completed
Kitchen/Cafeteria	Eliminate Oasis Cafeteria Dishwasher			\$ 4,357	1,165	0.4%			On-Going
Air Compressor	Install Recirculating Cooling Loop	\$ 31,155	\$ 12,000	\$ 24,418	6,529	2.5%			Completed
Chilled Water	Replace Packing Seals with Mechanical Seals ⁵			\$ 21,916	530	0.2%			On-Going
X-Ray Processing	Department Restructuring	Not based on Energy or Water savings			N/A				On-Going
Medical Vacuum	Retrofit Vacuum Pump in CS-008	\$ 17,100	\$ 800	\$ 11,284	3,017	1.2%	1.7 - 2.6 years	\$22,557 - \$33,742	Second Priority
	Retrofit Vacuum Pump in GG-048	\$ 11,400	\$ 800	\$ 10,479	2,802	1.1%	1.2 - 1.9 years	\$26,385 - \$36,777	Second Priority
	Put GH-014 Vacuum Pump's Load on CS-008	Currently Under Review			\$ 17,713	4,736	1.8%	N/A	N/A
Domestic		Requires Further Study, See Section 5.2							
Condensers	Install Year Round Cooling Loop	\$ 784,206	\$ 18,200	\$ 249,499	66,711	25.5%	3.4 - 4.2 years	\$174,181 - \$328,733	First Priority
	Convert BA-001 Condenser to Air Cooled	\$ 12,612	Unchanged	\$ 4,155	1,111	0.4%	3.1 - 4.6 years	\$2921 - \$7077	Third Priority
	Convert GF-632 Condenser to Air Cooled	\$ 16,577	Unchanged	\$ 9,376	2,507	1.0%	1.8 - 2.7 years	\$19,428 - \$49,694	Third Priority
	Convert GC-420 Condenser to Air Cooled	\$ 16,480	Unchanged	\$ 4,937	1,320	0.5%	3.5 - 5.1 years	\$1866 - \$6890	Third Priority
Total				\$ 386,794	99,253	37.9%			

¹Including installation costs and appropriate taxes.

²Based on 1996 water rate at \$3.74/CCF.

³From Table 4.2

⁴Based on 1994 costing data (\$2.80/CCF), not adjusted for inflation.

⁵Cost savings based on \$41.35/CCF.

- iii. Convert BA-001 (NPV = \$4999), GF-632 (NPV = \$34,561), and GC-420 (NPV = \$4378) Water-Cooled Condensers to Air-Cooled.

This implementation hierarchy does not follow the priority scheme in table 4.2 for two reasons. First, the net present values for the GF-632 water-cooled condenser and vacuum pumps in CS-008, and GG-048 are quite close. Secondly, by grouping minimization options into similar classes, potential cost savings may be realized with respect to crane rental (water-cooled condensers) and per diem and travel expenses (medical vacuum pumps).

By following the implementation hierarchy, HSC will maximize its return on investment while eliminating unsustainable water use at the hospital.

2. HSC proceed with the installation of the winter chilled water supply as described by SMS (1996) so as to provide year round chilled water.

With year round chilled water available, almost all of the water-cooled condensing units can be converted from a single-pass domestic water supply to the existing recirculating chilled water loop. The project costs approximately \$800,000 with annual cost savings, net of operating costs, of approximately \$230,000, translating into a payback period between 3.4 to 4.6 years. It is the most significant of all the water minimization options, identified in table 5.1, as it represents 67% of the identified potential savings (25.5% overall reduction) and has the largest net present value over twenty years (\$174,181 - \$328,733).

3. HSC proceed with the technical assessment required to operate the medical vacuum pumps in CS-008 and GG-048 at 90% recirculation.

Retrofitting these units is second on the implementation hierarchy. Potential cost savings (travel and per diem expenses) can be realized by combining the installation of

the two units since a technical assessment by the vacuum pump's manufacturer is required.

These kits are available in either air or water-cooled models. Since the mechanical rooms, in question, are not vented and are warm to begin with, the water-cooled option was chosen for costing purposes. However, it requires year round chilled water. For CS-008, the retrofit costs approximately \$17,000 producing annual cost savings, net of operating costs, of \$10,000 and translating into a payback period of 1.6 to 3.5 years. While GG-048 will cost \$11,400 with annual savings, net of operating costs, of approximately \$9500 or a payback period of 1.2 to 2.6 years.

Currently, a study is underway to determine whether the GH-014 vacuum pump's load can be assumed by the CS-008 vacuum pump unit (Berg, 1996). If so, converting GH-014s load to the CS-008 will positively affect the annual cost savings and payback period associated with the CS-008 vacuum pump unit.

Retrofitting CS-008 and GG-048 will reduce overall consumption by 5819 CCF/yr or 3.3%.

4. HSC convert three of the water-cooled condenser units not feasible in the SMS (1996) proposal (BA-001, GC-420, and GF-632) to air-cooled units.

Seven water-cooled condensers were not feasible in the SMS (1996) proposal. Three of the units (BA-001, GC-420, and GF-632) can be converted from the existing single pass water supply to air-cooled eliminating water use. Converting these units is last on the implementation priority list (recommendation 1) as the net present values are low compared to the other options (see table 5.1). The exception is the GF-632 condenser. This condenser, ranked second in table 4.2, is in the third classification due to potential cost savings (crane rental) by grouping 'like' options together. Converting the three units will reduce overall consumption by 4938 CCF/yr or 1.9%.

5. HSC should conduct a separate study on Domestic water minimization for hospitals.

Domestic consumption represents a third of HSCs water use. The potential exists to reduce consumption, but there are a number of obstacles preventing implementation. Little published information coupled with infection control concerns with commonly used devices in the residential and commercial setting have limited their use. Recently, products have been designed specifically for hospitals, however they are expensive and only offer limited savings. Also, due to the number of fixtures throughout the hospital, it is important to install a reliable product that is endorsed by all players in order to prevent unforeseen operating and maintenance expenses.

Before any retrofits are recommended, with respect to domestic consumption, these obstacles need to be overcome. The focus of this research was on initiatives that were benign or transparent to patient care, therefore those issues were not addressed. HSC should conduct a separate study specific to domestic consumption. Such a study should include:

- i. a detailed literature search and survey of existing practices,
- ii. a controlled trial or case study in a metered building primarily comprised of domestic consumption,
- iii. a test of the devices, and
- iv. an economic analysis of retrofits and renovations based on capital and operating costs, annual cost savings, and payback periods.

Most importantly, it should include input from all players or stakeholders in order to ensure effective implementation.

In conclusion, the proposed 35% reduction in the sewer rate for large water users by the City of Winnipeg will result in a 33% increase in the payback periods associated with potential conservation options. Even with this increase, the payback periods are still quite favorable, approximately five years or less. However, as the mid to long term

trend is toward higher water and sewer rates, HSC has an opportunity to significantly reduce the impact associated with price rate increases by eliminating all unsustainable practices. By doing so, HSC will be seen as an environmentally (promoting sustainable resource use) and economically responsible public institution.

BIBLIOGRAPHY

- Black and Veatch, n.d., A Guide to Water Conservation for Cooling Towers, City of Los Angeles Department of Water and Power.
- Black and Veatch, 1991a, Water Conservation Report - Hospital of the Good Samaritan, City of Los Angeles Department of Water and Power.
- Black and Veatch, 1991b, Water Conservation Report - Queen of Angels Hollywood Presbyterian Hospital, City of Los Angeles Department of Water and Power.
- Brooks, D.B. and Peters, R., 1988, Water: The Potential for Demand Management in Canada, Science Council of Canada, Supply and Services Canada.
- Chartier, G., 1995, Written Communication - Winnipeg Water and Sewer Rates, City of Winnipeg Water and Waste Department, Customer Accounts Branch.
- Dangerfield, S., 1993, An Overview of Federal and Provincial Water Conservation Policies, CCME.
- Endress et al, 1989, Flow Handbook, Flowtec AG, Kagenstrasse.
- Environment Canada, 1990, Water: No Time to Waste - A Consumer's Guide to Water Conservation, Supply and Services Canada.
- Environment Canada, 1993, Manual for Conducting Water Audits and Developing Water Efficiency Programs at Federal Facilities, Interdepartmental Advisory Group on Water Conservation at Federal Facilities, Supply and Services Canada.
- Environmental Protection Agency, 1990, Guides to Pollution Prevention: Selected Hospital Waste Streams, United States Environmental Protection Agency, Cincinnati, Ohio.
- Gates, C., 1994, The Potential for Improving Water Efficiency in Existing Housing: Implications for Municipal DSM Programming, in Every Drop Counts, eds. Dan Shrubsole and Don Tate, Canada's First National Conference and Trade Show on Water Conservation, Canadian Water Resources Association.
- Hanke, S.H., 1985, The User-Pay Principle and Market Socialism, *in* The Economics of Municipal Water Supply: Applying the User-Pay Principle, S.H. Hanke and M. Fortin, Inquiry on Federal Water Policy, Environment Canada, Research Paper No. 21.

- Hillard, J., 1994, What Governments are Doing in Water Conservation - A Consumer Response, in Every Drop Counts, eds. Dan Shrubsole and Don Tate, Canada's First National Conference and Trade Show on Water Conservation, Canadian Water Resources Association.
- Kobrick, J.D. and Wilson, M.D., 1994/5, Uses of Water and Water Conservation Opportunities for Cooling Towers, AWWA., 1339-1355.
- Koslowsky, D., 1994, CPD Steam Sterilizers -- Cost Saving Request, Health Sciences Centre, Winnipeg.
- Kreutzwiser, R.D., 1991, Water Resource Management: Canadian Perspectives and the Great Lakes Water Levels Issue, in Resource Management and Development: Addressing Conflict and Uncertainty, ed. B. Mitchell, Oxford University Press.
- Manitoba Round Table on Environment & Economy, 1992, Sustainable Development: Towards Institutional Change in the Manitoba Public Sector, Manitoba Round Table on Environment & Economy, Winnipeg.
- Manitoba Round Table on Environment & Economy, 1995, Sustainable Development: Workbook on The Capital Region Strategy "Partners for the Future", Manitoba Round Table on Environment & Economy, Winnipeg.
- Marley Cooling Tower Company, 1982, The Application of Cooling Towers for Free Cooling, Technical Report No. H-002.
- Navarro, G., 1994, Proposal to Operate Chilled Water Loop Year Round, Health Sciences Centre, Winnipeg.
- Parbery, D., 1994, A Water Conservation Program for the University of Manitoba, M.N.R.M. Practicum, University of Manitoba, Winnipeg.
- Perry, Robert H., 1976, Engineering Manual -- A Practical Reference of Design Methods and Data in Building Systems, Chemical, Civil, Electrical, Mechanical, and Environmental Engineering and Energy Conservation, 3rd Edition, McGraw-Hill Book Company, New York.
- Postel, S., 1985, Conserving Water: The Untapped Alternative, Worldwatch Paper 67, Worldwatch Institute.
- REIC Ltd. and Associates, 1991, Residential Water Conservation: A Review of Products, Processes, and Practices, The Research Division, Canada Mortgage and Housing Corporation, Ottawa.

- REIC Ltd., 1992, Water Conservation - Every Drop Counts, Freshwater Series A-6, Environment Canada, Supply and Services Canada.
- Saunders, H.J., 1994, Saving Money by Metering Nonsewered Water, AIPE Facilities, May/June, p. 36.
- SMS (Scouten Mitchell Sigurdson) Consulting Engineers, 1996, Health Sciences Centre Central Chilled Water System Winter Chilled Water Supply - Preliminary Engineering, HSC Project No. 95-20-SP, SMS Project No. 94-101-02, Winnipeg.
- Sustainability Manitoba, 1994, Applying Manitoba's Water Policies, Sustainable Development, Winnipeg, Manitoba.
- Thomas Industries Inc., 1993, Pneumotive Brand Products -- Industrial Products Guide, Monroe, Louisiana.
- Treasury Board, 1976, Benefit-Cost Analysis Guide, Planning Branch, Treasury Board Secretariat, Ottawa.
- United Nations Environment Programme (UNEP), 1991, Audit and Reduction Manual for Industrial Emissions and Wastes, Technical Report Series No. 7, Paris.
- Vickers, A., 1994, Municipal Water Conservation: Designing a Program to Meet Your System's Needs, in Every Drop Counts, eds. Dan Shrubsole and Don Tate, Canada's First National Conference and Trade Show on Water Conservation, Canadian Water Resources Association.
- Wardrop Engineering Inc., 1992, Regional Water Supply Conceptual Planning Study: Phase 2 Progress Report, City of Winnipeg Waterworks, Waste, and Disposal Department.
- Wilson, M.D., 1994/5, Water Conservation for Hospitals and Health Care Facilities, AWWA, 533-541.
- Winnipeg Free Press, Thursday June 6, 1996, *Homes, Businesses May Foot Schneider Bill*, Winnipeg, page 1.
- Winpenny, J., 1994, Managing Water as an Economic Resource, Development Policy Studies, Overseas Development Institute, London.

PERSONAL COMMUNICATIONS

Anderson, Chris, 1995, Director of Operations, Children's Hospital Administration, Health Sciences Centre.

Berg, Gord, 1995, Plumbing Supervisor, Maintenance Department, Health Sciences Centre.

Berg, Gord, 1996, Plumbing Supervisor, Maintenance Department, Health Sciences Centre.

Bettencourt, Manny, 1996, Environmental Controls Supervisor, Maintenance Department, Health Sciences Centre.

Braun, Sheri, Director, Daycare - Children at the Centre, Health Sciences Centre.

Good, Lenore, 1995, Director, Volunteer Services, Health Sciences Centre.

Hatfield, Susan, 1995, Assistant Director, Central Processing Services, Materiel Management, Health Sciences Centre.

Hickerson, E., 1995, Volunteer Services Coordinator, Cancer Foundation, Health Sciences Centre.

Kirk, Elvera, 1995, Technology Training Program Coordinator, Cancer Foundation, Health Sciences Centre.

Koslowsky, David, 1995, Director, Energy Management, Property Services, Health Sciences Centre.

Koslowsky, David, 1996, Director, Energy Management, Property Services, Health Sciences Centre.

Lehmann, Ed, 1995, Chief Operating Engineer, Energy Management, Health Sciences Centre.

Lehmann, Ed, 1996, Chief Operating Engineer, Energy Management, Health Sciences Centre.

Lepp, William, 1995, Senior Dialysis Technologist, Central Dialysis Unit, Health Sciences Centre.

Lorimer, Alison, 1995, Registered Nurse, Women's O.R., Health Sciences Centre.

Loveridge, Brenda, 1995, School of Medical Rehabilitation, Health Sciences Centre.

Maslowski, Jane, 1995, Environmental Protection, Materiel Management, Health Sciences Centre.

Nicol, Sharon, 1995, Secretary, School of Nursing, Health Sciences Centre.

Popoff, Jacob, 1995a, Technical Coordinator, Radiology Department, Health Sciences Centre.

Richardson, Kathleen, 1995, Production Manager - Main Kitchen, Dietetics Department, Health Sciences Centre.

Squires, Cecil, 1995, Hostel Manager, Lennox Bell Lodge Hostel, Health Sciences Centre.

Walker, Elaine, 1996, Quality Assurance Manager, Dietetics Department, Health Sciences Centre.

Yachemitz, Ted, 1995, Director, School of Respiratory Medicine, Health Sciences Centre.

WRITTEN COMMUNICATIONS

Brodeur, Lou, 1995, December 15, Flight-A-Round Dishwashers, Brodeur Agencies.

Hobart, n.d., FTM-800/FT-800 Series Dishwasher Specifications.

King, Chris, 1995, December 13, Hobart C-44 Dishwashers, PMI Food Equipment Group Canada.

MDT Technology for Life, n.d., Castle® M/C 3525 Washer Sterilizer Data and Specifications, MDT Canada.

MDT Technology for Life, 1994, August 4, Proposal to Provide CV-129 Water Saver Modernization Package for Steam Sterilizers at the Health Sciences Centre, MDT Canada.

Miller, C., 1995a, August 30, Senior Systems Engineer, SIHI Pumps Ltd., Guelph, Ontario.

Miller, C., 1995b, September 20, Water Savings Systems, Senior Systems Engineer, SIHI Pumps Ltd., Guelph, Ontario.

Popoff, Jacob, 1995a, Technical Coordinator, Radiology Department, Health Sciences Centre.

Stack, Hazel, 1995, System Implementor, Adult Ambulatory Care, Administration and Support Services, Health Sciences Centre.

Van Dulman, Rick, 1995, Facilities Engineering, Health Sciences Centre.

Appendix A List of Abbreviations

List of Abbreviations

Abbreviation	Description
°F	Degrees Fahrenheit
12/88	12% Ethylene Oxide and 88% Freon
3ph	Three Phase
AAC	Adult Ambulatory Care
AC	Accelerated Current
ACR	Accelerated Current Recorder
AD	Intern's Residence
Ave.	Average
BA	Financial Services Building
CB	Concentration of Bleed-Off
CBA	Cost - Benefit Analysis
CCF	Hundred Cubic Feet
CDU	Central Dialysis Unit
CE	Children's Hospital - E Wing
CEP	Central Energy Plant
CFC	Chloroflourocarbon
CH	Children's Hospital - H Wing
CK	Children's Hospital - K Wing
CM	Concentration of Makeup Water
CN	Children's Hospital - N Wing
CO ₂	Carbon Dioxide
CR	Concentration Ratio
CS	Children's Hospital - S Wing

Abbreviation	Description
CSA	Canadian Standards Association
e.g.	Example
EO	Ethylene Oxide
EPA	Environmental Protection Agency
etc.	Etcetera
EtO	Ethylene Oxide
FE	Community Services Building - E Wing
FW	Community Services Building - W Wing
GA	General Hospital - A Wing
GB	General Hospital - B Wing
GC	General Hospital - C Wing
GD	General Hospital - D Wing
GE	General Hospital - E Wing
GF	General Hospital - F Wing
GG	General Hospital - G Wing
GH	General Hospital - H Wing
GPD	Gallons per Day
gpm	Gallons per Minute
HCFC	Hydrochloroflourocarbons
HP	Horsepower
hr	Hour(s)
HSC	Health Sciences Centre
Imp.	Imperial
L	Liter
LA	Laundry Building
LB	Lennox Bell Lodge
MA	Maintenance Building

Abbreviation	Description
Med.	Medicine
MH	Materials Handling Building
min	Minute(s)
MS	Thorlakson Medical Support
n.d.	No Date
NA	School of Nursing
O.R.	Operating Room(s)
ON	Cancer Building
PX	PsychHealth Building - X Wing
PY	PsychHealth Building - Y Wing
PZ	PsychHealth Building - Z Wing
rla	Rotor Locked Amps
RR	Rehabilitation Hospital
RS	Respiratory Hospital
SCD	Self-Care Dialysis Building
SMS	Scouten Mitchell Sigurdson
sq.ft	Square Feet
TW	Tunnel
ULV	Ultra Low Volume
UNEP	United Nations Environmental Programme
US	United States
V	Volts
Wk	Week
WR	Women's Hospital - R Wing
WS	Women's Hospital - S Wing
WT	Women's Hospital - T Wing
yr	Year

Appendix B HSC Water Meter Information

Water Consumption - Health Sciences Centre

QUARTER	CONSUMPTION (CCF)			
	91/92	92/93	93/94	94/95
APR-JUNE	69,616	59,692	58,227	60,067
JULY-SEPT	85,039	73,279	67,597	72,823
OCT-DEC	70,403	64,183	62,900	62,446
JAN-MARCH	61,408	71,176	68,333	60,872
PsychHealth Adjustment	-	1,049	5,156	5,662
TOTALS	286,467	269,379	262,213	261,869
Cost/CCF	2.44	2.64	2.96	3.27
% Change	12%	8%	12%	10%

Two Year Average (CCF/yr) = 262,041

Average Cost/CCF Increase 10.6%

Appendix C Theoretical vs. Actual Flow Rates for HSC Condensers

Theoretical vs. Actual Flow Rates for HSC Condensers

Room	Month Observed	HP	Delta T° (°F)	Actual US GPM	Calc. US GPM	Actual/ Calc
GH-195A (cu-7)	July	1.8	18	1.0	3.2	.31
GH-195A (cu-8)	July	7.6	15	2.3	14.6	.16
ON-302	July	1.7	20	.7	2.2	.32
CS-006	July	6.1	32	1.2	2.7	.44
MS-444	July	1.58	11	.8	1.5	.53
MS-635E	July	1.8	12	1	3.7	.27
MS-449	July	4.8	12	1.7	7.3	.23
RR-044B	July	3.1	12	1.1	8	.14
MS-055B	July	2	9	1.8	2.9	.62
ON-040	July	2.4	14	2.6	6.3	.41
Plumbing	November	3	49	2.2	1.8	1.24
CCMS	November	3	41	2.2	2.1	1.01
BA-001	July	12	20	12	30.7	.39
GH-014	November	10	41	6	7.1	.85
ON-302	November	1.7	49	0.7	1.0	.66
NA-154	November	5	49	1.2	3	.40
GF-120	November	5	49	2.1	3	.71
CS-006	November	6.1	61	.9	2.9	.29
Average						.50

Appendix D HSC Condenser Loads

HSCs Condenser Loads

Room	Cooling Type	% ON
CS-111	Computer	24
ON-040	Space	44
MA-005A	Space	52
GH-195A (Garbage Rm.)	Process	52
MA-002	Space	53
GH-195A (#7)	Process	55
GC-420	Space	59
TW-37B	Space	68
GH-195A (CU-5)	Process	88
GG-347B	Space	98
GD-043 (F-37)	Space	100
GD-043 (F-38)	Space	99
WT-561	Space	14
CS-231	Space	1
NA-154	Space	81
	Average	59%

Appendix E Water-Cooled Condensers Summer and Winter Consumption

HSCs Water-Cooled Condensers Summer Consumption

Room #	Unit #	Horsepower & Usage			(A)	(B)	(C)	(D)	(E)	(F)	Consumption
		All Year	Spoiled	Summer	Delta T °F	GPM US	Adjustment	Summer Days	Load	% Theory	
GE-426				5	20	7.3	1	165	0.59	0.5	511672
GE-708		5			20	7.3	1	165	0.59	0.5	511672
GE-122A		2			20	2.9	1	165	0.59	0.5	203267
GE-118		6.1			20	8.8	1	165	0.59	0.5	616810
GH-014	#1	2.4			18	4.1	1	165	0.59	0.5	287377
	#2	2.4			26	2.8	1	165	0.59	0.5	196258
	#3	2.4			11	6.6	1	165	0.59	0.5	462607
GH-195A	CU-7	1.8			18	3.2	1	165	0.59	0.5	224294
	CU-8	7.6			15	14.6	1	165	0.59	0.5	1023343
	CU-11	NOT OPERATIONAL			20		1	165	0.59	0.5	0
	no. 10	7.2			13	15.7	1	165	0.59	0.5	1100444
	Dairy	7.5			34	6.4	1	165	0.59	0.5	448589
	no. 5	13.5			11	35.8	1	165	0.59	0.5	2509294
	Garbage	7.4			5	43.8	1	165	0.59	0.5	3070030
	Copeland	5.2			18	8.1	1	165	0.59	0.5	567745
	Salad	2			19	3.1	1	165	0.59	0.5	217285
	no. 7	2			23	2.5	1	165	0.59	0.5	175230
GG-158	FC-111	Included with GG-038			20		0	165	0.59	0.5	0
GG-169	FC-114	Included with GG-038			20		0	165	0.59	0.5	0
GG-639		5			21	7	1	165	0.59	0.5	490644
GG-346			6.3		20	7.3	0	165	0.59	0.5	0
GG-347B		3.6			17	5.2	1	165	0.59	0.5	364478
GG-038	SPOOLED		25		20	36.5	0	165	0.59	0.5	0
GF-632		20			22	26.5	1	165	0.59	0.5	1857438
GF-120		5			20	7.3	1	165	0.59	0.5	511672
GD-043	Supply Fan (F-37)		4.5		20	5.8	1	165	0.59	0.5	406534
	Supply Fan (F-38)		4.5		18	6.5	1	165	0.59	0.5	455598
	CR-1		2		19	3.1	1	165	0.59	0.5	217285
	CR-2		1.5		19	2.3	1	165	0.59	0.5	161212
GD-725		3			20	4.4	1	165	0.59	0.5	308405
GC-420		7.5			24	9.1	1	165	0.59	0.5	637837
GC-107		3			13	6.7	1	165	0.59	0.5	469616
GC-112		1.5			20	2.2	1	165	0.59	0.5	154202
GA-150		3			20	4.35	1	165	0.59	0.5	304900
NA-017				5	20	7.3	1	165	0.59	0.5	511672
NA-154		5			20	7.3	1	165	0.59	0.5	511672
NA-029A				7.3	20	7.3	1	165	0.59	0.5	511672
TW37B	Supply Fan (F-13) & (F-14)		10		20	14.6	1	165	0.59	0.5	1023343
TW39D	CR-1	1			5	2.9	1	165	0.59	0.5	203267
	CR-2	0.8			12	1.2	1	165	0.59	0.5	84110
	CR-3	0.8			7	2.1	1	165	0.59	0.5	147193
	CR-4	2.2			15	3.9	1	165	0.59	0.5	273359
	CR-5	2.9			16	5.5	1	165	0.59	0.5	385506
	CR-6	0.8			2	7.3	1	165	0.59	0.5	511672
RS-303			1.5		20	2.2	1	165	0.59	0.5	154202
RS-307			1.5		20	2.2	1	165	0.59	0.5	154202
RR-029A	#2	0.33			20	0.5	1	165	0.59	0.5	35046
	#3	1			27	1.1	1	165	0.59	0.5	77101
	#4	2			10	5.8	1	165	0.59	0.5	406534
	#5	1			18	1.6	1	165	0.59	0.5	112147

RR-044B	3.1			11	8	1	165	0.59	0.5	560736
WS-002	12.9			22	13.3	1	165	0.59	0.5	932224
WR-206			10	26	11.2	1	165	0.59	0.5	785030
WS-202A	1.5			14	3.1	1	165	0.59	0.5	217285
WR-506A			10	11	26.5	1	165	0.59	0.5	1857438
WT-563	8			8	18.3	1	165	0.59	0.5	1282684
BA-001			20.7	19	30.7	1	165	0.59	0.5	2151824
ON-040	2.4			14	6.3	1	165	0.59	0.5	441580
ON-048		3		9	9.7	0	165	0.59	0.5	0
ON-059		5		9	16.2	0	165	0.59	0.5	0
ON-231	1.4			20	2.2	1	165	0.59	0.5	154202
ON-245	1.4			20	2.2	1	165	0.59	0.5	154202
ON-302	1.7			20	2.2	1	165	0.59	0.5	154202
ON-174A	2			22	2.7	1	165	0.59	0.5	189248
CS-006	6.1			32	2.7	1	165	0.59	0.5	189248
CS-105	2			17	3.4	1	165	0.59	0.5	238313
Climate Master #1				32	2.3	1	165	0.59	0.5	161212
Climate Master #2	5.5			11	13.3	1	165	0.59	0.5	932224
CS-111	6.2			12	12.2	1	165	0.59	0.5	855122
Supply Fan F-95 (AC-1)	4.7			13	11.2	1	165	0.59	0.5	785030
Supply Fan F-96 (AC-4)	5			9	9.7	1	165	0.59	0.5	679892
CS-116				20	4.4	0	165	0.59	0.5	0
CS-231		4		20	4.4	1	165	0.59	0.5	308405
CCMS		3		20	2.2	1	165	0.59	0.5	154202
Plumbing	3			20	2.9	1	165	0.59	0.5	203267
MH-009B	2			20	2.9	1	165	0.59	0.5	203267
MH-009C	1.5			20	1.5	1	165	0.59	0.5	105138
MH-114	2			12	7.3	1	165	0.59	0.5	511672
MS-444	4.8			16	1.8	1	165	0.59	0.5	126166
MS-449	4.8			20	1.5	1	165	0.59	0.5	105138
MS-458A		4.1		20	1.5	1	165	0.59	0.5	105138
MS-543R	1.8			20	2.9	1	165	0.59	0.5	203267
MS-551E	2.4			12	3.7	1	165	0.59	0.5	259340
Convicon #1	3.4			20	2.2	1	165	0.59	0.5	154202
Convicon #2	1.8			20	4.4	1	165	0.59	0.5	308405
MS-635E	2.4			20	1.5	1	165	0.59	0.5	105138
MS-655A	2.5			20	2.9	1	165	0.59	0.5	203267
MS-655D	4.1			20	4.4	1	165	0.59	0.5	308405
MS-773	2			20	4.4	1	165	0.59	0.5	308405
MS-055B	3			20	14.6	1	165	0.59	0.5	1023343
AD-202A				23	6.9	1	165	0.59	0.5	483635
FE-018			10.2	20	4.4	0	165	0.59	0.5	0
Copeland #1			7.7	20	4.4	0	165	0.59	0.5	0
Copeland #2				20	4.4	0	165	0.59	0.5	0
PX-077		3		20	4.4	0	165	0.59	0.5	0
PX-049		3		20	4.4	0	165	0.59	0.5	0
PX-056A		3		20	4.4	0	165	0.59	0.5	0
PY-204		3		20	4.4	0	165	0.59	0.5	0

Total Horsepower 249.33 87.9 75.9

Consumption = A*B*C*D*E*F*24hrs/day*60min/hr
Gallons per Minute (GPM) = 14,544/(500*(A))
Adjustment: 0 = Summer Unit Only 1 = Operational

US Gallons/Summer 41,161,527
CCF/Summer 65,029
% of Total 21.0%
Cost (\$) \$ 182,696

HSCs Water-Cooled Condensers Winter Consumption

Room #	Unit #	Horsepower & Usage			(A)	(B)	(C)	(D)	(E)	(F)	GPWinter
		All Year	Spoiled	Summer	Delta T °F	GPM US	Days Winter	Adjustment	Load	% Theory	
GE-426				5	49	3.0	200	0	0.59	0.5	0
GE-708		5			49	3.0	200	1	0.59	0.5	254880
GE-122A		2			49	1.2	200	1	0.59	0.5	101952
GE-118		6.1			49	3.6	200	1	0.59	0.5	305856
GH-014	#1	2.4			47	1.5	200	1	0.59	0.5	127440
	#2	2.4			55	1.3	200	1	0.59	0.5	110448
	#3	2.4			40	1.7	200	1	0.59	0.5	144432
GH-195A	CU-7	1.8			47	1.1	200	1	0.59	0.5	93456
	CU-8	7.6			44	5.0	200	1	0.59	0.5	424800
	no. 10	7.2			42	5.0	200	1	0.59	0.5	424800
	Dairy	7.5			63	3.5	200	1	0.59	0.5	297360
	no. 5	13.5			40	9.8	200	1	0.59	0.5	832608
	Garbage	7.4			34	6.3	200	1	0.59	0.5	535248
	Copeland	5.2			47	3.2	200	1	0.59	0.5	271872
	Salad	2			48	1.2	200	1	0.59	0.5	101952
	no. 7	2			52	1.1	200	1	0.59	0.5	93456
		Included with GG-038			49	0.0	200	1	0.59	0.5	0
GG-169		Included with GG-038			49	0.0	200	1	0.59	0.5	0
GG-639		5			50	2.9	200	1	0.59	0.5	246384
GG-346			6.3		49	3.7	200	1	0.59	0.5	314352
GG-347B		3.6			46	2.3	200	1	0.59	0.5	195408
GG-038			25		49	14.8	200	1	0.59	0.5	1257408
GF-632		20			51	11.4	200	0	0.59	0.5	0
GF-120		5			49	3.0	200	1	0.59	0.5	254880
GD-043	Supply Fan (F-37)		4.5		49	2.7	200	1	0.59	0.5	229392
	Supply Fan (F-38)		4.5		47	2.8	200	1	0.59	0.5	237888
	CR-1		2		48	1.2	200	1	0.59	0.5	101952
	CR-2		1.5		48	0.9	200	1	0.59	0.5	76464
GD-725		3			49	1.8	200	1	0.59	0.5	152928
GC-420		7.5			53	4.1	200	1	0.59	0.5	348336
GC-107		3			42	2.1	200	1	0.59	0.5	178416
GC-112		1.5			49	0.9	200	1	0.59	0.5	76464
GA-150		3			49	1.8	200	1	0.59	0.5	152928
NA-017				5	49	3.0	200	0	0.59	0.5	0
NA-154		5			49	3.0	200	1	0.59	0.5	254880
NA-029A				7.3	50	4.2	200	0	0.59	0.5	0
TW37B	Supply Fan (F-13) & (F-14)		10		49	5.9	200	1	0.59	0.5	501264
TW39D	CR-1	1			34	0.9	200	1	0.59	0.5	76464
	CR-2	0.8			41	0.6	200	1	0.59	0.5	50976
	CR-3	0.8			36	0.6	200	1	0.59	0.5	50976
	CR-4	2.2			44	1.5	200	1	0.59	0.5	127440
	CR-5	2.9			45	1.9	200	1	0.59	0.5	161424
	CR-6	0.8			31	0.8	200	1	0.59	0.5	67968
RS-303			1.5		39	1.1	200	1	0.59	0.5	93456
RS-307			1.5		39	1.1	200	1	0.59	0.5	93456
RR-029A	#2	0.33			49	0.2	200	1	0.59	0.5	16992
	#3	1			56	0.5	200	1	0.59	0.5	42480
	#4	2			39	1.5	200	1	0.59	0.5	127440

#5	1		47	0.6	200	1	0.59	0.5	50976
RR-044B	3.1		40	2.3	200	1	0.59	0.5	195408
WS-002	12.9		51	7.4	200	1	0.59	0.5	628704
WR-206		10	55	5.3	200	0	0.59	0.5	0
WS-202A	15		43	1.0	200	1	0.59	0.5	84960
WR-506A		10	40	7.3	200	0	0.59	0.5	0
WT-563	8		37	6.3	200	1	0.59	0.5	535248
BA-001		20.7	48	12.5	200	0	0.59	0.5	0
ON-040	2.4		43	1.6	200	1	0.59	0.5	135936
ON-048		3	38	2.3	200	1	0.59	0.5	195408
ON-059		5	38	3.8	200	1	0.59	0.5	322848
ON-231	1.4		49	0.8	200	1	0.59	0.5	67968
ON-245	1.4		49	0.8	200	1	0.59	0.5	67968
ON-302	1.7		49	1.0	200	1	0.59	0.5	84960
ON-174A	2		51	1.1	200	1	0.59	0.5	93456
CS-006	6.1		61	2.9	200	1	0.59	0.5	246384
CS-105	2		46	1.3	200	1	0.59	0.5	110448
	5.5		61	2.6	200	1	0.59	0.5	220896
CS-111	Supply Fan F-95 (AC-1)	6.2	40	4.5	200	1	0.59	0.5	382320
	Supply Fan F-96 (AC-4)	4.7	41	3.3	200	1	0.59	0.5	280368
CS-116		5	42	3.5	200	1	0.59	0.5	297360
CS-231		4	38	3.1	200	1	0.59	0.5	263376
CCMS		3	41	2.1	200	1	0.59	0.5	178416
Plumbing	3		49	1.8	200	1	0.59	0.5	152928
MH-009B	2		35	1.7	200	1	0.59	0.5	144432
MH-009C	1.5		31	1.4	200	1	0.59	0.5	118944
MH-114	2		49	1.2	200	1	0.59	0.5	101952
MS-444	4.8		41	3.4	200	1	0.59	0.5	288864
MS-449	4.8		41	3.4	200	1	0.59	0.5	288864
MS-458A		4.1	45	2.7	200	1	0.59	0.5	229392
MS-543R	1.8		49	1.1	200	1	0.59	0.5	93456
MS-551E	Convicon #1	2.4	45	1.6	200	1	0.59	0.5	135936
	Convicon #2	3.4	45	2.2	200	1	0.59	0.5	186912
MS-635E		1.8	41	1.3	200	1	0.59	0.5	110448
MS-655A		2.4	49	1.4	200	1	0.59	0.5	118944
MS-655D		2.5	49	1.5	200	1	0.59	0.5	127440
MS-773		4.1	49	2.4	200	1	0.59	0.5	203904
MS-055B		2	38	1.5	200	1	0.59	0.5	127440
AD-202A		3	49	1.8	200	0	0.59	0.5	0
FE-018	Copeland #1		49	6.1	200	0	0.59	0.5	0
	Copeland #2		52	4.3	200	0	0.59	0.5	0
PX-077		3	49	0.0	200	0	0.59	0.5	0
PX-049		3	49	0.0	200	0	0.59	0.5	0
PX-056A		3	49	0.0	200	0	0.59	0.5	0
PY-204		3	49	0.0	200	0	0.59	0.5	0

Total Horsepower 249.33 87.9 75.9

Consumption = A*B*C*D*E*F*24hrs/day*60min/hr
Gallons per Minute (GPM) = 14,544/(500*(A))
Adjustment 0 = Summer Only 1 = Operational

US Gallons/Winter 16,482,240
CCF/Winter 22,035

% of Total 8.4%
Cost (\$) \$ 73,156

Appendix F Water Balance Accuracy Assessment

Water Balance Accuracy Assessment

Financial Services

Average CCF/yr 1,172
Square Footage 15,186

Consumption Estimates	CCF
Domestic Consumption	653
Hot Water	243
Condenser	2,877
Total CCF	3,773
Percent	322%

PsychHealth Building

Average CCF/yr 5,409
Square Footage 179,073

Consumption Estimates	CCF
Domestic Consumption	7,700
Hot Water	2,865
Condenser	-
Total CCF	10,565
Percent	195%

Womens Hospital

Average CCF/yr 14,844
Square Footage 95,029

Consumption Estimates	CCF
Domestic Consumption	4,086
Hot Water	1,520
Condenser	8,454
Medical Vacuum & Air	1,475
Sterilizer	1,690
Total CCF	17,225
Percent	116%

Cancer Building

Average CCF/yr 15,579
Square Footage 99,941

Consumption Estimates	CCF
Domestic Consumption	4,297
Hot Water	1,599
Condenser	2,757
Medical Vacuum & Air	1,763
Total CCF	10,416
Percent	67%

School of Nursing

Average CCF/yr 2,699
Square Footage 89,324

Consumption Estimates	CCF
Domestic Consumption	3,841
Hot Water	1,429
Condenser	2,393
Total CCF	7,663
Percent	284%

Childrens Hospital (CE/CS/CN)

Average CCF/yr 20,001
Square Footage 119,728

Consumption Estimates	CCF
Domestic Consumption	5,148
Hot Water	1,916
Condenser	7,543
Medical Vacuum & Air	5,232
X-Ray Processing	155
Sterilizers	201
Total CCF	20,194
Percent	101%

Internes Residence

Average CCF/yr 1,316
Square Footage 27,190

Consumption Estimates	CCF
Domestic Consumption	1,169
Hot Water	435
Condenser	412
Total CCF	2,017
Percent	153%

Lennox Bell Lodge

Average CCF/yr 1,530
Square Footage 36,214

Consumption Estimates	CCF
Domestic Consumption	1,557
Hot Water	579
Total CCF	2,137
Percent	140%

Respiratory/Rehabilitation Hospital (RR/RS)

Average CCF/yr 11,386
Square Footage 200,825

Consumption Estimates	CCF
Domestic Consumption	8,635
Hot Water	3,213
Condenser	2,834
Medical Vacuum & Air	257
X-Ray Processing	482

Total CCF 15,422
Percent 135%

General Hospital Service (GA to GH, AD, MA, LB, WR/WS/WT, LA2&3, MH)

Average CCF/yr 133,108
Square Footage 884,240

Consumption Estimates	CCF
Domestic Consumption	38,022
Hot Water	14,148
Condenser	46,266
Medical Vacuum & Air	10,371
X-Ray Processing	3,478
Kitchen & Cafeteria	4,187
Sterilizers	14,267

Total CCF 130,740
Percent 98%

Sherbrook Parkade Service (CE/CS/CN/CK/CH, MS, RR/RS, ON, NA)

Average CCF/yr 77,502
Square Footage 885,016

Consumption Estimates	CCF
Domestic Consumption	38,056
Hot Water	14,160
Condenser	23,883
Medical Vacuum & Air	8,008
X-Ray Processing	637
Kitchen & Cafeteria	2,209
Sterilizers	975

Total CCF 87,928
Percent 113%

Weighted Average Based on Square Footage
Weighted Average Based on CCF

121%
108%

Appendix G Financial Services Condenser's Consumption Methodology

Methodology to determine water consumption associated with the water-cooled condenser in the Financial Services Building.

CONSUMPTION (CCF)

Fiscal Year	88/89	89/90	90/91	91/92	92/93	93/94	94/95
April	29	62	41	42	31	38	29
May	149	225	89	166	67	73	109
June	332	215	194	226	95	164	258
July	304	435	376	172	61	123	292
August	504	649	298	295	118	207	327
September	202	564	112	80	44	78	209
October	112	357	26	45	52	125	65
November	35	24	29	45	26	35	26
December	22	19	20	37	20	20	19
January	23	21	27	50	46	24	21
February	25	26	41	36	44	23	30
March	27	27	88	37	56	25	22
CCF/yr	1764	2623	1341	1230	659	936	1407

Since this building is affected by outside temperatures, year-round consumption was estimated using data from 1988 to present.

Financial Services Building Average Annual Consumption (CCF/yr) = 1423

Since the condenser is not operational during winter, the original two-year methodology was used.

Non-Summer Average Monthly Consumption Nov. to April (CCF/yr) = 26

Average Condenser Consumption = $1423 - (26 \times 12) = 1111$ CCF/yr