

APPLICATION OF PROBABILITY TECHNIQUES
IN THE EVALUATION OF GENERATING
CAPACITY REQUIREMENTS

A Thesis
Presented to
The Faculty of Graduate Studies and Research
The University of Manitoba

In Partial Fulfillment
of the Requirements for the Degree
Master of Science
in Electrical Engineering

by
Roy Billinton
March 1963



PREFACE

A major capital expenditure in a modern power system is for generating facilities. These installations must be such that the load as a whole is supplied as economically as possible and with a reasonable assurance of the continuity of that service.

The determination of what is and what will be a reasonable assurance of continuity is an important problem which must be faced by engineering and management personnel. The usual approach to this problem in the past has been by relatively inflexible rule of thumb techniques such as a fixed percentage reserve. Considerable literature over the past twenty years has been published on the application of probability techniques to the evaluation of system generating capacity requirements. An unfortunate belief exists in most management and engineering circles that probability methods are the exclusive tools of statisticians and mathematicians and as such are complicated and somewhat difficult to understand without specialized training.

This thesis shows that the basic application of probability to the problem of system generating capacity requirements is not difficult to understand and should be readily acceptable to those concerned with generation planning. The added refinements which can be applied should remain as tools of the specialist but the basic concepts are relatively

simple and provide a sound basis for evaluation of reliability in comparative schemes of system capacity expansion.

The author wishes to express his appreciation to Manitoba Hydro for its assistance in the preparation of this thesis.

ABSTRACT

An attempt is made to remove the suspicion with which most engineering and management personnel regard a supposedly highly mathematical and abstract concept known as probability. The general application of this technique to system generating capacity requirements is basically simple and should be readily acceptable to those concerned with generating capacity planning while leaving the refinements to the statistician or mathematician.

TABLE OF CONTENTS

	PAGE
List of Figures	viii
List of Tables	ix
CHAPTER	
I. GENERAL CONSIDERATIONS IN THE EVALUATION OF GENERATING CAPACITY REQUIREMENTS	1
Introduction	1
Spinning Reserves	1
Static Reserves	3
Effect of Unit Size on Generating Capacity Reserves	5
Effect of Interconnections on Generating Capacity Reserves	6
Application of Probability in Planning Generating Capacity Requirements	6
II. APPLICATION OF PROBABILITY TECHNIQUES	8
Probability	8
A Priori Probability	8
Statistical or Empirical Probabilities ...	9
Forced Outage Rate	10
Generating Plant Reliability	14
Individual Unit Case	15
Two Unit Generating Station With Header System	17
Outage Probability Values for Non-Identical Units	20
III. LOAD FORECASTING	26
General Considerations	26

	PAGE
Detailed Load Forecasting	28
Load Characteristics Required in Evaluating Reliability	29
Load Duration Curve	29
Daily Peak Load Variation Curve	31
Uncertainties in Load Forecasting	32
Comments	33
IV. EVALUATION OF GENERATING CAPACITY RELIABILITY	34
Available Methods	34
Loss of Load Probability	34
Loss of Energy Probability	40
Interval Between Outages	43
Interconnection Effects	44
Comments	47
V. A CONCEPT OF TRANSMISSION RELIABILITY	49
General Considerations	49
Quality of Service	49
Design Criteria	50
Establishing an Index of Reliability	51
Comments	52
VI. A THEORETICAL PROBLEM	54
The Problem	54
Theoretical Systems	54
System Load Characteristics	56
Rule of Thumb Approach to Adequate Reliability	57

	PAGE
Probability Methods Approach To Adequate Reliability	58
Effect of Unit Size	59
Firm Capacity Purchases	61
Continuous Addition of Large Units To A System	62
Interconnection of Systems	63
Conclusions	65
VII. COMBINED SOUTHERN MANITOBA SYSTEM	67
Generating Facilities	67
Assumptions	68
Present Reliability Criteria	68
Reliability Using Probability Techniques ..	69
Conclusions	71
VIII. CONCLUSION	75
REFERENCES	77
APPENDIX A	82
APPENDIX B	140

LIST OF FIGURES

FIGURE	PAGE
1. Typical Plot of Cumulative and Individual Forced Outage Rate	13
2. Typical Load Duration Curve	30
3. Typical Daily Peak Load Variation Curve	31
4. Typical Probable Load Forecast Accuracy Curve.	32
5. Relationship Between Peak Load and Installed Capacity in a Typical System	36
6. Typical Curve Relating Risk of Loss of Load and System Peak Load	39
7. Typical Curve Showing Energy Curtailed Due to Generating Capacity Deficiency	41
8. Typical Curve Relating Index of Reliability and System Peak Load	42
9. Load Duration and Daily Peak Load Variation Curve Used For Theoretical Systems	57

LIST OF TABLES

TABLE	PAGE
I. Theoretical Systems	54
II. Theoretical System Data	55
III. Theoretical Interconnected System Data	56
IV. Theoretical System Peak Loads by Percentage Reserve Criterion	57
V. Reliability of Individual Theoretical Systems	58
VI. Allowable Peak Load Values Under Assigned Risk of Loss of Load for the Theoretical Systems	59
VII. Percentage of Units Added Available to the System	60
VIII. Allowable Peak Load Values Under Assigned Index of Reliability for the Theoretical Systems	60
IX. Increase in Load Carrying Ability With A Firm Capacity Purchase	61
X. Variation in Percentage Reserve Criterion For A Fixed Risk of Loss of Load with the Addition of Large Units	62
XI. Load Carrying Ability of Individual and Interconnected Systems	63
XII. Generating Facilities in the Combined Southern Manitoba System	67

TABLE	PAGE
XIII. Maximum Peak Loads by Percentage Reserve Criterion for the Combined Southern Manitoba System	69
XIV. Risk Levels For A Capacity Reserve of 12% .	69
XV. Maximum Peak Loads After Addition of Units at Grand Rapids	70
XVI. Variation In Percentage Reserve With Addition of Units at Grand Rapids	70
XVII. Increase In Load Carrying Capacity of the System With Units at Grand Rapids	71

CHAPTER I

GENERAL CONSIDERATIONS IN THE EVALUATION OF GENERATING CAPACITY REQUIREMENTS

INTRODUCTION

A prime requisite of a modern power system is the ability to meet the constantly changing system load at all times. An absolute guarantee of this ability is impossible and any attempt to approach this condition is impractical and uneconomical. An important function of the System Planning Engineer in a modern power system is to analytically determine the level of reliability to strive for and the attendant cost of maintaining this level.

The term "Generating Capacity Requirements" embraces all the factors which must be considered in the study and planning of generating capacity reserves in a modern power system. The system generating capacity must be sufficient so that the load as a whole will be supplied most economically and with a reasonable assurance of the continuity of this service. To measure the assurance of system continuity requires a determination of the reliability level of the system generating facilities and the risk of failure to meet and supply the system load demand.

SPINNING RESERVES

A certain reserve of capacity and energy known as the

"Spinning or Rolling Reserve" must be available at all times.

This generating capacity should not be less than the sum of:

- (a) the capacity required to meet load changes without impairing system frequency
- (b) the capacity of the greatest single risk of outage.

In interconnected systems with adequate tie-line facilities, condition (b) can be modified somewhat. A spinning reserve less than the capacity of the largest working unit in the system can be used if assistance from neighboring systems is available. In an isolated or interconnected system, condition (b) can be further modified by provision for shedding certain portions of the system load at times of generating capacity deficiencies. This provision can be accomplished by under-frequency relaying of large blocks of load. Though not particularly desirable, this ability to shed load under sudden outage conditions can produce sizable economic advantages if the spinning reserve is provided by thermal generating units.

The generating capacity requirements of condition (a) can also be reduced by accurate daily and hourly forecasting of the system load, accompanied by constant and adequate generation dispatching. Human abilities are augmented in most large systems especially those possessing considerable thermal generation by analog or digital techniques.

A method which can be used to reduce the system load at times of generating capacity deficiencies is to lower the

system voltage level slightly. Filament lamps will glow less brightly and some motor drives may experience outages due to increased current flow. This method should not be regarded as a means of reducing the required reserve margin but as a last resort in keeping the system together.

Assuming adequate transmission facilities, the "Spinning Reserve" held by one or a group of systems should be able to replace immediately the loss of capacity caused by the greatest single risk of outage.

STATIC RESERVES

In addition to the "Spinning Reserve" maintained by a system there must also exist a further reserve known as a "Static Reserve". This additional reserve must be sufficient to provide for:

- (a) the overhaul of generating equipment
- (b) outages which are not planned or scheduled
- (c) load growth requirements in excess of the estimates.

A generally standard practice that has developed over many years is to consider or measure the adequacy of both the planned and installed generating capacity in terms of a percentage reserve. This figure is computed by dividing the amount that the effective rating or capability of the installed capacity exceeds the expected or forecast annual peak load by that load. The capability of the installed capacity component does not include reductions due to scheduled and routine

maintenance or miscellaneous and seasonal capacity reductions.

Load forecasts made several years in advance or in the case of extremely advanced planning, five to fifteen years in advance, are subject to considerable uncertainty. An important factor in the consideration of an adequate allowance for installed generating capacity requirements is a probable load forecasting error. If some percentage of installed generating capacity is used for planning purposes and a large positive load forecasting error occurs, the actual available reserve will be considerably reduced from the design requirement. The occurrence of such a situation could be interpreted as an indication that inadequate generation planning had resulted in a deficiency of generating capacity.

An important objection to the use of the percentage reserve requirement criterion is the resultant tendency to compare the relative adequacy of generating capacity requirements provided for totally different systems on the basis of peak loads experienced throughout the year. Large differences in generating capacity requirements to provide the same assurance of continuity of service may be required in two different systems with system peak loads of the same magnitude. This situation could occur when the two systems to be compared have different types of installed or planned generating capacity with different forced outage rates, scheduled maintenance periods and system load characteristics.

To achieve the most economical expansion of the system

the installation of relatively large blocks of generating capacity may be required. This may result in some surplus of generating capacity in the system for a short period following such an addition. This overbuilding can be partially offset by firm capacity purchases from neighboring systems thus allowing major generating capacity additions to be delayed one or more years at a considerable saving.

EFFECT OF UNIT SIZE ON GENERATING CAPACITY RESERVES

An important condition which must be realized is the effect of generator unit size upon generating capacity requirements. There are several viewpoints on this matter. A point of view which stems from the policy of planning generating capacity additions to provide reserves equal to a fixed percentage of peak load is that unit size does not affect generating capacity requirements. This concept attaches no penalty to a unit because of its size unless this quantity exceeds the total generating capacity reserve. Another criterion is that the generating capacity reserve should equal the capacity of the largest unit on the system plus a fixed percentage of the total installed generating capacity of the system. A third viewpoint is that the reserve requirements increase with the addition of larger size units to the system. This characteristic generally results when generating capacity requirements are determined by probability techniques. The application of probability to reserve

capacity requirements is the approach elaborated here, as it provides an analytical basis for generating capacity planning which can be extended to cover partial or complete integration of systems, capacity of interconnections, effects of unit size and design, effects of maintenance schedules and other system parameters.

EFFECT OF INTERCONNECTIONS ON GENERATING CAPACITY RESERVES

The effect of interconnections between systems is an important factor in planning adequate reserve margins. Due to the diversity of forced outages and peak loads between two areas, integration through adequate interconnections will allow each area to operate with less reserve than would be required for isolated operation. In taking an interconnection into account in a generating capacity requirement study the level of system reliability of the neighboring system must be determined, together with that of the system under study.

APPLICATION OF PROBABILITY IN PLANNING GENERATING CAPACITY REQUIREMENTS

Unfortunately no standard criterion of adequate generating capacity requirements exists and each system must be analyzed individually on its own merits. It has been stated that:¹

"Reserve requirements in the past have been based upon rule of thumb criteria such as the fixed percentage of reserve or the outage of one or more of the largest generator units. The relationship between service reliability and such factors as the size of generator

additions, the capacity of interconnections, the accuracy of load forecasts, the load duration characteristics and the maintenance schedules can be described only by mathematical methods based upon probability."

Application of probability techniques to this problem is an exceedingly laborious process which fortunately can be reduced considerably with the aid of a medium size digital computer. The basic concepts, however, are quite simple and do not require specialized statistical or mathematical training in order to be understood.

CHAPTER II

APPLICATION OF PROBABILITY TECHNIQUES

PROBABILITY

"In all probability" is a common phrase used in everyday conversation and people are constantly making predictions based upon what they believe is probable. Predictions based upon personal opinion with no statistical evidence cannot normally be lent credence. Philosophically, it is possible to consider all causal relationships in terms of probability. For a given cause it is possible to have some knowledge of the event which is most likely to occur but without absolute certainty of the result until it actually occurs. If a large amount of previous data has been accumulated action can usually be taken on the basis of a high degree of certainty. A statistician, therefore, provides himself with a graduated yardstick with end points of zero and one. The zero point represents a situation in which there is no possibility of the event occurring whilst unity indicates absolute certainty. Any position on the yardstick between these two points represents a relative measure of probability.

A PRIORI PROBABILITIES

This type of probability can be specified from the very nature of the event. If a coin is tossed over a very flat surface, because of our prior knowledge we know that

the coin must lie either heads or tails. We consider the case of standing on edge to be entirely non-existent with an infinitesimal probability of occurrence. The probability of getting a head or a tail is exactly one half.

A second example of this type of probability is the result of rolling a die. If the die has six faces each with an equal probability of occurrence then in a single toss each face has a probability of one sixth of being in a designated position.

A priori probability is then, the predicted probability of an event occurring or not occurring based upon prior knowledge of the nature of the event.

STATISTICAL OR EMPIRICAL PROBABILITIES

This type of probability is based upon actual measured data concerning an event rather than the intrinsic properties of the event. In general this can be expressed as the number of occurrences of an event divided by the number of trials taken.

An example of this type of probability is the basic quantity used in the evaluation of generating capacity requirements. If over a long period of time a piece of equipment has operated a total time "I" and has been on forced outage a total time "F" then the probability of forced outage "p" can be expressed as:

$$p = \frac{F}{F + I}$$

The probability of the equipment remaining in operation "q" is given by:

$$q = \frac{I}{F + I}$$

and

$$p + q = 1$$

The term (F + I) is known as the demand time while "p" and "q" are known as the forced outage and availability rates respectively.

If the assumption is made that forced outages of generating equipment are random events, hence independent of each other, then these outages are governed by the same laws of chance as the tossing of coins, the rolling of dice and the spinning of a roulette wheel. This is not an unreasonable assumption in a modern power system as practically all outages are single individual occurrences. Probability theory is not specific in that predictions can be made of actual outage times and the order of occurrence. Its object is to foresee or predict the average performance of the condition investigated. Its application to the problem of generating capacity requirements will only provide a prediction of the average outage performance of a group of units over a long period of time.

FORCED OUTAGE RATE

The probability of having a unit available or unavailable at any time is the basic quantity upon which the

application of probability to the problem of generating capacity requirements is based. This information is obtained from previous experience with existing units. Careful consideration must be given to future units which may differ considerably from those existing, in design and method of operation.

The inservice time component, previously designated as "I" is a relatively simple statistic to obtain and requires no further discussion. The forced outage component "F" is not as obvious and can be defined in many ways. An outage to be classed as forced is one which is caused by a failure of the prime mover, alternator or any of their ancillary equipment or pertinent structures. A relatively simple definition of a forced outage is that such an outage must satisfy one of the following conditions.²

1. It is not necessary to take the unit out of service immediately but the eventual outage cannot be delayed until a normally scheduled maintenance period.
2. It is necessary to take the unit out of service immediately during the heavy load hours of a weekday.
3. It is necessary to take the unit out of service immediately during off peak night hours, a weekend, or other light load periods whether or not the outage can be concluded and the unit restored to service before needed to carry the load.

The duration of the forced outage extends from the time the equipment is taken out of service to the time it is released again for operation. This time period can vary

considerably for similar outage causes due to varying degrees of urgency applied to the restoration of service. A minor modification which can be applied is the determination of a minimum outage duration produced by overtime and accelerated work schedules.

Based upon the performance records of a single unit over a long period of time the forced outage time "F" and the inservice time "I" can be obtained, from which:

$$\text{Forced Outage Rate } p = \frac{F}{F + I}$$

In a generating plant which has several identical units, individual outage and inservice times can be combined to give a single forced outage rate representative of the identical units. In a three identical unit plant the forced outage rate is determined by:

$$p = \frac{F_1 + F_2 + F_3}{F_1 + F_2 + F_3 + I_1 + I_2 + I_3}$$

where:

F_1, F_2, F_3 are the individual unit forced outage times

I_1, I_2, I_3 are the individual unit inservice times.

The availability rate "q" is then obtained by:

$$q = 1 - p = \frac{I_1 + I_2 + I_3}{F_1 + F_2 + F_3 + I_1 + I_2 + I_3}$$

By accumulating the forced outage and inservice times and computing successive cumulative forced outage rates and yearly forced outage rates any indication towards or away

from a stable forced outage rate can be seen.³ This can be shown graphically for a single unit or for a group of identical units by plotting the cumulative and yearly forced outage rates. A typical plot is shown in Figure 1.




Figure 1. Typical Plot of Cumulative and Individual Forced Outage Rate.

When the cumulative forced outage rate reaches a stable value this can be looked upon as the probability of outage existing during a future time period. If aging effects are apparent, existing rates should be corrected for future application wherever possible. If the accumulated data represents a long time period this effect may be evident by graphical analysis or detected by more formal statistical methods. If the forced outage rate is representative of a

group of units the investigation can be extended to examine the homogeneity of the group.

Units which possess unique design features and/or units which are possibly new to the system should be examined individually, unless their size with respect to existing units makes their effect insignificant. The forced outage rates of the largest units in the system are of major importance as these units are the most significant in any reserve generating capacity study.

It can easily be seen that in a system having a large number of identical units a stable forced outage rate will probably be achieved quite quickly. In a large system of "n" units, future operation would expect to have a number equal to "n.p" out of service on a continuous basis for as one unit goes into service another goes out on forced outage. A system which has a relatively small number of identical units would require a long time period to arrive at a stable forced outage rate.

GENERATING PLANT RELIABILITY

Probability techniques can be applied to individual generator unit or individual generating station reliability quite simply and should always be used to assess plant design criteria from the reliability viewpoint. A practical example of this would be an evaluation of the increase in station reliability by installing a header system in a thermal

generating station. Assuming a two generator unit station, a header system would allow either turbine to receive steam from either boiler. A comparison of the difference in reliability with and without the header system would proceed as follows.

Individual Unit Case. Assume each unit is entirely separate and composed of a turbine-generator and boiler having forced outage rates " p_g " and " p_b " respectively. Availability rates are then:

$$q_g = 1 - p_g$$

$$q_b = 1 - p_b$$

The loss of either boiler or generator would make the unit inoperable. The unit forced outage rate is given by:

$$p_u = p_g + p_b - p_g p_b$$

where the product of " p_g " and " p_b " represents the probability of both boiler and turbine-generator being out of service simultaneously.

The same result can be arrived at by a slightly different approach. The inservice probability " q_u " of the two units is the product of " q_b " and " q_g " from which the forced outage probability is given by:

$$\begin{aligned} p_u &= 1 - q_u \\ &= 1 - q_b \cdot q_g \\ &= 1 - (1 - p_b)(1 - p_g) \\ &= p_b + p_g - p_b p_g \end{aligned}$$

This can easily be extended to any number of series elements by following the same basic method.

$$\begin{aligned}
 q_t &= \text{Total series availability rate} \\
 p_t &= \text{Total series forced outage rate} \\
 q_a, q_b, q_c, q_d &= \text{Individual availability rates} \\
 \therefore q_t &= q_a \cdot q_b \cdot q_c \cdot q_d \\
 \therefore p_t &= 1 - (q_a \cdot q_b \cdot q_c \cdot q_d)
 \end{aligned}$$

Having obtained the total individual unit forced outage rates the generating station outage rates can be obtained. Assuming independence of forced outages the outage probabilities of parallel combinations of identical units are given by the Binomial Expansion.

The outage probabilities of parallel combinations of "n" dissimilar units having outage rates p_1, p_2, \dots, p_n are obtained as follows:

$$(p_1 + q_1)(p_2 + q_2) \dots (p_n + q_n) = 1.0$$

If the "n" units are identical then this reduces to:

$$(p + q)^n = 1.0$$

In the two individual unit plant previously considered, employing the Binomial Expansion would give:


<u>No. of Units on Outage</u>	<u>Probability of Outage</u>
0	q_u^2
1	$2 p_u q_u$
2	p_u^2

The same results can be obtained intuitively by saying that the probability of having both units available is the product of the individual availability probabilities. The probability of having only one unit out of service is twice the product of the probability of having one available and the probability of having the other unavailable, whilst the probability of having two units out of service is the product of the two outage probabilities. For large numbers of identical units application of the Binomial Expansion proves to be much simpler.

The previous table can be modified by using the individual boiler and turbine-generator forced outage rates.

<u>No. of Units on Outage</u>	<u>Probability of Outage</u>
0	$q_b^2 \cdot q_g^2$
1	$2 q_b q_g (p_b + p_g - p_b p_g)$
2	$(p_b + p_g - p_b p_g)^2$

Two Unit Generating Station with Header System.



p_b = Boiler forced outage rate

p_g = Turbine-generator forced outage rate

The parallel outage combination of either boilers or turbine-generator are:

<u>No. of Components on Outage</u>	<u>Probability of Boiler Outage</u>	<u>Probability of Turbine Outage</u>
0	q_b^2	q_g^2
1	$2 p_b q_b$	$2 p_g q_g$
2	p_b^2	p_g^2

Combining the boilers and turbine-generators:

<u>No. of Units on Outage</u>	<u>Probability of Outage</u>
0	$q_b^2 \cdot q_g^2$
1	$2 q_b q_g (p_g q_b + 2 p_g p_b + p_b q_g)$
2	$p_b p_g (p_b p_g + 2 q_b p_g + 2 q_g p_b) + p_b^2 q_g^2 + p_g^2 q_b^2$

Typical forced outage rates for a thermal electric generating station are

$$p_g = p_b = 0.01$$

These are average figures but they serve to illustrate the difference in reliability between the two plants. Using these forced outage rates:

<u>No. of Units on Outage</u>	<u>Probability of Outage. Unit Header System</u>	<u>Probability of Outage. Individual Unit System</u>
0	0.96059601	0.96059601
1	0.03920400	0.03900798
2	0.00019999	0.00039601
	<u>1.00000000</u>	<u>1.00000000</u>

The increase in probability of outage of the individual unit system over that of the unit header system does not appear to be very great in the preceding table. A true evaluation of this difference requires the attendant outage probabilities to be combined with the remainder of the system generating facilities and the system load characteristics. If the generators were large compared to other units in the system this difference in reliability could be appreciable. The differences in unit outage rates for the two systems would be further increased if the number of units in the generating station were increased.

Due to the increased costs associated with header systems the present practice appears to be towards the use of individual units in most large thermal electric stations. The difference in system reliability can, however, be computed by application of probability techniques and cost comparisons can be made on an analytical basis.

This form of analysis can be used to evaluate the decrease in reliability when one large transformer is used for two generating units as opposed to each generating unit having a transformer.

An identical situation to the two unit thermal plant previously elaborated on is the case of two parallel transmission lines with an intermediate switching station. The switching station plays the same role as the boiler headers in the thermal electric plant. In the case of transmission

lines, however, the forced outage rates are not quite as simple to determine as those for generating facilities. A considerable amount of statistical data on lines over similar terrain with basically identical design is required to arrive at a stable forced outage rate.

In all cases in which probability techniques are applied the forced outage rate "p" is the basic quantity on which the entire prediction of future performance depends. It is therefore essential that the forced outage rate "p" be stable and corrected for aging or other causes.

The effect of an adequate preventative maintenance program is reflected in the forced outage rates of generating facilities and though figures are extremely difficult to obtain, it should be possible to evaluate increased maintenance costs with attendant increased station and hence increased system reliability.

OUTAGE PROBABILITY VALUES FOR NON-IDENTICAL UNITS

For identical units, which have equal generating capacities and forced outages rates, the probabilities of having various combinations of units available or unavailable is relatively simple to compute using the Binomial Expansion. Tables are available for this purpose.⁴

For units which are not identical, the Binomial Expansion cannot be used. The method of approach in this case is to commence with zero outage and investigate each possible outage of a combination of units and compute the

probability.

A general case for a three unit system would be as follows:

Assume units 1, 2 and 3 have outage probabilities of P_1 , P_2 , P_3 respectively.

Probability of units 1, 2 & 3 in service = $q_1 \cdot q_2 \cdot q_3$

Probability of units 1 & 2 in service & 3 out = $q_1 q_2 p_3$

Probability of units 1 & 3 in service & 2 out = $q_1 q_3 p_2$

Probability of units 2 & 3 in service & 1 out = $q_2 q_3 p_1$

Probability of units 1 & 2 out of service & 3 in = $p_1 p_2 q_3$

Probability of units 1 & 3 out of service & 2 in = $p_1 p_3 q_2$

Probability of units 2 & 3 out of service & 1 in = $p_2 p_3 q_1$

Probability of units 1, 2 & 3 out of service = $p_1 p_2 p_3$

Total probability is:

$$q_1 q_2 q_3 + (q_1 q_2 p_3 + q_1 q_3 p_2 + q_2 q_3 p_1) + (p_1 p_2 q_3 + p_1 p_3 q_2 + p_2 p_3 q_1) + p_1 p_2 p_3 = 1.0$$

For three identical units this would be:

$$q^3 + 3 q^2 p + 3 q p^2 + p^3 = 1.0$$

In combining units with different capacities the quantity of capacity on outage rather than the number of units on outage is required.

Assume a three 10 MW generator plant with identical

units is to be combined with a plant having a single 20 MW unit.

For the 3 unit plant where "p" and "q" are the outage and availability rates respectively:

<u>Capacity Out of Service</u>	<u>Probability of Outage</u>
0	q^3
10	$3 q^2 p$
20	$3 p^2 q$
30	p^3

For the single unit where "x" and "y" are the outages and availability rates respectively:

<u>Capacity Out of Service</u>	<u>Probability of Outage</u>
0	y
20	x

Combining these to give a 50 MW system:

<u>Capacity Out of Service</u>	<u>Probability of Outage</u>
0	$q^3 y$
10	$3 q^2 p y$
20	$q^3 x + 3 q p^2 y$
30	$y p^3 + 3 q^2 p x$
40	$3 q p^2 x$
50	$p^3 x$

It can clearly be seen that this can get quite complicated if large numbers of units with different capacities are to be

combined. A simpler approach and one which is more suited to digital computer application is to determine the cumulative probability of an outage equal to or exceeding a certain capacity. For the same 50 MW system previously considered this would be as follows.

For the three identical 10 MW units.

<u>Capacity Out of Service</u>	<u>Probability of Capacity Outage Equal to or Exceeding Amount Shown</u>
0	$q^3 + 3 q^2 p + 3 q p^2 + p^3 = 1.0$
10	$3 q^2 p + 3 q p^2 + p^3$
20	$3 q p^2 + p^3$
30	p^3

This is combined in two stages with the 20 MW unit. The first stage requires the probability of availability "y" of the 20 MW unit.

<u>Capacity Out of Service</u>	<u>Probability of Capacity Outage Equal to or Exceeding Amount Shown</u>
0	$q^3 y + 3 q^2 p y + 3 q p^2 y + p^3 y$
10	$3 q^2 p y + 3 q p^2 y + p^3 y$
20	$3 q p^2 y + p^3 y$
30	$p^3 y$
40	0
50	0

The second stage uses the probability of outage "x" of the 20 MW unit.

<u>Capacity Out of Service</u>	<u>Probability of Capacity Outage Equal to or Exceeding Amount Shown</u>
0 + 20 = 20	$q^3x + 3 q^2 p x + 3 q p^2 x + p^3 x$
10 + 20 = 30	$3 q^2 p x + 3 q p^2 x + p^3 x$
20 + 20 = 40	$3 q p^2 x + p^3 x$
30 + 20 = 50	$p^3 x$

Combining the two previous tables by adding the outage probabilities of corresponding amounts of capacity.

<u>Capacity Out of Service</u>	<u>Probability of Capacity Outage Equal to or Exceeding Amount Shown</u>
0	$q^3y + 3q^2py + 3qp^2y + p^3y + q^3x + 3q^2px + 3qp^2x + p^3x = 1.0$
10	$3q^2py + 3qp^2y + p^3y + q^3x + 3q^2px + 3qp^2x + p^3x$
20	$3qp^2y + p^3y + q^3x + 3q^2px + 3qp^2x + p^3x$
30	$p^3y + 3q^2px + 3qp^2x + p^3x$
40	$3qp^2x + p^3x$
50	p^3x

The individual outage probabilities for the various capacity levels can be found by subtracting the cumulative probability value from the value above it in the previous table. This procedure may look more complicated but it is one which follows a regular sequence and reduces the possibility of error.

The outage probability values associated with the installed or planned generating capacity must now be combined with the known or forecast load characteristics of the system

in order to determine the level of system reliability associated with a known or predicted system load level.

CHAPTER III

LOAD FORECASTING

GENERAL CONSIDERATIONS

There are numerous types of load forecasts made in a modern power system. Basically, the two components required in most forecasts are a knowledge of the peak load and the total energy requirements in a future time period. This time period may be a day, week, month, year or several years for system operating personnel who are concerned with economic operation, hydraulic scheduling, maintenance requirements and other system problems. For system planning personnel, load forecasts are usually on a yearly basis and are made for many years in the future. Long range forecasting is quite a controversial subject and many people claim that forecasting beyond a relatively short time period such as five to seven years is not practical. The comparison of alternate generating facilities using present worth techniques, however, requires load forecasts to be made for future time periods considerably in excess of seven years. The standard approach to this problem appears to be the development of trend lines with attendant confidence limits making possible upper and lower load boundaries for the future periods considered. Absolute reliance upon trend line techniques can, however, result in extremely inaccurate predictions of future

load levels and these predictions should be recognized as merely informed guesses of future loads. A concise description of the application of statistical methods to load forecasting problems is given by M. Z. Tarnawecky in his M.Sc. thesis presented to the University of Manitoba in 1960.⁵

The approach proposed here is that detailed load forecasting should be confined to a future time period of seven years. Trend lines are then determined by using corresponding loads for the previous seven years. Each year new trend lines are established using the values from the previous seven years. This information coupled with any further known data on known or expected system changes should provide forecasts which are reasonably accurate. The words, reasonably accurate, imply that system load levels will not create any contingency that cannot be handled by adequate generating capacity planning. Nearly all generating facilities can be planned, designed and constructed in five to seven years.

Limiting the time period of record to seven years will allow fluctuation in load due to economic cycling to be smoothed out and yet allow any effects of changing social and technical conditions in the later years to influence the trend line. For extremely advanced system planning, trend lines can be used, but upper and lower boundaries given by tight confidence limits diverge quite widely. Extremely advanced planning of system generating facilities can be co-ordinated with attainment of various system load levels

coupled with the probable year or years of expectancy. This approach can also be used for advanced transmission planning. Detailed forecasting need only cover two or three years in this case as the time required to design and construct reasonably large transmission facilities is considerably shorter than that required for generation sources of similar capacity.

DETAILED LOAD FORECASTING

In preparing a detailed load forecast it should be realized that in nearly all cases the values used and forecast for energy and peak load requirements are the generated values. These then differ from the actual load values by a transmission loss component. This is extremely difficult to evaluate in the case of energy generated over a particular time period but can be determined quite simply for peak load values. This transmission loss component can vary quite remarkably with the generating schedule used to meet the peak. Any major transmission or generation outage at the time of the peak can cause the peak to be considerably higher than it may have been with all facilities available. This factor should be recognized when using peak values in trend line forecasting.

System load and energy requirements vary considerably with the weather. A mild winter in a location such as Manitoba can result in energy requirements considerably below

forecast values. The system peak load in Manitoba usually occurs at a time when the wind chill temperature is lower than 50°F below zero.

Correction components for weather and transmission losses could be subtracted from actual peak and energy values and modified figures used in detailed load forecasting. These variables can then be re-assigned to the forecast load levels based upon information either statistically evaluated such as weather data or planned such as knowledge of proposed transmission facilities.

With a detailed forecast period of approximately seven years any sound forecasting approach tempered with practical application should result in forecast values which do not differ appreciably from the actual and certainly not in sufficient error to cause insufficient installed generating facilities.

LOAD CHARACTERISTICS REQUIRED IN EVALUATING RELIABILITY

A knowledge of two system load characteristics is required in the evaluation of system reliability by probability techniques. The first characteristic is known as a "Load Duration Curve", the second as a "Daily Peak Load Variation Curve".

Load Duration Curve. This characteristic is defined as "a curve showing the total time within a specified period during which the load equalled or exceeded the power value

shown".⁶ This is a form of cumulative frequency distribution curve in which the area under the curve represents the total load energy for the time period considered.




Figure 2. Typical Load Duration Curve.

These curves can be drawn for any time period, though they are usually created on a monthly and yearly basis. If the ordinate values are normalized by expressing each value as a percentage of the peak value, successive curves for the same time period can be compared. Future curves can then be forecast using a normalized curve and an energy value obtained by trend line techniques. It is interesting to note that in the Combined Southern Manitoba System, normalized Load Duration Curves for successive years are quite similar and can be used for predictions of non-hydraulic energy requirements based on forecast river flow conditions.

Daily Peak Load Variation Curve. This curve is again a form of cumulative frequency distribution curve and can be plotted for monthly, yearly or other required time periods. The ordinate values are the daily peak load values with the abscissa indicating the number of days that the peak load exceeded the indicated amount.




Figure 3. Typical Daily Peak Load Variation Curve.

This curve can be normalized in a similar manner to the Load Duration Curve. Although it has the same form as the Load Duration Curve, the area under the curve has no physical significance as the ordinates are the single peak load value occurring during the day.

UNCERTAINTIES IN LOAD FORECASTING

Usually departures in actual loads from forecast values are known as load forecasting errors. This is generally an erroneous conclusion as there exists considerable uncertainty in forecasting future system load levels which should not be confused with errors in computation. Attempts have been made in several papers to attach a probability value to the possible deviation in actual load from the forecast value.^{1,8} In order to do this the forecast value is assumed to have an equal chance of being exceeded and of not being reached.




Figure 4. Typical Probable Load Forecast Accuracy Curve.

The inclusion of a probability of load forecast deviation in reserve generating capacity studies tends to produce results which indicate a larger installed reserve is required to serve a future uncertain peak load than would be required to serve the same nominal peak. The

increased effort required to incorporate this concept is considerable and if knowingly omitted will not affect the value of the results. It is often used, however, in detailed simulation studies which have several random variables as it allows the forecast load values to be considered as known quantities.

COMMENTS

It is not intended to elaborate further in this thesis upon the techniques used in load forecasting. It should be realized, however, that reasonable forecasts can be produced without requiring extremely detailed studies and that attempts to improve upon these usually involve taking into account factors which require considerable effort to evaluate. The attempts at increased accuracy must be tempered with practical considerations as minor refinements can be completely overshadowed by economic or social changes occurring within the forecast period.

CHAPTER IV

EVALUATION OF GENERATING CAPACITY RELIABILITY

AVAILABLE METHODS

Having obtained the probabilities of having various combinations of generating capacity unavailable, the remaining problem is to combine these probabilities with the system load. This then gives an indication of the reliability of the particular system or a measure of its ability to meet its load requirements.

There are three established methods available for achieving this correlation between the probability of having a certain amount of generation unavailable and the system load level.⁸ These methods are known as follows.

1. Loss of Load Probability
2. Loss of Energy Probability
3. Interval between Outages

LOSS OF LOAD PROBABILITY

The results of this method are given in terms of the probable number of days per year that the system load may be expected to exceed the available generating capacity. This risk is also sometimes expressed as number of years per day which is merely the reciprocal of the number of days per year. Expressing the risk as the number of days per year is a figure which has the same significance as saying the

probability of throwing a two on any throw of two dice is $1/36$ or 0.026 which is 2.6% . Days per year is a similar fraction, as 1 day per year is $1/365$ or $1/x$ where "x" may represent the number of weekdays in a year. Several authors have considered the weekends as time periods in which a loss of generating capacity would not produce a curtailment in system loads. The result of this method is therefore a figure of probability of the existence of a specified condition and when considered in this light is an extremely useful result.

To obtain this probability figure, the probability of capacity outage is combined with the "Daily Peak Load Variation Curve".

Prior to combining the outage probabilities and the load characteristic it must be realised that there exists a difference between the terms "outage" and "loss of load". "Outage" indicates a loss of generation which may or may not result in a loss of load depending upon the amount of available generating capacity and the system load level. A loss of load will occur only when the capability of the generating capacity remaining in service is exceeded by the system load level.

A typical system may have the following relationship.




Figure 5. Relationship Between Peak Load and Installed Capacity in a Typical System.

A particular capacity outage will contribute to the system loss of load probability by an amount equal to the product of the probability of existence of the particular outage and the number of days per year that loss of load would occur if such a capacity outage were to exist. It can clearly be seen in the above figure that any capacity outage less than the quantity "R" would not contribute to the system probability of loss of load. Outages of capacity in excess of "R" would result in varying numbers of days during which loss of load could occur. This can be expressed mathematically in a very simple manner.

- If: O_k = magnitude of the capacity outage
 P_k = probability of an outage of capacity equal to O_k
 t_k = number of days per year that an outage of magnitude O_k would cause a loss of load

the contribution to the system loss of load probability made by capacity outage O_k is $P_k t_k$ days per year.

The total system loss of load probability is therefore

$$\sum_{k=1}^n P_k t_k \text{ days per year}$$

where "n" indicates the "nth" entry in the probability table, which is the largest amount of capacity outage that can occur.

The "Daily Peak Load Variation Curve" can be obtained on a yearly, monthly or even weekly basis. The simplest application is the use of the curve on a yearly basis. If no generator maintenance were done then this approach would be correct as the number of units available to meet the load requirements would be constant throughout the year. This excludes those on forced outage of course and the probabilities of this occurrence are given in one table applicable for the year.

An allowance for the withdrawal of units from service can be made by determining a monthly component of the system loss of load probability. This would require a different table of capacity outage probabilities for each month of the

year depending upon available generating capacity.

Applying the same technique as for the yearly system loss of load probability, a monthly figure is obtained.

$$\text{i.e. } \sum_1^n P_k t_k \text{ days per month}$$

The yearly figure is then the sum of the monthly figures. In the case of a system in which the summer load levels are considerably below those of the winter and all scheduled maintenance is performed during these summer months the system loss of load probability contribution due to these light load periods may be negligible. In this case the yearly "Daily Peak Load Variation Curve" can be used with negligible error. If, however, the maintenance requirements of a system are scheduled at times of reasonably high system load, it is possible to have a lower system reliability or higher probability of loss of load at this load level than at the system peak period when all generating capacity is available. This approach can be used to evaluate the restrictions to place upon a maintenance program due to its effect on system reliability.

Due to the inherent uncertainties in load forecasting it is impossible to state the load level which will exist at a particular time in the future. If the probable deviations from the system forecast load level can be evaluated then these deviations can be included. This complicates the required computations to a considerable extent and it is

doubtful for most studies if the resulting quantities are worth the increase in effort required.

Omitting the uncertainties in load forecasting from the computations provides a relatively simple means of obtaining a graph giving the risk of loss of load or the system loss of load probability for different load levels.




Figure 6. Typical Curve Relating Risk of Loss of Load and System Peak Load.

To this graph, maximum and minimum forecast load levels can be applied for future time periods and the risk immediately seen. This is considerably simpler and generally of more value than applying an adjustment to the compensating procedure to account for uncertainties in load forecasting.

This method as stated previously expresses system reliability as a probability of the existence of a specified condition and nothing more. Each occurrence of daily peak

load in excess of available capacity is given equal weight regardless of the amount of deficiency in capacity.

LOSS OF ENERGY PROBABILITY

The results of this method are given in terms of the probable ratio of load energy curtailed due to deficiencies in the generating capacity available, to the total load energy required to serve the requirements of the system. For a given load duration curve this ratio is independent of the time period considered which is usually a month or a year. The ratio is generally an extremely small figure less than one and the usual means of expressing this energy index of reliability is to subtract this quantity from unity and thus obtain the probable ratio of load energy that will be supplied to the total load energy required by the system. This is known as the "Energy Index of Reliability".

The probabilities of having varying amounts of capacity unavailable are combined with the system load by means of the Load Duration Curve.

Any outage of generating capacity exceeding the reserve will result in a curtailment of system load energy.

O_k = magnitude of the Capacity Outage

P_k = probability of a Capacity Outage equal to O_k

A_k = energy curtailed by a Capacity Outage equal to O_k

This energy curtailment is given by the shaded area in figure 7.




Figure 7. Typical Curve of Energy Curtailment Due to Generating Capacity Deficiency.

The probable energy curtailed is then $A_k P_k$. The sum of these products is the total probable energy curtailment "E" where

$$E = \sum A_k P_k$$

This can then be normalized by utilizing the total energy under the Load Duration Curve designated as "A"

$$E_{p.u.} = \frac{\sum A_k P_k}{A}$$

The figure "E" represents the ratio of the probable load energy curtailed due to deficiencies in available gene-

rating capacity to the total load energy required to serve the system demand. The Energy Index of Reliability EIR is then

$$\text{EIR} = 1 - E_{p.u.}$$

As in the previous method, "Loss of Load Probability", the available generating capacity is not constant over a one year period due to maintenance requirements. The probable energy curtailed can then be determined on a monthly basis, using monthly load duration curves and capacity outage probabilities for the available generation during the month. The sum of these monthly values would represent the probable yearly energy curtailed due to deficiencies in available generating capacity. The ratio of this value to the yearly system energy requirement is then the per unit value of "E".

The uncertainties of load forecasting can be taken into account in a similar manner as for the previous method. The Energy Index of Reliability can be plotted against peak load level as shown in figure 8.




Figure 8. Typical Curve Relating Index of Reliability and System Peak Load.

The uncertainties of load forecasting can be included in both loss of load and loss of energy approaches and a curve similar to the one preceding produced.

INTERVAL BETWEEN OUTAGES

This method gauges the reliability of a system in regard to the generating capacity in terms of average intervals between outages and the corresponding average outage duration. The "interval" and "duration" are probability statistics in the same terms as the results of the Loss of Load approach, i.e. in days per year. The average duration of outage divided by the average interval between the outages is the probability of finding the specified outage condition in existence at any particular time. An example of this is the probability of an outage having an average duration of four days occurring at average intervals of four years. This corresponds to the probability that the same outage would occur at the rate of one day per year when considered in the same manner as the "Loss of Load" approach. In the "Interval Between Outages" approach the parameters "interval" and "duration" are related to the outage capacity equal to or greater than some given amount which may be more or less than the difference between the installed system capacity and the forecast system peak load.

"The concept of duration and interval of a given out-

age condition adds a physical significance to this approach which is lacking in the other two methods."⁸ From the view of flexibility in approach and use of load conditions both previous methods are more suitable than the Interval between Outages approach. In view of this, this technique will not be discussed here further.

The application of each of these methods to a system will not of course produce identical answers when applied to the same problem as each method places its emphasis on a different system characteristic. That the applications of any of these techniques is preferable to no application at all was stated in a recent AIEE Committee Report.⁸ It states that "No one answer is right and no one answer is wrong; and any of these methods should lead to system planning that is better than can be expected where decisions are made arbitrary or by rule of thumb".

INTERCONNECTION EFFECTS

Basic rule of thumb techniques when applied to the determinations of reserve capacity requirements have been in the form of percentage reserves, equivalence to largest unit in the system and equivalence to largest unit plus a percentage of the system load. A common figure used by management and unfortunately by engineering personnel as a standard criterion of adequate reserve capacity requirements is a reserve margin of 12 percent. This figure implies that

the load should not exceed 89.3% of the installed capacity prior to the installation of additional capacity. That this criterion has been adequate in the past is probably evident by the fact that adherence to it has resulted in no load curtailment due to inadequate generating capacity margins. The use of a percentage reserve margin for discussion and approximation is advantageous in that it is easily understood and applied. That this percentage reserve margin should be inflexible, especially in view of the rapidly changing technology associated with generation patterns and system interconnections is definitely not desirable. The percentage reserve margin should be computed by probability techniques and be merely a simplified yardstick for ready application. A desirable Energy Index of Reliability or Loss of Load Probability should be determined and future installations evaluated according to these criteria.

The percentage reserve method and other rule of thumb techniques are even more inadequate in evaluating the advantages of system interconnections. The problem encountered in attempting to allocate benefits, savings and costs from partial integrations of system generating facilities can only be approached by probability techniques.

$$\frac{\text{Installed Capacity} - \text{Peak Load}}{\text{Peak Load}} \times 100 = 12\%$$

It is a recognized fact that the interconnection of two or more generating systems always reduces the amount of capacity required to meet the respective load levels as compared to that amount which would be required without the interconnection. The amount of such a reduction may be large or small depending upon the inter-relation of the various characteristics of the individual systems and the level of reliability desired. The installation of the transmission facilities that are required in such an interconnection may or may not be justified. This fact can be determined only by a proper economic comparison of the alternate installations required if the interconnection were not made.

In determining the increase in load carrying capability of a group of systems upon integration, as opposed to the sum of the load carrying capabilities of the individual systems, several factors must be considered. For example, will the resulting system function as a one company system in which each fully shares the difficulties of the group or will any company assist another only as far as it is able without sharing in the difficulties? These conditions must be known in order to arrive at a true comparison of economic installations.

In applying both the "Energy Index of Reliability" and "Loss of Load Probability" approaches to this problem the diversity of loads in the individual systems can be taken into account and "Daily Peak Load Curves" and "Load Duration Curves" obtained for the combined systems. For

preliminary work, however, the load characteristics can be determined without complete load integration and at a considerable reduction of the work involved. The approach is then relatively simple. The individual systems are evaluated, followed by the integrated system and the differences in reliability levels compared.

No attempt will be made here to discuss the possible basis upon which allocation of resultant capacity benefits can or should be made. One concept which appears to be quite reasonable is known as "the mutual benefits method of allocation" and is based upon benefits mutually contributed by the systems concerned.⁹

GENERAL COMMENTS

The application of any one of the three reliability evaluation methods previously discussed is definitely preferable to continued application of rule of thumb techniques to the timing of generation additions or establishing reserve capacity policies. Consistent use of any of the methods would provide basically the same schedule for capacity additions.

Unfortunately numerical analysis alone cannot establish just what is a satisfactory level of system generating capacity reliability or establish a fixed value for the index of system reliability. To determine these factors requires a measure of informed judgement. Following this,

however, application of probability techniques will assist in maintaining this reliability level at minimum cost under widely changing system conditions.

CHAPTER V

A CONCEPT OF TRANSMISSION RELIABILITY

GENERAL CONSIDERATIONS

The general acceptance of probability techniques to power system problems has been quite slow. Only in the field of generating capacity requirements has their application been considerable and unfortunately this is far from universal. In other fields, progress has been slow or entirely non-existent, an exception being the subject of secondary networks where several interesting papers have been published.^{7, 47}

The following concept of transmission reliability stems from the basic reliability principles used in generation planning and to the author's knowledge has not been proposed by anyone else.

QUALITY OF SERVICE

In order to put a figure of reliability on a particular terminal or sub-transmission station there must exist a definition of just what constitutes a breach of continuity at that station. If due to line outages a low voltage condition exists at the station this is not an actual breach of continuity even though the voltage level may be considerably below a desired minimum.

It is proposed, that voltage limits be defined at

the substations throughout the system and that any departures outside these limits constitute a breach of continuity. This may seem somewhat harsh in that customers can be served at reduced voltage without creating undue hardship. This is true, but as in the case of generating facilities previously elaborated, low voltage operation is not a satisfactory design criterion but a last resort.

Transients caused by switching, loss of load or other system disturbances which cause departures from the acceptable voltage levels should not be classed as disruptions in continuity.

A clear difference must exist between quality of service and continuity of service and any departure from the requirements for quality of service constitutes a breach of continuity of that service.

DESIGN CRITERIA

In constructing an additional infeed to an area the reason often given is increased transmission reliability. This in most cases is not the true reason. It is obvious that the addition of a transmission line to supply a station will increase the reliability of that station. Any duplication of facilities will do this to some extent. To build a line on the basis of reliability alone implies extremely high outage rates for the remaining lines supplying the station.

The criterion used should be as follows.

(a) If with all lines in service, voltage levels fall outside the defined limits then new transmission facilities are required to meet quality of service standards, this also applies to reactive or synchronous compensation facilities at that station.

(b) With the various possible combinations of lines out of service, establish an index of reliability for the station. If this is below the design figure then additional transmission is required to meet reliability standards.

A station could still meet quality of service standards for several years of load growth but not meet reliability standards for the present if a minimum number of transmission lines were installed having high outage rates.

ESTABLISHING AN INDEX OF RELIABILITY

This requires the creation of a Load Duration Curve for the particular station and a knowledge of the load level at that station for which any outage or combination of outages of transmission facilities would cause the load voltage to lie outside the specified zone. Determination of these load levels could be done on an A.C. Network Calculator or digital computer by performing a regular load flow study of an area or the entire system at various load levels and for various line outages. The problem of backfeeding along lower voltage networks can be eliminated if it is assumed that load points having adequate voltages would not allow their voltages to drop to unacceptable levels in an attempt to maintain an unacceptable level at the station under study.

This assumes that loads are fed radially from the stations under study with extenuating circumstances in the case of stations with large low voltage transmission ties.

The forced outage rates of the transmission lines can be determined in a similar manner to the rates for generating facilities. Using these and the Load Duration Curve the probable amount of energy which might be curtailed can be determined and the index of reliability evaluated.

The forced outage rates of transmission facilities vary considerably with the time of year. The index of reliability could be at its lowest on a monthly basis during the sleet season when the load may or may not be at its highest. This would depend on the power system considered. For this condition a monthly or similar time period index of reliability would be more suitable.

COMMENTS

As most transmission lines have very low forced outage rates, lines are seldom built for reliability alone. They are built in nearly all cases to maintain the quality of service in that area for the actual load level and forecast load levels of some specified period. Addition or duplication of transmission facilities increases the station reliability but reliability is seldom the reason for addition of these facilities. The approach postulated here will allow a figure of reliability to be determined for transmission

facilities which was previously not possible.

The principle postulate is that a breach of service quality constitutes a breach of service continuity and is the basis of this concept. This idea can be modified slightly by selecting various voltage zones, such as favourable, tolerable and extreme with attendant increases in the effort required to arrive at the indexes of reliability.¹⁰

Regardless of the voltage definition used, this method provides an analytical basis for evaluating the reliability of terminal and sub-transmission stations which was not previously available.

CHAPTER VI

A THEORETICAL PROBLEM

THE PROBLEM

The system reliability levels of four hydro-electric systems are to be evaluated. Each system has the same load characteristics and total installed capacity of 200 MW. The number of units and their capacity in each system is different. To each system is added one, two and finally three 50 megawatt units. These units are added individually and with forced outage rates of both hydraulic and thermal-electric generating units. The reliability levels of each initial system with a firm capacity purchase of 25 MW is also to be considered. Two of the original systems are interconnected and the effect on system reliability considered.

THEORETICAL SYSTEMS

The basic systems considered are as follows.

TABLE I

THEORETICAL SYSTEMS

<u>System</u>	<u>No. of Units</u>	<u>Unit Capacity (MW)</u>	<u>Forced Outage Rate</u>
A	20	10	0.01
B	10	20	0.01
C	5	40	0.01
D	4	50	0.01

A forced outage rate of 0.01 is representative of a hydraulic generating unit.

To these systems are to be added 150 MW of generating capacity, either hydraulic or thermal-electric units in three stages of 50 MW per stage. A forced outage rate of 0.02 is assumed for the thermal-electric units.

TABLE II
THEORETICAL SYSTEM DATA

<u>System Number</u>	<u>Total Generating Capacity (MW)</u>	<u>Forced Outage Rates of the 50 MW Units Added</u>
1A-1	200	Original System
2A-1	250	0.01
3A-1	300	0.01
4A-1	350	0.01
2A-2	250	0.02
3A-2	300	0.02
4A-2	350	0.02
1B-1	200	Original System
2B-1	250	0.01
3B-1	300	0.01
4B-1	350	0.01
2B-2	250	0.02
3B-2	300	0.02
4B-2	350	0.02
1C-1	200	Original System
2C-1	250	0.01
3C-1	300	0.01
4C-1	350	0.01
2C-2	250	0.02
3C-2	300	0.02
4C-2	350	0.02
1D-1	200	Original System
2D-1	250	0.01
3D-1	300	0.01
4D-1	350	0.01
2D-2	250	0.02
3D-2	300	0.02
4D-2	350	0.02

System "A" and "D" are to be interconnected and to each are added three 50 MW hydraulic generating units.

TABLE III

THEORETICAL INTERCONNECTED SYSTEM DATA

<u>System Number</u>	<u>Total Generating Capacity (MW)</u>	<u>Forced Outage Rates of the 50 MW Units</u>
1AD	400	Original Systems
2AD	450	0.01
3AD	500	0.01
4AD	550	0.01
5AD	600	0.01
6AD	650	0.01
7AD	700	0.01

System "A" is expanded to an installed capacity of 700 MW by adding ten 50 MW hydraulic generating units with forced outage rates of 0.01. This is identical to having one system with the installed capacity shown in Table III.

SYSTEM LOAD CHARACTERISTICS

All of the systems studied are assumed to have identical load characteristics. Both "Load Duration Curves" and "Daily Peak Load Variation Curves" are assumed to be represented by a straight line from the 100% to the 40% load level. In both cases the time period is considered to be one year consisting of three hundred and sixty-five days.

This assumes that there are no capacity reductions due to maintenance requirements.




Figure 9. Load Duration and Daily Peak Load Variation Curve Used For Theoretical Systems.

"RULE OF THUMB" APPROACH TO ADEQUATE RELIABILITY

The criterion of adequate reliability used by many utilities is that a reserve margin of 12% be maintained. This criterion is also used in the Combined Southern Manitoba System. Based upon this, the largest load which could be supplied by each system is as follows.

TABLE IV

THEORETICAL SYSTEM PEAK LOADS BY PERCENTAGE RESERVE CRITERION

<u>System</u>	<u>Installed Generating Capacity (MW)</u>	<u>Peak Load (MW)</u>
A,B,C,D	200	178.5
A,B,C,D	250	223
A,B,C,D	300	268
A,B,C,D	350	312

"PROBABILITY METHODS" APPROACH TO ADEQUATE RELIABILITY

For each of the 28 systems shown in Table II on page 54 the probability of Loss of Load in years per day and the Index of Reliability for various load levels are shown in Appendix A. The risk corresponding to the various load levels is plotted on semi-logarithmic paper and also shown in Appendix A. These values were obtained using two relatively simple digital computer programs on the IBM 1620 digital computer.

The relative adequacy of a 12% reserve capacity margin for each of the original systems is as follows.

TABLE V
RELIABILITY OF INDIVIDUAL THEORETICAL SYSTEMS

<u>System</u>	<u>Peak Load (MW)</u>	<u>Risk of Loss of Load (Years/Day)</u>	<u>Index of Reliability</u>
A	178.5	44	0.9999983
B	178.5	3.6	0.9999977
C	178.5	0.33	0.999242
D	178.5	0.26	0.998676

It can clearly be seen that in the systems considered as the unit size increases the system reliability correspondingly decreases. Systems C and D are not practical systems but they do serve to illustrate the inadequacy of an inflexible reserve capacity criterion such as that of a fixed percentage reserve.

EFFECT OF UNIT SIZE

If a constant risk level is selected, the effect on a system of adding units can be clearly seen. The actual increase in load carrying capability can be evaluated and the capacity penalty of a large unit determined.

Using a "Risk of Loss of Load" of 10 Years/Day the effects of adding 50 MW units to systems A, B, C, and D are as follows:

TABLE VI

ALLOWABLE PEAK LOAD VALUES UNDER
ASSIGNED RISK OF LOSS OF LOAD FOR
THE THEORETICAL SYSTEMS

<u>Generation Pattern</u>	<u>System Peak Load in MW</u>			
	<u>System A</u>	<u>System B</u>	<u>System C</u>	<u>System D</u>
O.S. (Original System)	184	168	144	138
O.S. + 50 MW Hydro	202	205	186	179
O.S. + 100 MW Hydro	250	248	232	224
O.S. + 150 MW Hydro	298	291	279	271
O.S. + 50 MW Thermal	199	194	180	170
O.S. + 100 MW Thermal	246	238	222	213
O.S. + 150 MW Thermal	284	281	268	260

The penalty attached to a large unit can be seen by expressing the increase in load carrying capability of the system as a percentage of the total capacity of the units added.

TABLE VIIPERCENTAGE OF UNITS ADDED
AVAILABLE TO THE SYSTEM

<u>Generation Pattern</u>	<u>Percent Increase</u>			
	<u>System A</u>	<u>System B</u>	<u>System C</u>	<u>System D</u>
O.S. + 50 MW Hydro	36	74	84	82
O.S. + 100 MW Hydro	66	80	88	86
O.S. + 150 MW Hydro	76	82	90	89
O.S. + 50 MW Thermal	30	52	72	64
O.S. + 100 MW Thermal	62	70	78	75
O.S. + 150 MW Thermal	67	75	83	81

Similar statistics can be obtained using the "Index of Reliability" approach.

Assuming an Index of Reliability of 0.99999

TABLE VIIIALLOWABLE PEAK LOAD VALUES UNDER
ASSIGNED INDEX OF RELIABILITY
FOR THE THEORETICAL SYSTEMS

<u>Generation Pattern</u>	<u>System Peak Load in MW</u>			
	<u>System A</u>	<u>System B</u>	<u>System C</u>	<u>System D</u>
O.S. (Original System)	183	169	131	113
O.S. + 50 MW Hydro	201	197	177	164
O.S. + 100 MW Hydro	246	242	224	214
O.S. + 150 MW Hydro	292	286	274	265
O.S. + 50 MW Thermal	196	191	173	161
O.S. + 100 MW Thermal	230	228	217	210
O.S. + 150 MW Thermal	269	268	263	258

The results of the two methods are not identical as each utilizes a different load characteristic. The "Loss of Load" approach gives equal weight to each occurrence of daily peak load in excess of available capacity, whilst the "Index of Reliability" method weights each occurrence of available capacity less than the load by the percentage of load energy that is interrupted. The results, however, are quite similar and both methods produce the same basic trends when applied to systems with large numbers of machines such as most modern power systems.

FIRM CAPACITY PURCHASES

Using the "Loss of Load" approach the purchase of 25 MW of firm capacity for the original systems is examined. A firm capacity purchase is one which has an infinitesimal probability of being unavailable. Assume a Risk of Loss of Load of 10 years/day.

TABLE IX

INCREASE IN LOAD CARRYING ABILITY
WITH A FIRM CAPACITY PURCHASE

<u>Generation Pattern</u>	<u>System Peak Load in MW</u>			
	<u>System A</u>	<u>System B</u>	<u>System C</u>	<u>System D</u>
O.S. (Original System)	184	168	144	138
O.S. + 25 MW Firm	209	196	173	174

It can be seen that a firm capacity purchase can increase the load carrying capability of the system by more

than the firm capacity purchased. This, however, is only in systems having a small number of machines of relatively large capacity. In a normal system having a relatively large number of units a firm capacity purchase increases the load carrying capacity of the system by the amount of the firm purchase.

CONTINUOUS ADDITION OF LARGE UNITS TO A SYSTEM

The addition of large units to a system creates increases in reserve capacity requirements which when expressed as a percentage reserve decrease with the addition of more large units. This is shown by adding 50 MW hydraulic units to system "A" which has twenty 10 MW hydraulic units.

TABLE X

VARIATION IN PERCENTAGE RESERVE CRITERION FOR A FIXED RISK OF LOSS OF LOAD WITH THE ADDITION OF LARGE UNITS

Criterion A - Risk of Loss of Load of
10 years/day

Criterion B - Index of Reliability of
0.99999

<u>Installed Capacity (MW)</u>	<u>Peak Load by Criter- ion A (MW)</u>	<u>Percentage Reserve for Criterion A</u>	<u>Peak Load by Criter- ion B (MW)</u>	<u>Percentage Reserve for Criterion B</u>
200	184	8.7	183	9.3
250	202	23.8	201	24.4
300	250	20.0	246	22.0
350	298	17.4	292	19.9
400	345	15.9	337	18.7
450	393	14.5	382	17.8
500	439	13.9	428	16.8
550	485	13.4	477	15.3
600	529	13.2	526	14.1
650	575	13.0	573	13.4
700	621	12.8	622	12.5

It can be seen that the percentage reserve required to maintain a constant risk changes with the addition of more large units. The percentage reserve does not, however, continue to decrease as more units are added but approaches a new figure somewhat higher than that required for the original system. The difference between the original and modified percentage values depends upon the relative capacity of the unit additions to the system and the forced outage rates of the new units.

INTERCONNECTION OF SYSTEMS

The effect on capacity requirements of interconnection between two systems can be seen by selecting a constant risk level and comparing the increase in load carrying capacity of the integrated systems to the sum of the load carrying capacities of the individual systems. Systems "A" and "D" are to be integrated and individual 50 MW hydraulic units added.

Assume a Risk of Loss of Load of 10 years/day.

TABLE XI

LOAD CARRYING ABILITY OF INDIVIDUAL AND INTERCONNECTED SYSTEMS

<u>Installed Capacity (MW)</u>	<u>System A Peak Load (MW)</u>	<u>System D Peak Load (MW)</u>
200	184	138
250	202	179
300	250	224
350	298	271

<u>Installed Capacity (MW)</u>	<u>Total Peak Load Individual Systems (MW)</u>	<u>Total Peak Load Interconnected Systems (MW)</u>
400	322	345
450	340 or 363	393
500	381	439
550	429 or 426	485
600	474	529
650	521 or 522	575
700	561	621

Interconnection between systems is also enhanced by the usual diversity which exists between system loads. Although this has not been taken into account in this case, it can be seen from the above values that the integrated system can meet a greater peak load than the sum of the individual peaks with one less 50 MW unit installed than the sum of the individual installed capacities. This in itself represents a considerable advantage to integration.

Interconnection of two or more systems by adequate transmission facilities allows larger units to be added to the pool than could be absorbed by the individual systems. This is partially due to the diversity of outages and loads. The combined load growth of the integrated system may also justify the large increase in installed capacity caused by the addition of large units. The trend to large thermal units with higher efficiencies has been accelerated in

North America by the integration of extremely large systems by high voltage transmission ties.

CONCLUSIONS

The ability of different systems to carry the same peak load magnitude cannot be measured by rule of thumb techniques such as a percentage reserve. Only by the application of probability techniques can comparative reliability levels be determined.

The two approaches used, "Loss of Load" and "Index of Reliability" do not produce exactly similar results and comparison of numerical reliability levels is meaningless. Each method utilizes a different system load characteristic. Consistent application of either method is considerably better than using rule of thumb techniques.

The penalty attached to a single large generating unit addition and the attendant increase in percentage reserve required to maintain the design risk can only be determined by probability techniques. Further addition of relatively large units will reduce the percentage reserve requirement to a stable value slightly higher than that required for the original system. The difference depends on the relative capacity and forced outage rates of the unit additions.

The selection of a risk level cannot be determined by mathematical methods. Human judgement must be used to

decide what is and what is not adequate reliability. Probability techniques do, however, provide a sound basis for the comparison of alternate schemes of expansion and the optimum time to implement these schemes once the risk level has been selected. Different risk levels will indicate different peak loads which can be served. In systems having a large number of units the penalty attached to a relatively large unit or units is constant over a wide risk zone.

The value to a system of an adequate transmission link with a second system can not be measured entirely in terms of the economic energy interchange available. Each system gains in reliability by an adequate interconnection. This gain can only be realized by probability techniques.

The systems investigated here have forced outage rates of 0.01 and 0.02, these values being representative of hydraulic and thermal generating units. When investigating the reliability of a particular system, probable variations in future forced outage rates should be studied and the consequences determined.

The load characteristics used were straight line approximations for simplicity of application. The degree of refinement justified for a particular system must be determined on its own merits.

CHAPTER VII

COMBINED SOUTHERN MANITOBA SYSTEM

GENERATING FACILITIES

The generation facilities of the Combined Southern Manitoba System are comprised of sixty generating units having generating capacities as shown in the following table.

TABLE XII

GENERATING FACILITIES IN THE
COMBINED SOUTHERN MANITOBA SYSTEM

Present Installed Capacity

<u>Generating Station</u>	<u>Generation Type</u>	<u>No. of Units</u>	<u>Machine Rating (MW) *</u>	<u>Station Total (MW)</u>
Seven Sisters	Hydraulic	6	25	150
Pine Falls	Hydraulic	6	13.5	81
McArthur Falls	Hydraulic	8	7	56
Great Falls	Hydraulic	6	22	132
Slave Falls	Hydraulic	8	8.5	68
Pointe du Bois	Hydraulic	5	3.2)	72
		3	4.0)	
		8	5.5)	
Brandon	Thermal	4	30	120
Selkirk	Thermal	2	60	120
Amy Street	Thermal	2	5)	50
		1	15)	
		1	25)	
<u>Total Installed Capacity</u>				<u>849</u>

* Available To The System

Future Installed Capacity

Grand Rapids	Hydraulic	3	110	330
--------------	-----------	---	-----	-----

ASSUMPTIONS

1. Forced Outage Rates of all hydraulic generating units is 0.008.
2. Forced Outage Rates of all thermal-electric generating units is 0.015.
3. The transmission is adequate and all generation is tied directly to the belt line which has infinitesimal probability of causing deficiencies in capacity.
4. Both "Load Duration Curves" and "Daily Peak Load Variation Curves" are represented on a yearly basis by a straight line from the 100% to 40% load points.
5. The interconnections with Saskatchewan and Ontario are neglected except in the case of the firm capacity purchase of 50 MW from Saskatchewan.
6. The flow conditions at the hydraulic generating stations are sufficiently adequate to cause no capacity or energy restrictions.

PRESENT RELIABILITY CRITERIA

The criterion presently employed by the Combined Southern Manitoba System is a fixed capacity reserve of 12%. Based on this the load carrying ability of the system with and without Grand Rapids is as follows.

TABLE XIII

MAXIMUM PEAK LOADS BY PERCENTAGE
RESERVE CRITERION FOR THE COMBINED
SOUTHERN MANITOBA SYSTEM

C.S.M.S. - Combined Southern Manitoba System

G.R. - Grand Rapids

F. S.P.C.- Firm Purchase From Saskatchewan Power Corp.

<u>System</u>	<u>Installed Capacity (MW)</u>	<u>Peak Load (MW)</u>
C.S.M.S.	849	758
C.S.M.S. - 1 Unit G.R.	959	856
C.S.M.S. - 2 Units G.R.	1069	954
C.S.M.S. - 3 Units G.R.	1179	1053
C.S.M.S. - 50 MW F. S.P.C.	899	803

RELIABILITY USING PROBABILITY TECHNIQUES

Assuming that a reserve of 12% is adequate for the Combined Southern Manitoba System the corresponding risk levels are as follows.

TABLE XIV

RISK LEVELS FOR A
CAPACITY RESERVE OF 12%

<u>Maximum Load Level (MW)</u>	<u>Risk of Loss of Load Years/Day</u>	<u>Index of Reliability</u>
758	46.0	0.9999982

Using these risk levels the load carrying ability of the system with Grand Rapids is as follows.

TABLE XV

MAXIMUM PEAK LOAD AFTER
ADDITION OF GRAND RAPIDS UNITS

Criterion A - Risk of Loss of Load

Criterion B - Index of Reliability

<u>System</u>	<u>Installed Capacity (MW)</u>	<u>Peak Load Criterion A (MW)</u>	<u>Peak Load Criterion B (MW)</u>
C.S.M.S.	849	758	758
C.S.M.S. - 1 Unit G.R.	959	832	827
C.S.M.S. - 2 Units G.R.	1069	929	923
C.S.M.S. - 3 Units G.R.	1179	1027	1020
C.S.M.S. - 50 MW F. S.P.C.	899	808	808

Using the peak load values determined at a risk of loss of load of 46.0 years/day.

TABLE XVI

VARIATION IN PERCENTAGE RESERVE
WITH ADDITION OF UNITS AT GRAND RAPIDS

<u>Installed Capacity (MW)</u>	<u>Percent Reserve Margin</u>
849	12.0
899	11.2
959	15.3
1069	15.1
1179	14.8

The increase in load carrying capacity of the system with each Grand Rapids unit is as follows.

TABLE XVIIINCREASE IN LOAD CARRYING CAPACITY
OF THE SYSTEM WITH UNITS AT GRAND RAPIDS

S.L.C.C. - System Load Carrying Capacity

<u>Addition to C.S.M.S.</u>	<u>Increase in S.L.C.C. (MW)</u>	<u>Percentage L.C.C. In- crease is of G.R. Capacity</u>
1 G.R. Unit	74	67.2
2 G.R. Units	171	77.7
3 G.R. Units	269	81.5

To maintain a 12% reserve would be an increase in system load carrying capability of 89.3% of the generating unit capacity added.

CONCLUSIONS

If the risk of generating capacity deficiencies associated with a present capacity reserve of 12% is justified for the Combined Southern Manitoba System, then this risk level can be used to determine the increase in load carrying capability of the system after the development at Grand Rapids.

Due to the large units at Grand Rapids the capacity reserve required will no longer be 12%. Based upon the assumptions used this figure will be 14.8% to maintain the desired risk level.

The addition of further units of the same capacity as those at Grand Rapids will not reduce the percentage reserve required to the present figure of 12%.

The approach used here has utilized some major assumptions as to load characteristics and forced outage rates. The refinements that can be applied to this problem are numerous and do not always justify their application. Future system load characteristics can be determined reasonably accurately and Load Duration and Daily Peak Load Curves represented for digital computation. Future studies in this field performed by Manitoba Hydro should incorporate actual and forecast load characteristics on a monthly basis thus allowing maintenance schedules to be incorporated.

Unfortunately, insufficient statistics have been accumulated for the Manitoba System to deduce a stable forced outage rate for either hydraulic or thermal generating units. In view of this, studies should be done to ascertain the effect on capacity requirements of variations in the forced outage rates of generating facilities particularly those at Grand Rapids.

The actual increase in system reliability due to the interconnections with Saskatchewan and Ontario should be evaluated. This would require a three system reliability study. Such a study even on a preliminary basis using similar assumptions to those made here would illustrate the value of adequate transmission links to system reliability.

If Manitoba is to develop its northern hydraulic resources without large export contracts, considerable generation overbuild and capital expenditures on generating

and transmission facilities are required. It may be possible to justify this development by capacity sharing with our neighboring provinces with Manitoba carrying the installed reserve for all three systems. This could be a cycling arrangement thus allowing each individual system to develop its possible major generating schemes which cannot be justified on a single system basis. This would not have to be complete system integration as each system could supply its own energy and capacity requirements under normal conditions with energy purchases made wherever economical. The application of probability techniques will provide a sound analytical basis from which the relative merits of different schemes of expansion can be judged from the reliability standpoint. These techniques should go hand in hand with economic evaluations of any proposed generating scheme.

In order to be able to take into account the load diversity existing between the three systems, individual and pool load characteristic curves are required. This can be done quite simply by having hourly and peak load values tabulated and forwarded to one of the three utilities where the information is punched on cards ready for digital computation. The pool load characteristics can also be used to evaluate spinning reliability of the interconnected systems.

The approach presented here is relatively simple and has utilized several simplifying assumptions. It is, however, an analytical basis upon which refinements can be made if

desired. These added refinements should remain as tools of the specialist but the general concepts associated with the application of probability should be understood by those concerned with generating capacity planning.

CHAPTER VIII

CONCLUSION

Conclusions have already been stated for both the theoretical systems and actual system used in this thesis and therefore are not repeated here. It should be readily apparent, however, that reserve generating requirements vary with each power system and they can only be compared by means of analytical methods involving probability.

The factors affecting capacity requirements are:

1. the load characteristics of the system
2. the number and size of generating units in the system
3. the probability of forced outage of each unit in the system
4. the assistance available from other systems through adequate interconnections
5. the risk of a capacity deficiency acceptable to the system.

These factors cannot be correctly evaluated using rule of thumb techniques such as a percentage reserve margin. The basic concepts involved in the application of probability mathematics to this problem are quite straightforward. The refinements which can be applied are numerous and can involve detailed statistical analysis, whether or not these refinements are made will depend upon the particular problem studied.

The selection of the acceptable risk of capacity deficiency can not be made by mathematical methods. Human

judgement must be used to decide what is and what is not adequate reliability. Once this has been decided, the application of mathematical techniques involving probability, provide a sound basis for economic evaluation of maintaining this criterion under widely changing system conditions.

REFERENCES

1. LIMMER, H. D., "Determination of Reserve and Inter-connection Requirements", A.I.E.E. Transactions, August, 1958, p. 544.
2. BROWN, H. U., L. A. DEAN and A. R. CAPREZ, "Forced Generation Outage Investigation", A.I.E.E. Transactions, October, 1960.
3. CALABRESE, G., "Generating Reserve Capacity Determined by the Probability Method", A.I.E.E. Transactions, 1947, Vol. 66, p. 1439.
4. A.I.E.E. COMMITTEE REPORT, "Tables of Binomial Probability Distribution to Six Decimal Places", A.I.E.E. Transactions, August, 1952, p. 597.
5. TARNAWECKY, M. Z., "The Design of An Extra-High Voltage Transmission System for the Transfer of Energy from Northern to Southern Manitoba", M.Sc. Thesis, University of Manitoba, 1960.
6. POWEL, C. A., "Principles of Electric Utility Engineering", John Wiley & Sons Inc., New York, 1956.
7. NEAGLE, N. M. and D. R. NELSON, "The Use of Probability in the Design and Operation of Secondary Network Systems", A.I.E.E. Transactions, August, 1955.
8. A.I.E.E. COMMITTEE REPORT, "Application of Probability Methods to Generating Capacity Problems", A.I.E.E. Transactions, February, 1961, p. 1165.
9. WATCHORN, C. W., "Interconnecting Generating Systems", A.I.E.E. Transactions, 1950, p. 1180.
10. EEI - NEMA PUBLICATION, "Preferred Voltage Ratings for A.C. Systems and Equipment", EEI Publication No. R-6, NEMA Publication No. 117.
11. SMITH, S. A. Jr., "Service Reliability Measured by Probabilities of Outage", Electrical World, Vol. 103, March 10, 1934, pp. 371 - 74.
12. BENNER, P. E., "The Use of Theory of Probability to Determine Spare Capacity", General Electric Review, Schenectage, N. Y., Vol. 37, No. 7, July, 1934, pp. 345 - 48.

13. LYMAN, W. J., "Calculating Probability of Generating Capacity Outages", A.I.E.E. Transactions, Vol. 66, 1947, pp. 1471 - 77.
14. SEELYE, HOWARD P., "Outage Expectancy as a Basis for Generator Reserve", A.I.E.E. Transactions, Vol. 66, 1947, pp. 1483 - 88.
15. LOANE, E. S., and C. W. WATCHORN, "Probability Methods Applied to Generator Capacity Problems of a Combined Hydro and Steam System", A.I.E.E. Transactions, Vol. 66, 1947, pp. 1645 - 54.
16. A.I.E.E. COMMITTEE REPORT, "Outage Rates of Steam Turbines and Boilers and of Hydro Units", A.I.E.E. Transactions, Vol. 68, Pt. I, 1949, pp. 450 - 57.
17. A.I.E.E. COMMITTEE REPORT, "Forced Outage Rates of High-Pressure Steam Turbines and Boilers", A.I.E.E. Transactions, Pt. III - B (Power Apparatus and Systems), Vol. 73, December, 1954, pp. 1438 - 42; also Combustion, New York, N.Y., October, 1954, pp. 57 - 61.
18. A.I.E.E. JOINT SUB-COMMITTEE REPORT, "Forced Outage Rates of High-Pressure Steam Turbines and Boilers", A.I.E.E. Transactions, Vol. 76, June, 1957, pp. 338 - 43; also Combustion, Vol. 28, February, 1957, pp. 43 - 46.
19. KIST, CARL and G. J. THOMAS, "Probability Calculations for System Generation Reserves", A.I.E.E. Transactions, Vol. 77, August, 1958, pp. 515 - 20.
20. JONES, A. PAT and A. C. MIEROW, "Use of Probability Methods in the Economic Justification of Interconnecting Facilities Between Power Systems in South Texas", A.I.E.E. Transactions, Vol. 77, 1958, pp. 520 - 30.
21. HALPERIN, HERMAN and H. A. ADLER, "Determination of Reserve Generating Capability", A.I.E.E. Transactions, Vol. 77, 1958, pp. 530 - 44.
22. MILLER, ANDREW L., "Details of Outage Probability Calculations", A.I.E.E. Transactions, Vol. 77, 1958, pp. 551 - 57.

23. PITCHER, W. J., L. K. KIRCHMAYER, A. G. MELLOR and H. O. SIMMONS, Jr., "Generator Unit Size Study for the Dayton Power and Light Company", A.I.E.E. Transactions, Vol. 77, 1958, pp. 558 - 63.
24. BRENNAN, M. K., C. D. GALLOWAY and L. K. KIRCHMAYER, "Digital Computer Aids Economic-Probabilistic Study of Generation Systems I", A.I.E.E. Transactions, Vol. 77, 1958, pp. 564 - 71.
25. GALLOWAY, C. D., and L. K. KIRCHMAYER, "Digital Computer Aids Economic-Probabilistic Study of Generation Systems II", A.I.E.E. Transactions, Vol. 77, 1958, pp. 571 - 77.
26. HICKS, K. L., "Treatment of Hydro Capability Duration Curves in Probability Calculations", A.I.E.E. Transactions, Vol. 77, 1958, pp. 577 - 80.
27. ALDER, H. A. and K. W. MILLER, "A New Approach to Probability Problems in Electrical Engineering", A.I.E.E. Transactions, Vol. 65, October, 1946, pp. 630 - 32.
28. CALABRESE, A., "Determination of Reserve Capacity by the Probability Method", A.I.E.E. Transactions, Vol. 69, Pt. II, 1950, pp. 1681 - 89.
29. WATCHORN, C. W., "Elements of System Capacity Requirements", A.I.E.E. Transactions, Vol. 70, Pt. II, 1951, pp. 1163 - 85.
30. KIRCHMAYER, L. K., and A. G. MELLOR, "New Analytical Tools Permit Integrated System Planning", Electrical World, June, 1959, pp. 52 - 54, 59, 60.
31. SEELYE, HOWARD P., "A Convenient Method for Determining Generator Reserve", A.I.E.E. Transactions, Vol. 68, Pt. II, 1949, pp. 1317 - 20.
32. KIRCHMAYER, L. K., A. G. MELLOR, J. F. O'MARA and J. R. STEVENSON, "An Investigation of the Economic Size Steam-Electric Generating Units", A.I.E.E. Transactions, Pt. III (Power Apparatus and Systems) Vol. 74, August, 1955, pp. 600 - 14; also Combustion, February, 1955, pp. 57 - 64.
33. STEINBERG, M. J. and V. M. COOK, "Evaluation of Unit Capacity Additions", A.I.E.E. Transactions, Vol. 75, April, 1956, pp. 169 - 79.

34. KIRCHMAYER, L. K., A. G. MELLOR and H. O. SIMMONS, Jr., "The Effect of Interconnections on Economic Generation Expansion Patterns", A.I.E.E. Transactions, Vol. 76, June, 1957, pp. 203 - 14.
35. CALABRESE, G., "Determination of Reserve Capacity by the Probability Method - Effect of Interconnections", A.I.E.E. Transactions, Vol. 70, Pt. I, 1951, pp. 1018 - 20, also Electrical Engineering, Vol. 72, 1953, p. 100 for correction.
36. FRY, T. C., "Probability and Its Engineering Uses" (book) D. Van Nostrand Company Inc., Princeton, N.J., 1928.
37. PHILLIPS, H. W., "Reserve Requirements for Interconnected Systems", Electrical World, May 11, 1946, p. 78; also Bulletin, Edison Electric Institute, Vol. 14, April, 1946, pp. 117 - 20; also Mechanical World, Manchester, England, Vol. 120, September 27, 1946, pp. 351 - 53.
38. RICH, ARNOLD, "A Classification of Outages of Facilities in Electric Power Systems", Combustion, Vol. 24, March, 1953, pp. 43 - 47.
39. WATCHORN, C. W., "A Simplified Basis for Applying Probability Methods to the Determination of Installed Generating Capacity Requirements", A.I.E.E. Transactions, Vol. 76, October, 1957, pp. 829 - 832.
40. HICKS, K. L., "Probability in Planning", Electric Light and Power, Chicago, Ill., July 15, 1958, pp. 43 - 46, 59.
41. BALDWIN, C. J. and C. H. HOFFMAN, "Evaluating Chance in Planning", Electric Light and Power, August 15, 1959, pp. 55 - 57, 91.
42. BALDWIN, C. J., D. P. GAVER and C. H. HOFFMAN, "Mathematical Models for Use in the Simulation of Power Generation Outages: I - Fundamental Considerations", A.I.E.E. Transactions, Vol. 78, 1959, pp. 1251 - 58.
43. BALDWIN, C. J., J. E. BILLINGS, D. P. GAVER and C. H. HOFFMAN, "Mathematical Models for Use in the Simulation of Power Generation Outages; II - Power System Forced Outage Distributions", A.I.E.E. Transactions, Vol. 78, 1959, pp. 1258 - 72.

44. REPS, D. N. and J. A. ROSE, "Strategy for Expansion of Utility Generation", A.I.E.E. Transactions, Vol. 78, (February 1960 section) pp. 1710 - 20.
45. DE SALVO, C. A., C. H. HOFFMAN and R. G. HOCKE, "The Application of Planning Criteria to the Determination of Generator Service Dates by Operational Gaming", A.I.E.E. Transactions, Vol. 78, February, 1960, pp. 1752 - 59.
46. BALDWIN, C. J., D. P. GAVER, C. H. HOFFMAN and J. A. ROSE, "Mathematical Models for Use in the Simulation of Power Generation Outages; III - Models for a Large Interconnection", A.I.E.E. Transactions, Vol. 78, February, 1960, pp. 1645 - 50.
47. REPS, D. N., "The Probability of Coincident Primary-Feeder Outages in Secondary Networks", A.I.E.E. Transactions, December, 1954, p. 1467.

APPENDIX A

APPENDIX A

The abbreviations used in the following tables are as follows:

CAP OUT MW	Capacity Out of Service in MW
CUM PROB	Cumulative Probability
IND PROB	Individual Probability
DOUT	Risk in Days per Year
YOUT	Risk in Years per Day
RIND	Index of Reliability

SYSTEM 1A-1

83

INSTALLED CAPACITY 200.0000 MW
DAYS 365.0
NO OF LEVELS 5

CAP OUT MW	CUM PROB	IND PROB
.0000	1.000000	.817907
10.0000	.182093	.165234
20.0000	.016859	.015856
30.0000	.001003	.000963
40.0000	.000040	.000040

DOUT	YOUT	RIND	LOAD MW
6.083180	.16	.999291	200.0000
.573178	1.74	.999933	190.0000
.035249	28.37	.999995	180.0000
.001431	698.63	.999999	170.0000

SYSTEM DATA

20 - 10 MW Hydraulic Units. Forced Outage Rate 0.01.

INSTALLED CAPACITY 250.0000 MW
 DAYS 365.0
 NO OF LEVELS 9

CAP OUT MW	CUM PROB	IND PROB
.0000	1.000000	.809728
10.0000	.190272	.163582
20.0000	.026690	.015697
30.0000	.010993	.000953
40.0000	.010040	.000040
50.0000	.010000	.008180
60.0000	.001820	.001652
70.0000	.000168	.000158
80.0000	.000010	.000010

DOUT	YOUT	RIND	LOAD MW
6.083162	.16	.999032	250.0000
1.513761	.66	.999590	240.0000
.873646	1.14	.999762	230.0000
.609384	1.64	.999876	220.0000
.347561	2.88	.999955	210.0000
.060772	16.45	.999993	200.0000
.005699	175.47	.999999	190.0000
.000337	2958.90	1.000000	180.0000

SYSTEM DATA

20 - 10 MW Units. Forced Outage Rate 0.01
 1 - 50 MW Unit. Forced Outage Rate 0.01

INSTALLED CAPACITY 300.0000 MW
 DAYS 365.0
 NO OF LEVELS 13

CAP OUT MW	CUM PROB	IND PROB
.0000	1.000000	.801631
10.0000	.198369	.161946
20.0000	.036423	.015540
30.0000	.020883	.000944
40.0000	.019939	.000039
50.0000	.019900	.016195
60.0000	.003705	.003272
70.0000	.000433	.000314
80.0000	.000119	.000019
90.0000	.000100	.000000
100.0000	.000100	.000082
110.0000	.000013	.000017
120.0000	.000001	.000001

DOUT	YOUT	RIND	LOAD MW
6.083136	.16	.998964	300.0000
2.131705	.47	.999460	290.0000
1.416504	.71	.999674	280.0000
.998455	1.00	.999828	270.0000
.570336	1.75	.999936	260.0000
.108915	9.18	.999985	250.0000
.019542	51.17	.999995	240.0000
.008939	111.86	.999997	230.0000
.006055	165.13	.999998	220.0000
.003447	290.09	.999999	210.0000
.000577	1730.35	1.000000	200.0000
.000032	31232.86	1.000000	190.0000

SYSTEM DATA

20 - 10 MW Units	Forced Outage Rate 0.01
2 - 50 MW Units	Forced Outage Rate 0.01

INSTALLED CAPACITY 350.0000 MW
 DAYS 365.0
 NO OF LEVELS 16

CAP OUT MW	CUM PROB	IND PROB
.0000	1.000000	.793615
10.0000	.206385	.160326
20.0000	.046059	.015385
30.0000	.030674	.000934
40.0000	.029740	.000039
50.0000	.029701	.024049
60.0000	.005652	.004859
70.0000	.000793	.000466
80.0000	.000327	.000029
90.0000	.000298	.000000
100.0000	.000298	.000243
110.0000	.000055	.000049
120.0000	.000006	.000005
130.0000	.000001	.000000
140.0000	.000001	.000000
150.0000	.000001	.000001

DOUT	YOUT	RIND	LOAD MW
6.083183	.16	.998967	350.0000
2.509422	.39	.999413	340.0000
1.798215	.56	.999641	330.0000
1.271283	.79	.999809	320.0000
.728685	1.37	.999926	310.0000
.150704	6.64	.999980	300.0000
.037339	26.78	.999991	290.0000
.021443	46.63	.999995	280.0000
.014870	67.25	.999997	270.0000
.008469	118.07	.999999	260.0000
.001557	642.12	.999999	250.0000
.000228	4383.56	1.000000	240.0000
.000079	12602.74	1.000000	230.0000
.000055	18082.19	1.000000	220.0000
.000028	34520.51	1.000000	210.0000

SYSTEM DATA

20 - 10 MW Units Forced Outage Rate 0.01
 3 - 50 MW Units Forced Outage Rate 0.01

INSTALLED CAPACITY 250.0000 MW
 DAYS 365.0
 NO OF LEVELS 9

CAP OUT MW	CUM PROB	IND PROB
.0000	1.000000	.801549
10.0000	.198451	.161929
20.0000	.036522	.015539
30.0000	.020983	.000944
40.0000	.020039	.000039
50.0000	.020000	.016359
60.0000	.003641	.003304
70.0000	.000337	.000317
80.0000	.000020	.000020

DOUT	YOUT	RIND	LOAD MW
7.299828	.14	.998518	250.0000
2.573803	.39	.999222	240.0000
1.719732	.58	.999527	230.0000
1.217689	.82	.999752	220.0000
.695180	1.44	.999911	210.0000
.121605	8.22	.999985	200.0000
.011430	87.49	.999998	190.0000
.000675	1479.45	1.000000	180.0000

SYSTEM DATA

20 - 10 MW Units Forced Outage Rate 0.01
 1 - 50 MW Unit Forced Outage Rate 0.02

INSTALLED CAPACITY 300.0000 MW
 DAYS 365.0
 NO OF LEVELS 13

CAP OUT MW	CUM PROB	IND PROB
.0000	1.000000	.785518
10.0000	.214482	.158691
20.0000	.055791	.015228
30.0000	.040563	.000924
40.0000	.039639	.000039
50.0000	.039600	.032062
60.0000	.007538	.006478
70.0000	.001060	.000621
80.0000	.000439	.000039
90.0000	.000400	.000000
100.0000	.000400	.000328
110.0000	.000072	.000066
120.0000	.000006	.000006

DOUT	YOUT	RIND	LOAD MW
8.110913	.12	.998230	300.0000
3.891404	.26	.998935	290.0000
2.818257	.35	.999336	280.0000
2.008717	.50	.999643	270.0000
1.158525	.86	.999859	260.0000
.241264	4.14	.999961	250.0000
.060250	16.60	.999983	240.0000
.034833	28.71	.999990	230.0000
.024278	41.19	.999995	220.0000
.013846	72.22	.999998	210.0000
.002372	421.50	.999999	200.0000
.000192	5205.48	1.000000	190.0000

SYSTEM DATA

20 - 10 MW Units Forced Outage Rate 0.01
 2 - 50 MW Units Forced Outage Rate 0.02

INSTALLED CAPACITY 350.0000 MW
 DAYS 365.0
 NO OF LEVELS 17

CAP OUT MW	CUM PROB	IND PROB
.0000	1.000000	.769808
10.0000	.230192	.155517
20.0000	.074675	.014923
30.0000	.059752	.000906
40.0000	.058846	.000038
50.0000	.058808	.047132
60.0000	.011676	.009521
70.0000	.002155	.000914
80.0000	.001241	.000056
90.0000	.001185	.000001
100.0000	.001184	.000962
110.0000	.000222	.000195
120.0000	.000027	.000019
130.0000	.000008	.000000
140.0000	.000008	.000000
150.0000	.000008	.000007
160.0000	.000001	.000001

DOUT	YOUT	RIND	LOAD MW
8.690274	.12	.998136	350.0000
4.827232	.21	.998817	340.0000
3.596928	.28	.999253	330.0000
2.573420	.39	.999590	320.0000
1.501662	.67	.999825	310.0000
.359221	2.78	.999938	300.0000
.126680	7.89	.999967	290.0000
.084384	11.85	.999980	280.0000
.059549	16.79	.999989	270.0000
.034113	29.31	.999996	260.0000
.006667	149.99	.999999	250.0000
.001318	758.69	.999999	240.0000
.000661	1512.33	.999999	230.0000
.000470	2127.32	1.000000	220.0000
.000260	3835.61	1.000000	210.0000
.000030	32876.71	1.000000	200.0000

SYSTEM DATA

20 - 10 MW Units	Forced Outage Rate 0.01
3 - 50 MW Units	Forced Outage Rate 0.02

INSTALLED CAPACITY 200.0000 MW
 DAYS 365.0
 NO OF LEVELS 4

CAP OUT MW	CUM PROB	IND PROB
.0000	1.000000	.904383
20.0000	.095617	.091351
40.0000	.004266	.004153
60.0000	.000113	.000113

DOUT	YOUT	RIND	LOAD MW
6.083089	.16	.998702	200.0000
3.341832	.30	.999566	190.0000
.295988	3.38	.999932	180.0000
.160743	6.22	.999978	170.0000
.008592	116.38	.999997	160.0000
.004582	218.21	.999999	150.0000

SYSTEM DATA

10 - 20 MW Units

Forced Outage Rate 0.01

INSTALLED CAPACITY 250.0000 MW
 DAYS 365.0
 NO OF LEVELS 8

CAP OUT MW	CUM PROB	IND PROB
.0000	1.000000	.895339
20.0000	.104661	.090438
40.0000	.014223	.004111
50.0000	.010112	.009044
60.0000	.001068	.000112
70.0000	.000956	.000914
90.0000	.000042	.000041
110.0000	.000001	.000001

DOUT	YOUT	RIND	LOAD MW
6.083089	.16	.998655	250.0000
3.683687	.27	.999358	240.0000
1.075639	.93	.999719	230.0000
.731244	1.37	.999858	220.0000
.354050	2.82	.999949	210.0000
.064179	15.58	.999986	200.0000
.033362	29.97	.999995	190.0000
.002906	344.06	.999999	180.0000
.001574	635.12	.999999	170.0000
.000076	13150.69	1.000000	160.0000
.000040	24657.52	1.000000	150.0000

SYSTEM DATA

10 - 20 MW Units	Forced Outage Rate 0.01
1 - 50 MW Unit	Forced Outage Rate 0.01

INSTALLED CAPACITY 300.0000 MW
 DAYS 365.0
 NO OF LEVELS 10

CAP OUT MW	CUM PROB	IND PROB
.0000	1.000000	.886385
20.0000	.113615	.089534
40.0000	.024081	.004070
50.0000	.020011	.017997
60.0000	.002104	.000111
70.0000	.001993	.001809
90.0000	.000184	.000082
100.0000	.000102	.000091
110.0000	.000011	.000002
120.0000	.000009	.000009

DOUT	YOUT	RIND	LOAD MW
6.083131	.16	.998702	300.0000
3.909592	.26	.999300	290.0000
1.580798	.63	.999642	280.0000
1.096780	.91	.999814	270.0000
.575530	1.74	.999928	260.0000
.111616	3.96	.999978	250.0000
.062937	15.89	.999991	240.0000
.012960	77.16	.999996	230.0000
.008461	118.18	.999998	220.0000
.003534	282.96	.999999	210.0000
.000608	1643.84	.999999	200.0000
.000238	3470.32	1.000000	190.0000

SYSTEM DATA

10 - 20 MW Units	Forced Outage Rate 0.01
2 - 50 MW Units	Forced Outage Rate 0.01

INSTALLED CAPACITY 350.0000 MW
 DAYS 365.0
 NO OF LEVELS 12

CAP OUT MW	CUM PROB	IND PROB
.0000	1.000000	.877522
20.0000	.122478	.088638
40.0000	.033840	.004029
50.0000	.029811	.026592
60.0000	.003219	.000110
70.0000	.003109	.002686
90.0000	.000423	.000122
100.0000	.000301	.000269
110.0000	.000032	.000003
120.0000	.000029	.000028
140.0000	.000001	.000000
150.0000	.000001	.000001

DOUT	YOUT	RIND	LOAD MW
6.083092	.16	.998774	350.0000
4.070610	.25	.999296	340.0000
1.936159	.52	.999616	330.0000
1.353351	.74	.999797	320.0000
.732944	1.36	.999918	310.0000
.152874	6.54	.999972	300.0000
.090620	11.03	.999987	290.0000
.026310	38.01	.999994	280.0000
.017754	56.32	.999997	270.0000
.008540	117.09	.999999	260.0000
.001557	642.12	.999999	250.0000
.000811	1232.88	1.000000	240.0000
.000079	12602.74	1.000000	230.0000
.000055	18082.19	1.000000	220.0000
.000028	34520.51	1.000000	210.0000

SYSTEM DATA

10 - 20 MW Units	Forced Outage Rate 0.01
3 - 50 MW Units	Forced Outage Rate 0.01

INSTALLED CAPACITY 250.0000 MW
 DAYS 365.0
 NO OF LEVELS 8

CAP OUT MW	CUM PROB	IND PROB
.0000	1.000000	.886295
20.0000	.113705	.089525
40.0000	.024180	.004069
50.0000	.020111	.018088
60.0000	.002023	.000111
70.0000	.001912	.001827
90.0000	.000085	.000083
110.0000	.000002	.000002

DOUT	YOUT	RIND	LOAD MW
7.299755	.14	.998141	250.0000
4.721808	.21	.998988	240.0000
1.919688	.52	.999480	230.0000
1.338333	.75	.999730	220.0000
.701611	1.43	.999899	210.0000
.124982	8.00	.999973	200.0000
.066788	14.97	.999991	190.0000
.005880	170.05	.999998	180.0000
.003184	313.99	.999999	170.0000
.000152	6575.34	1.000000	160.0000
.000081	12328.76	1.000000	150.0000

SYSTEM DATA

10 - 20 MW Units	Forced Outage Rate 0.01
1 - 50 MW Unit	Forced Outage Rate 0.02

INSTALLED CAPACITY 300.0000 MW
 DAYS 365.0
 NO OF LEVELS 11

CAP OUT MW	CUM PROB	IND PROB
.0000	1.000000	.868569
20.0000	.131431	.087734
40.0000	.043697	.003988
50.0000	.039709	.035452
60.0000	.004257	.000109
70.0000	.004148	.003581
90.0000	.000567	.000163
100.0000	.000404	.000362
110.0000	.000042	.000004
120.0000	.000038	.000037
140.0000	.000001	.000001

DOUT	YOUT	RIND	LOAD MW
8.110909	.12	.997968	300.0000
5.633567	.18	.998772	290.0000
2.979270	.34	.999299	280.0000
2.105081	.48	.999622	270.0000
1.163649	.86	.999845	260.0000
.243941	4.10	.999946	250.0000
.146202	6.84	.999974	240.0000
.042847	23.34	.999988	230.0000
.029117	34.34	.999994	220.0000
.014078	71.03	.999998	210.0000
.002494	400.94	.999999	200.0000
.001280	780.82	.999999	190.0000
.000067	14794.51	1.000000	180.0000
.000035	27945.17	1.000000	170.0000

SYSTEM DATA

10 - 20 MW Units	Forced Outage Rate 0.01
2 - 50 MW Units	Forced Outage Rate 0.02

INSTALLED CAPACITY 350.0000 MW
 DAYS 365.0
 NO OF LEVELS 12

CAP OUT MW	CUM PROB	IND PROB
.0000	1.000000	.851198
20.0000	.148802	.085979
40.0000	.062823	.003908
50.0000	.058915	.052114
60.0000	.006801	.000108
70.0000	.006693	.005264
90.0000	.001429	.000239
100.0000	.001190	.001063
110.0000	.000127	.000007
120.0000	.000120	.000107
140.0000	.000013	.000005
150.0000	.000008	.000008

DOUT	YOUT	RIND	LOAD MW
8.690270	.12	.997943	350.0000
6.283476	.16	.998697	340.0000
3.730815	.27	.999222	330.0000
2.653112	.38	.999570	320.0000
1.505881	.66	.999810	310.0000
.361410	2.77	.999923	300.0000
.231208	4.33	.999958	290.0000
.094052	10.63	.999978	280.0000
.065339	15.30	.999988	270.0000
.034417	29.05	.999995	260.0000
.006837	146.25	.999998	250.0000
.003903	256.18	.999999	240.0000
.000899	1112.01	.999999	230.0000
.000580	1722.11	1.000000	220.0000
.000231	4315.06	1.000000	210.0000

SYSTEM DATA

10 - 20 MW Units	Forced Outage Rate 0.01
3 - 50 MW Units	Forced Outage Rate 0.02

SYSTEM 1C-1

97

INSTALLED CAPACITY 200.0000 MW
DAYS 365.0
NO OF LEVELS 4

CAP OUT MW	CUM PROB	IND PROB
.0000	1.000000	.950991
40.0000	.049009	.048029
80.0000	.000980	.000971
120.0000	.000009	.000009

DOUT	YOUT	RIND	LOAD MW
6.083090	.16	.997524	200.0000
4.834106	.21	.998414	190.0000
3.446346	.29	.999162	180.0000
1.895318	.53	.999699	170.0000
.150410	6.65	.999925	160.0000
.120693	8.29	.999951	150.0000
.086730	11.53	.999974	140.0000
.047543	21.03	.999991	130.0000
.001825	547.95	.999998	120.0000
.001493	669.71	.999999	110.0000
.001095	913.24	.999999	100.0000
.000608	1643.83	.999999	90.0000

SYSTEM DATA

5 - 40 MW Units

Forced Outage Rate 0.01

INSTALLED CAPACITY 250.0000 MW
 DAYS 365.0
 NO OF LEVELS 7

CAP OUT MW	CUM PROB	IND PROB
.0000	1.000000	.941481
40.0000	.058519	.047549
50.0000	.010970	.009510
80.0000	.001460	.000961
90.0000	.000499	.000480
120.0000	.000019	.000010
130.0000	.000009	.000009

DOUT	YOUT	RIND	LOAD MW
6.083113	.16	.997901	250.0000
4.853282	.21	.998635	240.0000
3.516512	.28	.999243	230.0000
2.058214	.49	.999683	220.0000
.461030	2.17	.999896	210.0000
.150410	6.65	.999948	200.0000
.111581	8.96	.999970	190.0000
.068437	14.61	.999987	180.0000
.020218	49.46	.999996	170.0000
.002509	398.51	.999999	160.0000
.001906	524.63	.999999	150.0000
.001216	821.92	.999999	140.0000
.000421	2374.43	1.000000	130.0000

SYSTEM DATA

5 - 40 MW Units

Forced Outage Rate 0.01

1 - 50 MW Unit

Forced Outage Rate 0.01

INSTALLED CAPACITY 300.0000 MW
 DAYS 365.0
 NO OF LEVELS 9

CAP OUT MW	CUM PROB	IND PROB
.0000	1.000000	.932066
40.0000	.067934	.047074
50.0000	.020860	.018829
80.0000	.002031	.000951
90.0000	.001080	.000951
100.0000	.000129	.000096
120.0000	.000033	.000009
130.0000	.000024	.000020
140.0000	.000004	.000004

DOUT	YOUT	RIND	LOAD MW
6.083172	.16	.998178	300.0000
4.867883	.21	.998804	290.0000
3.565790	.28	.999318	280.0000
2.167245	.46	.999692	270.0000
.661118	1.51	.999887	260.0000
.179969	5.56	.999946	250.0000
.135987	7.35	.999968	240.0000
.088181	11.34	.999984	230.0000
.036029	27.75	.999994	220.0000
.006459	154.80	.999998	210.0000
.002859	349.75	.999999	200.0000
.001953	512.01	.999999	190.0000
.000946	1056.75	.999999	180.0000
.000143	6986.29	1.000000	170.0000

SYSTEM DATA

5 - 40 MW Units	Forced Outage Rate 0.01
2 - 50 MW Units	Forced Outage Rate 0.01

INSTALLED CAPACITY 350.0000 MW
 DAYS 365.0
 NO OF LEVELS 10

CAP OUT MW	CUM PROB	IND PROB
.0000	1.000000	.922745
40.0000	.077255	.046603
50.0000	.030652	.027962
80.0000	.002690	.000942
90.0000	.001748	.001412
100.0000	.000336	.000283
120.0000	.000053	.000009
130.0000	.000044	.000029
140.0000	.000015	.000014
150.0000	.000001	.000001

DOUT	YOUT	RIND	LOAD MW
6.083196	.16	.998389	350.0000
4.879852	.20	.998935	340.0000
3.603583	.28	.999381	330.0000
2.247544	.44	.999706	320.0000
.804020	1.24	.999884	310.0000
.209266	4.78	.999944	300.0000
.160054	6.25	.999966	290.0000
.107327	9.32	.999983	280.0000
.050694	19.73	.999993	270.0000
.011745	85.14	.999997	260.0000
.004039	247.57	.999999	250.0000
.002864	349.13	.999999	240.0000
.001586	630.14	.999999	230.0000
.000442	2260.27	1.000000	220.0000
.000028	34520.51	1.000000	210.0000

SYSTEM DATA

5 - 40 MW Units	Forced Outage Rate 0.01
3 - 50 MW Units	Forced Outage Rate 0.01

INSTALLED CAPACITY 250.0000 MW
 DAYS 365.0
 NO OF LEVELS 7

CAP OUT MW	CUM PROB	IND PROB
.0000	1.000000	.931971
40.0000	.068029	.047069
50.0000	.020960	.019020
80.0000	.001940	.000951
90.0000	.000989	.000960
120.0000	.000029	.000010
130.0000	.000019	.000019

DOUT	YOUT	RIND	LOAD MW
7.299780	.14	.997386	250.0000
5.879591	.17	.998264	240.0000
4.335910	.23	.999000	230.0000
2.651892	.38	.999547	220.0000
.807400	1.24	.999837	210.0000
.210331	4.75	.999923	200.0000
.159287	6.28	.999954	190.0000
.102571	9.75	.999979	180.0000
.039183	25.52	.999993	170.0000
.004030	248.13	.999998	160.0000
.003122	320.23	.999998	150.0000
.002085	479.45	.999999	140.0000
.000889	1124.73	.999999	130.0000

SYSTEM DATA

5 - 40 MW Units	Forced Outage Rate 0.01
1 - 50 MW Unit	Forced Outage Rate 0.02

INSTALLED CAPACITY 300.0000 MW
 DAYS 365.0
 NO OF LEVELS 9

CAP OUT MW	CUM PROB	IND PROB
.0000	1.000000	.913331
40.0000	.086669	.046128
50.0000	.040541	.037279
80.0000	.003262	.000932
90.0000	.002330	.001883
100.0000	.000447	.000380
120.0000	.000067	.000009
130.0000	.000058	.000039
140.0000	.000019	.000019

DOUT	YOUT	RIND	LOAD MW
8.110930	.12	.997444	300.0000
6.572560	.15	.998275	290.0000
4.924307	.20	.998969	280.0000
3.153962	.32	.999490	270.0000
1.247435	.80	.999791	260.0000
.310833	3.22	.999900	250.0000
.241102	4.15	.999937	240.0000
.165306	6.05	.999967	230.0000
.082622	12.10	.999987	220.0000
.019061	52.46	.999995	210.0000
.006417	155.81	.999998	200.0000
.004610	216.89	.999998	190.0000
.002602	384.27	.999999	180.0000
.000679	1470.80	1.000000	170.0000

SYSTEM DATA

5 - 40 MW Units	Forced Outage Rate 0.01
2 - 50 MW Units	Forced Outage Rate 0.02

INSTALLED CAPACITY 350.0000 MW
 DAYS 365.0
 NO OF LEVELS 12

CAP CUT MW	CUM PROB	IND PROB
0.0000	1.000000	.695065
40.0000	.104935	.045205
50.0000	.059730	.054800
60.0000	.004930	.000912
90.0000	.004017	.002768
100.0000	.001249	.001118
120.0000	.000131	.000009
130.0000	.000122	.000056
140.0000	.000066	.000058
150.0000	.000003	.000007
170.0000	.000001	.000000
180.0000	.000001	.000001

DOUT	YOUT	RIND	LOAD MW
8.690252	.12	.997559	350.0000
7.068332	.14	.998335	340.0000
5.848116	.19	.998961	330.0000
3.520386	.28	.999469	320.0000
1.574740	.64	.999763	310.0000
.416039	2.40	.999880	300.0000
.326963	3.03	.999923	290.0000
.231536	4.32	.999953	280.0000
.129034	7.75	.999981	270.0000
.040009	24.89	.999993	260.0000
.011217	89.15	.999996	250.0000
.008364	119.55	.999998	240.0000
.005263	189.99	.999999	230.0000
.002129	469.67	.999999	220.0000
.000310	3138.23	1.000000	210.0000
.000091	10958.90	1.000000	200.0000
.000064	15616.43	1.000000	190.0000
.000033	29589.02	1.000000	180.0000

SYSTEM DATA

5 - 40 MW Units

Forced Outage Rate 0.01

3 - 50 MW Units

Forced Outage Rate 0.02

INSTALLED CAPACITY 200.0000 MW
 DAYS 365.0
 NO OF LEVELS 4

CAP OUT MW	CUM PROB	IND PROB
.0000	1.000000	.960597
50.0000	.039403	.038811
100.0000	.000592	.000589
150.0000	.000003	.000003

DOUT	YOUT	RIND	LOAD MW
6.082755	.16	.996935	200.0000
5.141353	.19	.997793	190.0000
4.095347	.24	.998576	180.0000
2.926284	.34	.999239	170.0000
1.611087	.62	.999719	160.0000
.120531	8.30	.999920	150.0000
.103468	9.66	.999941	140.0000
.083781	11.94	.999961	130.0000
.060782	16.45	.999979	120.0000
.033568	29.79	.999993	110.0000
.000912	1095.89	.999999	100.0000
.000811	1232.88	.999999	90.0000
.000684	1461.19	.999999	80.0000
.000521	1917.81	.999999	70.0000
.000304	3287.67	1.000000	60.0000

SYSTEM DATA

4 - 50 MW Units

Forced Outage Rate 0.01

INSTALLED CAPACITY 250.0000 MW
 DAYS 365.0
 NO OF LEVELS 4

CAP OUT MW	CUM PROB	IND PROB
.0000	1.000000	.950991
50.0000	.049009	.048029
100.0000	.000980	.000971
150.0000	.000009	.000009

DOUT	YOUT	RIND	LOAD MW
6.083090	.16	.997524	250.0000
5.094310	.20	.998245	240.0000
4.019549	.25	.998884	230.0000
2.847083	.35	.999407	220.0000
1.562954	.64	.999773	210.0000
.150410	6.65	.999925	200.0000
.126949	7.88	.999946	190.0000
.100881	9.91	.999965	180.0000
.071747	13.94	.999982	170.0000
.038971	25.66	.999994	160.0000
.001825	547.95	.999998	150.0000
.001564	639.27	.999999	140.0000
.001263	791.48	.999999	130.0000
.000912	1095.89	.999999	120.0000
.000497	2009.13	1.000000	110.0000

SYSTEM DATA

5 - 40 MW Units

Forced Outage Rate 0.01

INSTALLED CAPACITY 300.0000 MW
 DAYS 365.0
 NO OF LEVELS 4

CAP OUT MW	CUM PROB	IND PROB
.0000	1.000000	.941481
50.0000	.058519	.057059
100.0000	.001460	.001441
150.0000	.000019	.000019

DOUT	YOUT	RIND	LOAD MW
6.083131	.16	.997916	300.0000
5.065341	.20	.998537	290.0000
3.974851	.25	.999075	280.0000
2.803583	.36	.999507	270.0000
1.542220	.65	.999804	260.0000
.179945	5.56	.999927	250.0000
.150435	6.65	.999949	240.0000
.118360	8.45	.999968	230.0000
.083369	11.99	.999983	220.0000
.045045	22.20	.999994	210.0000
.002889	346.07	.999998	200.0000
.002433	410.96	.999999	190.0000
.001926	519.11	.999999	180.0000
.001359	735.40	.999999	170.0000
.000722	1384.28	1.000000	160.0000

SYSTEM DATA

6 - 50 MW Units

Forced Outage Rate 0.01

INSTALLED CAPACITY 350.0000 MW
 DAYS 365.0
 NO OF LEVELS 4

CAP OUT MW	CUM PROB	IND PROB
.0000	1.000000	.932066
50.0000	.067934	.065903
100.0000	.002031	.001998
150.0000	.000033	.000033

DOUT	YOUT	RIND	LOAD MW
6.083161	.16	.998197	350.0000
5.046591	.20	.998740	340.0000
3.947198	.25	.999205	330.0000
2.779094	.36	.999574	320.0000
1.535631	.65	.999824	310.0000
.209266	4.78	.999929	300.0000
.173878	5.75	.999951	290.0000
.135962	7.35	.999969	280.0000
.095237	10.50	.999984	270.0000
.051380	19.46	.999994	260.0000
.004015	249.07	.999998	250.0000
.003345	298.88	.999999	240.0000
.002618	381.90	.999999	230.0000
.001825	547.95	.999999	220.0000
.000955	1046.08	1.000000	210.0000

SYSTEM DATA

7 - 50 MW Units

Forced Outage Rate 0.01

INSTALLED CAPACITY 250.0000 MW
 DAYS 365.0
 NO OF LEVELS 4

CAP OUT MW	CUM PROB	IND PROB
.0000	1.000000	.941385
50.0000	.058615	.057247
100.0000	.001368	.001353
150.0000	.000015	.000015

DOUT	YOUT	RIND	LOAD MW
7.299756	.14	.997009	250.0000
6.118186	.16	.997874	240.0000
4.833869	.21	.998640	230.0000
3.432797	.29	.999268	220.0000
1.898291	.53	.999709	210.0000
.210331	4.75	.999894	200.0000
.177601	5.63	.999924	190.0000
.141234	7.08	.999951	180.0000
.100589	9.94	.999974	170.0000
.054864	18.23	.999991	160.0000
.003041	328.77	.999998	150.0000
.002607	383.56	.999998	140.0000
.002105	474.89	.999999	130.0000
.001520	657.53	.999999	120.0000
.000829	1205.48	.999999	110.0000

SYSTEM DATA

4 - 50 MW Units	Forced Outage Rate 0.01
1 - 50 MW Unit	Forced Outage Rate 0.02

INSTALLED CAPACITY 300.0000 MW
 DAYS 365.0
 NO OF LEVELS 4

CAP OUT MW	CUM PROB	IND PROB
.0000	1.000000	.922557
50.0000	.077443	.074930
100.0000	.002513	.002471
150.0000	.000042	.000042

DOUT	YOUT	RIND	LOAD MW
8.110909	.12	.997182	300.0000
6.766074	.15	.998008	290.0000
5.325177	.19	.998725	280.0000
3.777548	.26	.999303	270.0000
2.110872	.47	.999702	260.0000
.310858	3.22	.999874	250.0000
.260113	3.84	.999911	240.0000
.204955	4.88	.999944	230.0000
.144783	6.91	.999970	220.0000
.078880	12.68	.999989	210.0000
.006387	156.56	.999996	200.0000
.005378	185.91	.999997	190.0000
.004258	234.83	.999998	180.0000
.003005	332.68	.999999	170.0000
.001596	626.22	.999999	160.0000

SYSTEM DATA

4 - 50 MW Units	Forced Outage Rate 0.01
2 - 50 MW Units	Forced Outage Rate 0.02

INSTALLED CAPACITY 350.0000 MW
 DAYS 365.0
 NO OF LEVELS 4

CAP OUT MW	CUM PROB	IND PROB
.0000	1.000000	.904106
50.0000	.095894	.091883
100.0000	.004011	.003919
150.0000	.000092	.000092

DOUT	YOUT	RIND	LOAD MW
8.690218	.12	.997366	350.0000
7.230061	.14	.998140	340.0000
5.681409	.18	.998804	330.0000
4.035968	.25	.999334	320.0000
2.284372	.44	.999697	310.0000
.415998	2.40	.999858	300.0000
.346204	2.89	.999900	290.0000
.271425	3.68	.999937	280.0000
.191106	5.23	.999967	270.0000
.104610	9.56	.999987	260.0000
.011193	89.34	.999995	250.0000
.009327	107.21	.999997	240.0000
.007300	136.99	.999998	230.0000
.005087	196.55	.999999	220.0000
.002665	375.22	.999999	210.0000

SYSTEM DATA

4 - 50 MW Units Forced Outage Rate 0.01
 3 - 50 MW Units Forced Outage Rate 0.02

SYSTEM 1A-1 & 25 MW FIRM PURCHASE

INSTALLED CAPACITY 225.0000 MW
DAYS 365.0
NO OF LEVELS 5

111

CAP	OUT MW	CUM PROB	IND PROB
	.0000	1.000000	.817907
	10.0000	.182093	.165234
	20.0000	.016859	.015856
	30.0000	.001003	.000963
	40.0000	.000040	.000040

DOUT	YOUT	RIND	LOAD MW
5.407277	.18	.999440	225.0000
.506530	1.97	.999948	215.0000
.030950	32.31	.999996	205.0000
.001247	801.37	.999999	195.0000

SYSTEM DATA

20 - 10 MW Units Forced Outage Rate 0.01
1 - 25 MW Firm Capacity Purchase

SYSTEM 1B-1 & 25 MW FIRM PURCHASE

112

INSTALLED CAPACITY 225.0000 MW
DAYS 365.0
NO OF LEVELS 4

CAP OUT MW	CUM PROB	IND PROB
.0000	1.000000	.904383
20.0000	.095617	.091351
40.0000	.004266	.004153
60.0000	.000113	.000113

DOUT	YOUT	RIND	LOAD MW
5.407191	.18	.998975	225.0000
2.953250	.34	.999661	215.0000
.259891	3.85	.999947	205.0000
.140135	7.14	.999983	195.0000
.007431	134.56	.999998	185.0000
.003928	254.58	.999999	175.0000

SYSTEM DATA

10 - 20 MW Units Forced Outage Rate 0.01

1 - 25 MW Firm Capacity Purchase

SYSTEM 1C-1 & 25 MW FIRM PURCHASE

113

INSTALLED CAPACITY 225.0000 MW
 DAYS 365.0
 NO OF LEVELS 4

CAP OUT MW	CUM PROB	IND PROB
.0000	1.000000	.950991
40.0000	.049009	.048029
80.0000	.000980	.000971
120.0000	.000009	.000009

DOUT	YOUT	RIND	LOAD MW
5.407191	.18	.998043	225.0000
4.271999	.23	.998761	215.0000
3.026058	.33	.999354	205.0000
1.652328	.61	.999771	195.0000
.130084	7.69	.999944	185.0000
.103451	9.67	.999964	175.0000
.073589	13.59	.999981	165.0000
.039875	25.08	.999994	155.0000
.001510	662.10	.999999	145.0000
.001216	821.92	.999999	135.0000
.000675	1141.55	.999999	125.0000
.000476	2100.45	1.000000	115.0000

SYSTEM DATA

5 - 40 MW Units Forced Outage Rate 0.01
 1 - 25 MW Firm Capacity Purchase

SYSTEM 1D-1 & 25 MW FIRM PURCHASE

INSTALLED CAPACITY 225.0000 MW
 DAYS 365.0
 NO OF LEVELS 4

114

CAP OUT MW	CUM PROB	IND PROB
0.0000	1.000000	.960597
50.0000	.039403	.038811
100.0000	.000592	.000589
150.0000	.000003	.000003

DOUT	YOUT	RIND	LOAD MW
5.407016	.18	.997578	225.0000
4.543649	.22	.998276	215.0000
3.596049	.28	.998902	205.0000
2.551261	.39	.999422	195.0000
1.393511	.72	.999790	185.0000
.103416	9.67	.999941	175.0000
.087858	11.38	.999957	165.0000
.070291	14.23	.999972	155.0000
.050302	19.88	.999985	145.0000
.027352	36.56	.999995	135.0000
.000730	1369.86	.999999	125.0000
.000634	1575.34	.999999	115.0000
.000521	1917.81	.999999	105.0000
.000384	2602.74	.999999	95.0000
.000214	4657.53	1.000000	85.0000

SYSTEM DATA

4 - 50 MW Units Forced Outage Rate 0.01

1 - 25 MW Firm Capacity Purchase

INSTALLED CAPACITY 400.0000 MW
 DAYS 365.0
 NO OF LEVELS 16

CAP	OUT MW	CUM PROB	IND PROB
	.0000	1.000000	.785679
10	.0000	.214321	.158722
20	.0000	.055599	.015231
30	.0000	.040368	.000925
40	.0000	.039443	.000040
50	.0000	.039403	.031744
60	.0000	.007659	.006413
70	.0000	.001246	.000616
80	.0000	.000630	.000037
90	.0000	.000593	.000001
100	.0000	.000592	.000481
110	.0000	.000111	.000098
120	.0000	.000013	.000009
130	.0000	.000004	.000001
140	.0000	.000003	.000000
150	.0000	.000003	.000003

DOUT	YOUT	RIND	LOAD MW
6.083149	.16	.998997	400.0000
2.896090	.35	.999403	390.0000
2.082229	.48	.999632	380.0000
1.474798	.68	.999803	370.0000
.849250	1.18	.999920	360.0000
.188653	5.30	.999975	350.0000
.057165	17.49	.999988	340.0000
.035928	27.83	.999993	330.0000
.025074	39.88	.999996	320.0000
.014246	70.19	.999998	310.0000
.002717	368.02	.999999	300.0000
.000482	2072.66	1.000000	290.0000
.000217	4602.74	1.000000	280.0000
.000135	7397.26	1.000000	270.0000
.000070	14246.55	1.000000	260.0000

SYSTEM DATA

20 - 10 MW Units Forced Outage Rate 0.01
 4 - 50 MW Units Forced Outage Rate 0.01

INSTALLED CAPACITY 450.0000 MW
 DAYS 365.0
 NO OF LEVELS 17

CAP OUT MW	CUM PROB	IND PROB
.0000	1.000000	.777822
10.0000	.222178	.157135
20.0000	.065043	.015079
30.0000	.049964	.000916
40.0000	.049048	.000039
50.0000	.049009	.039283
60.0000	.009726	.007937
70.0000	.001789	.000761
80.0000	.001028	.000047
90.0000	.000981	.000001
100.0000	.000980	.000794
110.0000	.000186	.000160
120.0000	.000026	.000016
130.0000	.000010	.000001
140.0000	.000009	.000000
150.0000	.000009	.000008
160.0000	.000001	.000001

DOUT	YOUT	RIND	LOAD MW
6.083166	.16	.999037	450.0000
3.149632	.32	.999409	440.0000
2.302698	.43	.999633	430.0000
1.633839	.61	.999801	420.0000
.945944	1.06	.999917	410.0000
.224246	4.46	.999971	400.0000
.078287	12.77	.999985	390.0000
.051708	19.34	.999991	380.0000
.036204	27.62	.999995	370.0000
.020632	48.47	.999998	360.0000
.004188	238.73	.999999	350.0000
.000984	1016.19	.999999	340.0000
.000534	1870.57	1.000000	330.0000
.000361	2768.57	1.000000	320.0000
.000196	5095.88	1.000000	310.0000
.000020	49314.97	1.000000	300.0000

SYSTEM DATA

20 - 10 MW Units Forced Outage Rate 0.01
 5 - 50 MW Units Forced Outage Rate 0.01

INSTALLED CAPACITY 500.0000 MW
 DAYS 365.0
 NO OF LEVELS 17

CAP	OUT MW	CUM PROB	IND PROB
00.0000		1.000000	.770044
10.0000		.229956	.155564
20.0000		.074392	.014928
30.0000		.059464	.000906
40.0000		.058558	.000039
50.0000		.058519	.046669
60.0000		.011850	.009420
70.0000		.002422	.000905
80.0000		.001517	.000055
90.0000		.001462	.000002
100.0000		.001460	.001179
110.0000		.000281	.000238
120.0000		.000043	.000023
130.0000		.000010	.000001
140.0000		.000019	.000000
150.0000		.000019	.000017
160.0000		.000002	.000002

DOUT	YOUT	RIND	LOAD MW
6.083137	.16	.999079	500.0000
3.352390	.30	.999423	490.0000
2.479414	.40	.999639	480.0000
1.762510	.57	.999803	470.0000
1.026419	.97	.999914	460.0000
.258136	3.87	.999967	450.0000
.100167	9.93	.999982	440.0000
.068232	14.66	.999989	430.0000
.047384	20.83	.999994	420.0000
.027360	36.55	.999997	410.0000
.005839	171.23	.999999	400.0000
.001606	622.42	.999999	390.0000
.000960	1041.10	.999999	380.0000
.000657	1520.55	1.000000	370.0000
.000354	2818.00	1.000000	360.0000
.000034	28767.05	1.000000	350.0000

SYSTEM DATA

20 - 10 MW Units Forced Outage Rate 0.01
 6 - 50 MW Units Forced Outage Rate 0.01

INSTALLED CAPACITY 550.0000 MW
 DAYS 365.0
 NO OF LEVELS 17

CAP OUT MW	CUM PROB	IND PROB
.0000	1.000000	.762343
10.0000	.237657	.154009
20.0000	.083648	.014778
30.0000	.068870	.000898
40.0000	.067972	.000038
50.0000	.067934	.053903
60.0000	.014031	.010889
70.0000	.003142	.001045
80.0000	.002097	.000064
90.0000	.002033	.000002
100.0000	.002031	.001634
110.0000	.000397	.000330
120.0000	.000067	.000032
130.0000	.000035	.000001
140.0000	.000034	.000001
150.0000	.000033	.000028
160.0000	.000005	.000005

DOUT	YOUT	RIND	LOAD MW
6.083185	.16	.999121	550.0000
3.518522	.28	.999440	540.0000
2.624798	.38	.999648	530.0000
1.869586	.53	.999805	520.0000
1.095467	.91	.999913	510.0000
.290844	3.44	.999965	500.0000
.122585	8.16	.999980	490.0000
.085318	11.72	.999988	480.0000
.059992	16.67	.999993	470.0000
.034410	29.06	.999997	460.0000
.007719	129.55	.999999	450.0000
.002405	415.68	.999999	440.0000
.001513	660.61	.999999	430.0000
.001042	958.90	.999999	420.0000
.000563	1773.61	1.000000	410.0000
.000076	13150.69	1.000000	400.0000

SYSTEM DATA

20 - 10 MW Units Forced Outage Rate 0.01
 7 - 50 MW Units Forced Outage Rate 0.01

INSTALLED CAPACITY 600.0000 MW
 DAYS 365.0
 NO OF LEVELS 17

CAP OUT MW	CUM PROB	IND PROB
.0000	1.000000	.754720
10.0000	.245280	.152468
20.0000	.092812	.014631
30.0000	.078181	.000389
40.0000	.077292	.000037
50.0000	.077255	.060988
60.0000	.016267	.012320
70.0000	.003947	.001183
80.0000	.002764	.000072
90.0000	.002692	.000002
100.0000	.002690	.002157
110.0000	.000533	.000435
120.0000	.000098	.000042
130.0000	.000056	.000002
140.0000	.000054	.000001
150.0000	.000053	.000044
160.0000	.000009	.000009

DOUT	YOUT	RIND	LOAD MW
6.003165	.16	.999160	600.0000
3.657252	.27	.999458	590.0000
2.746848	.36	.999658	580.0000
1.960650	.51	.999809	570.0000
1.156031	.87	.999912	560.0000
.322561	3.10	.999962	550.0000
.145279	6.08	.999978	540.0000
.102716	9.74	.999986	530.0000
.072356	13.82	.999993	520.0000
.041664	24.00	.999997	510.0000
.009769	102.36	.999999	500.0000
.003352	298.33	.999999	490.0000
.002179	458.74	.999999	480.0000
.001501	666.04	.999999	470.0000
.000619	1219.62	1.000000	460.0000
.000121	8219.15	1.000000	450.0000

SYSTEM DATA

20 - 10 MW Units

Forced Outage Rate 0.01

8 - 50 MW Units

Forced Outage Rate 0.01

SYSTEM 6AD

INSTALLED CAPACITY 650.0000 MW
 DAYS 365.0
 NO OF LEVELS 17

CAP	OUT MW	CUM PROB	IND PROB
.0000		1.000000	.747173
10.0000		.252827	.150943
20.0000		.101884	.014485
30.0000		.087399	.000879
40.0000		.086520	.000038
50.0000		.086482	.067924
60.0000		.018558	.013723
70.0000		.004835	.001316
80.0000		.003519	.000081
90.0000		.003428	.000003
100.0000		.003435	.002744
110.0000		.000691	.000555
120.0000		.000136	.000053
130.0000		.000083	.000003
140.0000		.000080	.000000
150.0000		.000080	.000066
160.0000		.000014	.000014

DOUT	YOUT	RIND	LOAD MW
6.083162	.16	.999197	650.0000
3.775030	.26	.999476	640.0000
2.851154	.35	.999667	630.0000
2.039596	.49	.999812	620.0000
1.210196	.83	.999911	610.0000
.353533	2.83	.999960	600.0000
.168178	5.95	.999976	590.0000
.130366	8.31	.999985	580.0000
.094921	11.73	.999992	570.0000
.069090	20.37	.999996	560.0000
.041989	83.40	.999998	550.0000
.034427	225.87	.999999	540.0000
.002949	339.00	.999999	530.0000
.002035	491.26	.999999	520.0000
.001121	891.87	1.000000	510.0000
.000170	5870.84	1.000000	500.0000

SYSTEM DATA

20 - 10 MW Units Forced Outage Rate 0.01
 9 - 50 MW Units Forced Outage Rate 0.01

INSTALLED CAPACITY 700.0000 MW
 DAYS 365.0
 NO OF LEVELS 18


CAP OUT MW	CUM PROB	IND PROB
0.0000	1.000000	.739701
10.0000	.260299	.149434
20.0000	.110865	.014340
30.0000	.096525	.000871
40.0000	.095654	.000037
50.0000	.095617	.074717
60.0000	.020900	.015094
70.0000	.005806	.001449
80.0000	.004357	.000088
90.0000	.004269	.000003
100.0000	.004266	.003397
110.0000	.000869	.000686
120.0000	.000183	.000066
130.0000	.000117	.000004
140.0000	.000113	.000000
150.0000	.000113	.000092
160.0000	.000021	.000020
170.0000	.000001	.000001

DOUT	YOUT	RIND	LOAD MW
6.083123	.16	.999231	700.0000
3.876374	.26	.999494	690.0000
2.541572	.34	.999677	680.0000
2.109067	.47	.999816	670.0000
1.259364	.79	.999911	660.0000
.833859	2.61	.999958	650.0000
.491197	5.23	.999975	640.0000
.238169	7.24	.999984	630.0000
.097647	10.24	.999991	620.0000
.056674	17.64	.999996	610.0000
.014366	69.60	.999998	600.0000
.005656	176.98	.999999	590.0000
.003828	261.21	.999999	580.0000
.002646	377.82	.999999	570.0000
.001466	681.89	1.000000	560.0000
.000243	4109.57	1.000000	550.0000
.000011	88766.73	1.000000	540.0000


SYSTEM DATA

20 - 10 MW Units Forced Outage Rate 0.01


10 - 50 MW Units Forced Outage Rate 0.01




RB
2/1/63




RB
21/1/63




RB
21/1/63




RB
21/1/63




RB.
2/1/63





RB
29/1/53



RB
29/1/63







0.99999

INDEX OF RELIABILITY


RB.
30/1/63

0.99999

80 120 160 200 240 280 320 360

PEAK LOAD IN MW

0.9999




INDEX OF RELIABILITY

RB
30/1/63

0.999999

PEAK LOAD IN MW




0.99999

RB
30/1/63

0.9999999

INDEX OF RELIABILITY

PEAK LOAD IN MW



0.99999


INDEX OF RELIABILITY

P.B.
30/1/63

0.999999


PEAK LOAD IN MW

00 120 160 200 240 280 320 360



RB
6/1/63

0.9999




0.99999

RB
30/1/63

0.999999

INDEX OF RELIABILITY


PEAK LOAD IN MW



R3
20/1/63

0.99999

0.9999



0.99999


RB
30/1/62

0.99999

INDEX OF RELIABILITY

PEAK LOAD IN MW

0.9999



INDEX OF RELIABILITY

PEAK LOAD IN MW.

APPENDIX B

APPENDIX B

The abbreviations used in the following tables are as follows:

C.S.M. SYSTEM	Combined Southern Manitoba System
G.R.	Grand Rapids
CAP OUT MW	Capacity Out of Service in MW
CUM PROB	Cumulative Probability
IND PROB	Individual Probability
DOUT	Risk in Days per Year
YOUT	Risk in Years per Day
RIND	Index of Reliability

Generating Unit Data for the Combined Southern Manitoba System is given on page 67.

INSTALLED CAPACITY 849.0000 MW
 DAYS 365.0
 NO OF LEVELS 19

CAP OUT MW	CUM PROB	IND PROB
.0000	1.000000	.643960
10.0000	.356040	.139120
20.0000	.216920	.074285
30.0000	.142535	.080412
40.0000	.062123	.018120
50.0000	.044003	.008373
60.0000	.035630	.023917
70.0000	.011713	.005244
80.0000	.006469	.002646
90.0000	.003823	.002576
100.0000	.001247	.000582
110.0000	.000665	.000263
120.0000	.000402	.000282
130.0000	.000120	.000063
140.0000	.000057	.000028
150.0000	.000029	.000022
160.0000	.000007	.000004
170.0000	.000003	.000002
180.0000	.000001	.000001

DOUT	YOUT	RIND	LOAD MW
6.318267	.16	.999453	849.0000
5.812037	.26	.999678	839.0000
2.266227	.44	.999815	829.0000
1.235179	.81	.999895	819.0000
.783306	1.28	.999941	809.0000
.458085	2.18	.999970	799.0000
.189177	5.29	.999986	789.0000
.100136	9.99	.999993	779.0000
.050264	19.89	.999996	769.0000
.020285	49.30	.999998	759.0000
.010428	95.89	.999999	749.0000
.005095	196.25	.999999	739.0000
.001810	552.24	.999999	729.0000
.000820	1218.47	1.000000	719.0000
.000343	2913.69	1.000000	709.0000
.000095	10445.80	1.000000	699.0000
.000035	28315.05	1.000000	689.0000
.000008	111615.98	1.000000	679.0000

C.S.M.SYSTEM & 50 MW FIRM CAPACITY PURCHASE

INSTALLED CAPACITY 899.0000 MW
 DAYS 365.0
 NO OF LEVELS 19

142

CAP OUT MW	CUM PROB	IND PROB
.0000	1.000000	.643960
10.0000	.856040	.139120
20.0000	.716920	.074305
30.0000	.582585	.060412
40.0000	.462123	.018120
50.0000	.344003	.008273
60.0000	.233630	.023917
70.0000	.111713	.005244
80.0000	.006469	.002646
90.0000	.003023	.002576
100.0000	.001247	.000582
110.0000	.000665	.000263
120.0000	.000402	.000282
130.0000	.000120	.000063
140.0000	.000057	.000028
150.0000	.000029	.000022
160.0000	.000007	.000004
170.0000	.000003	.000002
180.0000	.000001	.000001

DOUT	YOUT	RIND	LOAD MW
5.966864	.17	.999512	899.0000
3.597683	.28	.999713	889.0000
2.137315	.47	.999835	879.0000
1.164109	.86	.999906	869.0000
.737712	1.36	.999948	859.0000
.431107	2.32	.999974	849.0000
.177903	5.62	.999987	839.0000
.094097	10.43	.999994	829.0000
.047196	21.19	.999997	819.0000
.019032	52.54	.999998	809.0000
.009775	102.29	.999999	799.0000
.004772	209.53	.999999	789.0000
.001694	590.11	.999999	779.0000
.000767	1303.20	1.000000	769.0000
.000320	3119.17	1.000000	759.0000
.000089	11192.99	1.000000	749.0000
.000032	30369.86	1.000000	739.0000
.000008	119334.92	1.000000	729.0000

INSTALLED CAPACITY 959.0000 MW
 DAYS 365.0
 NO OF LEVELS 25

CAP	OUT	IND	CUM PROB	IND PROB
.0000	1.000000	.638808		
10.0000	.331192	.138007		
20.0000	.223185	.073790		
30.0000	.149295	.079769		
40.0000	.069626	.017975		
50.0000	.051651	.008306		
60.0000	.043345	.023726		
70.0000	.019619	.005202		
80.0000	.014417	.002625		
90.0000	.011792	.002555		
100.0000	.009237	.000577		
110.0000	.008660	.005413		
120.0000	.003247	.001393		
130.0000	.001654	.000657		
140.0000	.001197	.000671		
150.0000	.000526	.000167		
160.0000	.000359	.000071		
170.0000	.000288	.000193		
180.0000	.000095	.000043		
190.0000	.000052	.000021		
200.0000	.000031	.000021		
210.0000	.000010	.000005		
220.0000	.000005	.000002		
230.0000	.000003	.000002		
240.0000	.000001	.000001		

DOUT	YOUT	RIND	LOAD MW
6.151766	.16	.999426	959.0000
3.901258	.26	.999622	949.0000
2.496893	.40	.999748	939.0000
1.545488	.65	.999829	929.0000
1.101414	.91	.999882	919.0000
.767867	1.30	.999920	909.0000
.483100	2.07	.999945	899.0000
.354284	2.82	.999963	889.0000
.258538	3.87	.999975	879.0000
.178965	5.59	.999985	869.0000
.115623	8.63	.999991	859.0000
.054943	18.20	.999995	849.0000
.032055	31.20	.999997	839.0000
.018837	53.09	.999998	829.0000
.010176	98.27	.999999	819.0000
.006346	157.57	.999999	809.0000
.003692	270.81	.999999	799.0000
.001518	658.37	.999999	789.0000
.000796	1255.44	1.000000	779.0000
.000395	2528.21	1.000000	769.0000
.000152	6566.68	1.000000	759.0000
.000073	13680.33	1.000000	749.0000
.000032	30369.86	1.000000	739.0000
.000008	119834.92	1.000000	729.0000

C.S.M.SYSTEM & 2 UNITS AT G.R.

INSTALLED CAPACITY 1069.0000 MW

DAYS 365.0

NO OF LEVELS 29

144


CAP OUT MW	CUM PROB	INC PROB		
.0000	1.000000	.633698		
10.0000	.366302	.136903		
20.0000	.229399	.073200		
30.0000	.156199	.079130		
40.0000	.077069	.017831		
50.0000	.059238	.008239		
60.0000	.050999	.023536		
70.0000	.027463	.005160		
80.0000	.022303	.002604		
90.0000	.019399	.002535		
100.0000	.017164	.000573		
110.0000	.016391	.010480		
120.0000	.006111	.002486		
130.0000	.003625	.001243		
140.0000	.002382	.001304		
150.0000	.001078	.000310		
160.0000	.000768	.000137		
170.0000	.000631	.010382		
180.0000	.000249	.000084		
190.0000	.000165	.000042		
200.0000	.000123	.000041		
210.0000	.000082	.000009		
220.0000	.000073	.000045		
230.0000	.000028	.000013		
240.0000	.000015	.000006		
250.0000	.000009	.000005		
260.0000	.000004	.000001		
270.0000	.000003	.000001		
280.0000	.000002	.000002		
DOUT	YOUT	RIND	LOAD MW	
0.019453	.17	.999419	1069.0000	
0.972104	.25	.999594	1059.0000	
2.679846	.37	.999711	1049.0000	
1.790891	.56	.999790	1039.0000	
1.352671	.74	.999846	1029.0000	
1.012299	.99	.999889	1019.0000	
.714836	1.40	.999920	1009.0000	
.554777	1.80	.999944	999.0000	
.425200	2.36	.999962	989.0000	
.3305116	3.28	.999976	979.0000	
.260512	4.99	.999986	969.0000	
.097358	10.27	.999991	959.0000	
.059111	16.89	.999995	949.0000	
.036957	27.50	.999996	939.0000	
.021150	47.23	.999998	929.0000	
.014245	70.20	.999998	919.0000	
.009262	107.97	.999999	909.0000	
.005095	196.26	.999999	899.0000	
.003448	239.95	.999999	889.0000	
.002346	426.23	.999999	879.0000	
.001512	661.34	.999999	869.0000	
.000940	1053.77	1.000000	859.0000	
.00037	2237.89	1.000000	849.0000	
.000239	4179.32	1.000000	839.0000	
.000132	7570.75	1.000000	829.0000	
.000066	14958.87	1.000000	819.0000	
.000037	26597.22	1.000000	809.0000	

INSTALLED CAPACITY 1179.0000 MW
 DAYS 365.0
 NO OF LEVELS 29


CAP OUT MW	CUM PROB	IND PROB
.0000	1.000000	.628631
10.0000	.371369	.135308
20.0000	.205561	.072614
30.0000	.123947	.078498
40.0000	.084449	.017689
50.0000	.066760	.008174
60.0000	.053586	.023348
70.0000	.035238	.005119
80.0000	.030119	.002583
90.0000	.027536	.002515
100.0000	.025021	.000568
110.0000	.024453	.015463
120.0000	.008990	.003561
130.0000	.005429	.001818
140.0000	.003611	.001926
150.0000	.001685	.000449
160.0000	.001236	.000202
170.0000	.001034	.000567
180.0000	.000467	.000125
190.0000	.000382	.000062
200.0000	.000280	.000061
210.0000	.000219	.000014
220.0000	.000205	.000128
230.0000	.000077	.000033
240.0000	.000044	.000015
250.0000	.000029	.000016
260.0000	.000013	.000004
270.0000	.000009	.000002
280.0000	.000007	.000007

OUT	YOUT	RIND	LOAD MW
5.911601	.17	.999424	1179.0000
4.029612	.25	.999581	1169.0000
2.827973	.35	.999690	1159.0000
1.989866	.50	.999767	1149.0000
1.556298	.64	.999824	1139.0000
1.210362	.83	.999870	1129.0000
.902682	1.11	.999904	1119.0000
.717520	1.39	.999931	1109.0000
.557336	1.79	.999953	1099.0000
.408633	2.45	.999970	1089.0000
.271354	3.69	.999981	1079.0000
.134738	7.42	.999988	1069.0000
.084368	11.05	.999992	1059.0000
.053688	18.63	.999995	1049.0000
.033063	30.25	.999996	1039.0000
.023412	42.69	.999997	1029.0000
.016273	61.45	.999998	1019.0000
.010201	98.03	.999999	1009.0000
.007415	134.06	.999999	999.0000

.00043	184.12	.999999	989.0000
.000746	266.88	.999999	979.0000
.002410	414.81	.999999	969.0000
.001135	880.69	1.000000	959.0000
.000653	1529.41	1.000000	949.0000
.000375	2661.30	1.000000	939.0000
.000109	5265.94	1.000000	929.0000
.000105	9441.77	1.000000	919.0000
.000041	21346.19	1.000000	909.0000



0.9999



INDEX OF RELIABILITY

PEAK LOAD IN MW.

0.999999

RB
30/1/63